



2025 Annual Groundwater Monitoring and Corrective Action Report

*AVS CCR Landfill
Antelope Valley Station, Beulah, North Dakota*



Prepared for
Basin Electric Power Cooperative


Prepared by
Barr Engineering Co.

January 2026

4585 Coleman Street, Suite 210
Bismarck, ND 58503
701.255.5460

barr.com





2025 Annual Groundwater Monitoring and Corrective Action Report

January 2026

Contents

| | | |
|-------|--|---|
| 1 | Executive Summary | 1 |
| 2 | Introduction | 2 |
| 2.1 | Physical Setting..... | 2 |
| 2.2 | Purpose | 3 |
| 2.3 | CCR Rule Requirements..... | 3 |
| 3 | Groundwater Monitoring Program..... | 5 |
| 3.1 | Groundwater Monitoring System..... | 5 |
| 3.1.1 | Changes to Groundwater Monitoring System | 6 |
| 3.2 | Actions Completed/Problems Encountered | 6 |
| 3.3 | Data and Collection Summary | 6 |
| 3.3.1 | June 2025 Detection Monitoring Event | 6 |
| 3.3.2 | October 2025 Detection Monitoring Event..... | 7 |
| 3.4 | Activities for Upcoming Year | 7 |
| 4 | References | 8 |



Tables

| | | |
|---------|--|---|
| Table 1 | CCR Rule Requirements and Compliance | 3 |
| Table 2 | Groundwater Monitoring System | 5 |

Attached Tables

| | |
|------------------|---------------------------------------|
| Attached Table 1 | Sampling Summary |
| Attached Table 2 | Statistical Evaluation Summary |
| Attached Table 3 | Water Quality Analytical Data Summary |

Figures

| | |
|----------|--|
| Figure 1 | Site Location |
| Figure 2 | Monitoring Network |
| Figure 3 | Spring 2025 Potentiometric Surface Map |
| Figure 4 | Fall 2025 Potentiometric Surface Map |

Appendices

| | |
|------------|-----------------------------------|
| Appendix A | Lab and Field Reports |
| Appendix B | Alternative Source Demonstrations |
| Appendix C | Groundwater Flow Rate |
| Appendix D | Baseline Sample Results |



Abbreviations

| | |
|-------|--|
| asm | above mean sea level |
| ASD | Alternative Source Demonstration |
| AVS | Antelope Valley Station |
| bgs | below ground surface |
| CCR | Coal Combustion Residuals |
| CFR | Code of Federal Regulations |
| cm | centimeters |
| EPA | Environmental Protection Agency |
| FGD | flue gas desulfurization |
| ft | feet |
| NDAC | North Dakota Administrative Code |
| NDDEQ | North Dakota Department of Environmental Quality |
| SAP | Sampling and Analysis Plan |
| sec | second |
| SSI | Statistically Significant Increase |
| TDS | Total Dissolved Solids |

1 Executive Summary

This 2025 Annual Groundwater Monitoring and Corrective Action Report (Annual Report) describes the monitoring program and results for the Coal Combustion Residuals (CCR) landfill at Basin Electric Power Cooperative's (Basin Electric) Antelope Valley Station (Site). The permitted landfill is the only CCR Unit at this Site. The content of this report is to satisfy the requirements of the federal CCR rule.

In 2018, the CCR Unit began operating under a detection monitoring program as described in 40 CFR § 257.94 and NDAC 33.1-20-08-06-04. At the beginning, end, and throughout 2025, the CCR Unit was operating under a detection monitoring program with semi-annual detection monitoring events conducted in the spring and fall. Landfill expansion required the installation of three additional monitoring wells in September 2020: background well MW-21(S) and downgradient wells MW-22(S) and MW-24(S). In late 2023, three new downgradient landfill expansion wells, MW-25(S), MW-26(S), and MW-27(S), were installed at the Site. In May 2023, CCR waste began being placed into the landfill expansion area. A successful ASD was completed in 2025 for verified SSIs at the end of the 2024 reporting period. During this report timeframe, and pursuant to § 257.94 and NDAC 33.1-20-08-06-04, statistically significant increases (SSIs) were determined for:

- June 2025: chloride at MW-16(S), MW-20(S), MW-24(S), MW-25(S), and MW-26(S) and boron, calcium, chloride, and total dissolved solids (TDS) at MW-27(S)
- October 2025: chloride at MW-16(S), MW-20(S), MW-24(S), and MW-25(S); calcium and chloride at MW-26(S); and boron, calcium, chloride, and TDS at MW-27(S)

Subsequent determinations and actions (if any) will be addressed in the 2026 Annual Report. Successful alternative source demonstrations (ASDs) were completed for the SSIs determined during the October 2024 and June 2025 sampling events. The ASD documentation for SSIs determined for both the fall 2024 and spring 2025 monitoring events are included in this report under Figure 2. An ASD for the October 2025 detection monitoring results is in progress, and results of the ASD are anticipated in 2026. Therefore, no assessment monitoring program (§ 257.95 and NDAC 33.1-20-08-06-04) or related corrective or remedial measures (§§ 257.96, 257.97, and 257.98; NDAC 33.1-20-08-06-06, -07, and -08) were necessary.

2 Introduction

Basin Electric Power Cooperative (Basin Electric) owns and operates Antelope Valley Station (AVS), comprised of a coal-fired generating station consisting of two power generating units, located in Beulah, North Dakota (Figure 1). Unit 1 coal-based operations began in 1984 and Unit 2 operations began in 1986. One coal combustion residual (CCR) unit, as defined by 40 CFR 257.53 and North Dakota Administrative Code (NDAC) 33.1-20-08-01, is located on the property. The landfill (Site or CCR Landfill) was permitted by the North Dakota Department of Environmental Quality (NDDEQ) in 1995 under Permit SP-160 (now designated 0160) and began accepting CCR in 1996. The most recent Permit 0160 was issued by NDDEQ in early 2022, and the most recent cell including a composite liner system and leachate collection system was constructed the same year.

The CCRs including fly ash, bottom ash, and flue gas desulfurization (FGD) waste are managed at the Site along with other minor wastes accepted as per the NDDEQ permit. The CCR unit is required to comply with the provisions of the US Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261, Disposal of Coal Combustion Residuals from Electric Utilities) and the NDDEQ CCR Rule (NDAC Title 33.1, Article 20, Chapter 8).

This Annual Report describes the monitoring program and results for the CCR landfill. No corrective actions were required or conducted in 2025.

Basin Electric utilizes a consulting firm, Barr Engineering Co. (Barr) to assist in groundwater reporting and analysis. Barr is familiar with the Site and installed and certified the most recent added to the network wells (MW-25(S), MW-26(S), and MW-27(S)). Barr has reviewed the historical groundwater data, CCR information for the Site, and is knowledgeable about facility design and operation.

Additional Site monitoring information, including CCR reports and certifications can be found on Basin Electric's CCR website: [Section 7 CCR Landfill - AVS - Basin Electric Power Cooperative](#).

2.1 Physical Setting

The geology underlying the Site includes mine spoils underlain by the Sentinel Butte Formation. This formation is comprised of continental deposits more than 1,000-feet thick, consisting of dense clay, weakly cemented sandstone, mudstone, and lignite beds.

The base of the CCR Landfill is underlain by 115 to 200 feet (approximately) of clay-rich mine spoil that overlies the Lower Sentinel Butte Formation. At the Site, the Sentinel Butte is comprised primarily of dense clay with a trace of very fine sand and lignite beds typically ranging from 6- to 9-feet thick.

The uppermost aquifer is found within the 6- to 9-foot unmined lignite bed, mapped locally as the Spaer Bed or Spaer Lignite, located at depths ranging roughly from 180 to 260 feet below ground surface (ft bgs). The elevation of the Spaer Lignite varies across the Site by approximately 35 feet from 1,844 feet above mean sea level (ft amsl) at MW-18(S) to 1,879 ft amsl at MW-23(S). The potentiometric surface reflects that variation.

Across the southern portions of the landfill, the potentiometric surface generally slopes to the east with groundwater elevations ranging from approximately 1,893 ft amsl on the western side of the CCR Landfill to 1,886 ft amsl on the eastern side. In the northern portion of the landfill, the potentiometric surface generally slopes to the northeast with groundwater elevations ranging from 1,893 ft amsl in the

southwestern corner to 1,864 ft amsl in the northeastern corner. Field hydraulic conductivity measurements from 2017 for the uppermost aquifer range from 1.65×10^{-4} centimeters per second (cm/sec) in MW-19(S) to 2.48×10^{-9} cm/sec in Well MW-16(S).

Additional Site information can be found on Basin Electric's CCR website in the CCR Groundwater Monitoring System Report (AECOM, October 2017).

2.2 Purpose

As stated in § 257.90(e) and NDAC 33.1-20-08-06-01(e), the Annual Report must:

- Document the status of groundwater monitoring and any corrective action programs for the CCR unit,
- Summarize key actions completed,
- Describe any problems encountered,
- Discuss actions to resolve the problems, and
- Project key activities for the upcoming year.

2.3 CCR Rule Requirements

Additional requirements for the Annual Report, as outlined in § 257.90(e) and NDAC 33.1-20-08-06-01(e), and this Site's compliance with the CCR Rules, are summarized in Table 1.

Table 1 CCR Rule Requirements and Compliance

| EPA CCR Rule Reference (40 CFR) | NDDEQ CCR Rule Reference (NDAC) | Content Required in Report | Location |
|---------------------------------|---------------------------------|--|---|
| § 257.90(e)(1) | § 33.1-20-08-06-01(e)(1) | Monitoring System Figure: A map, aerial image, or diagram showing the CCR unit and all background (or upgradient) and downgradient monitoring wells, to include the well identification numbers, that are part of the groundwater monitoring program for the CCR unit. | Section 2.1 Groundwater Monitoring System; see 3.2 |
| § 257.90(e)(2) | § 33.1-20-08-06-01(e)(2) | Monitoring System Adjustments: Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken. | Section 3.1.1 Changes to Groundwater Monitoring System |
| § 257.90(e)(3) | § 33.1-20-08-06-01(e)(3) | Data and Collection Summary: In addition to all the monitoring data obtained under § 257.90 through § 257.98 and § 33.1-20-08-06, a summary including the number of groundwater samples that were collected, and whether the sample was required by the detection monitoring or assessment monitoring programs. | Section 3.3 Data and Collection Summary; monitoring data included in Attached Table 1, Attached Table 2, Attached Table 3, Appendix A, and Appendix C |

| EPA CCR Rule Reference (40 CFR) | NDDEQ CCR Rule Reference (NDAC) | Content Required in Report | Location |
|---------------------------------|---------------------------------|--|--|
| § 257.90(e)(4) | § 33.1-20-08-06-01(e)(4) | Monitoring Program: A narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from detection monitoring to assessment monitoring in addition to identifying the constituent(s) detected at a statistically significant increase over background levels). | Not applicable – No transition between monitoring programs was necessary |
| § 257.90(e)(5) | § 33.1-20-08-06-01(e)(5) | Other Information: Other information required, if applicable, to be included in the annual report as specified in § 257.90 through § 257.98 and § 33.1-20-08-06. | Section 3.2 Actions Completed/Problems Encountered; Appendix B |
| § 257.90(e)(6) | N/A | Executive Summary: A section at the beginning of the annual report that provides an overview of the current status of groundwater monitoring and corrective action programs for the CCR unit. | Executive Summary |

3 Groundwater Monitoring Program

This section documents the status of the groundwater monitoring and corrective action program for the CCR unit in 2025. A description of the groundwater monitoring system is included in Section 3.1, key actions completed and problems encountered are described in Section 3.2, the monitoring and analytical results are described in Section 3.3, and key activities planned for 2025 are described in Section 0.

3.1 Groundwater Monitoring System

The certified groundwater monitoring well network around the CCR unit consists of three background wells and nine downgradient wells, sampled for groundwater analysis on a semi-annual basis as described in Table 2.

Table 2 **Groundwater Monitoring System**

| CCR Unit | Background Wells | Downgradient Wells |
|-------------------------|--------------------|--|
| Active Landfill | MW-18(S), MW-19(S) | MW-15(S), MW-16(S), MW-17(S), MW-20(S) |
| Landfill Expansion Area | MW-21(S) | MW-22(S), MW-24(S), MW-25(S), MW-26(S), MW-27(S) |

The wells monitor the uppermost aquifer underlying the CCR unit in the lignite bed mapped locally as the Spaer Bed or the Spaer Lignite, within the Sentinel Butte Formation approximately 180 to 260 ft bgs. Well locations are shown on Figure 2. Monitoring wells MW-21(S), MW-22(S), MW-23(S), and MW-24(S) were installed in September 2020 in advance of northward landfill expansion to be used as background and downgradient monitoring wells. Wells MW-25(S), MW-26(S), and MW-27(S) were installed in late-2023 to provide enhanced downgradient coverage for the future expansion area. Background wells monitor background water quality that is not potentially influenced by the presence of the CCR unit.

Two monitoring wells, MW-14(S) and MW-23(S) have been historically excluded from the groundwater monitoring network due to insufficient water production. The wells remain in place for optional collection of groundwater level measurements for potential inclusion in the potentiometric evaluation of the Site.

Baseline monitoring was initiated in August 2016 for wells in the pre-expansion portion of the monitoring network and included sampling groundwater over ten baseline monitoring events. Baseline monitoring for wells MW-21(S), MW-22(S), MW-23(S), and MW-24(S) began in the spring of 2021 and continued through 2022. These wells were added to the well network in May 2023. The results of baseline monitoring are discussed in previous Annual Reports.

Detection monitoring events in and prior to 2025 were performed in general accordance with procedures established in the site-specific Sampling and Analysis Plan (SAP) (AECOM, January 2018), which is included in the facility's Operating Record. The CCR Landfill was placed in Detection monitoring in October 2017, with the first Detection monitoring groundwater sampling event completed in April 2018. Detection monitoring events have been completed semi-annually since April 2018. The results of previous Detection monitoring events were presented and discussed in the previous Annual Reports, which can be found on Basin Electric's CCR website.

3.1.1 Changes to Groundwater Monitoring System

Monitoring locations MW-25(S), MW-26(S), and MW-27(S) were added to the monitoring network in late 2023 in anticipation of waste placement in the landfill expansion area. Baseline monitoring and inclusion in detection monitoring began in June 2024 and will continue until at least eight samples have been collected. Baseline sampling results are included in Appendix D. The system described in Section 3.1 and shown on Figure 2 are described in the Groundwater Monitoring System Certification (Barr Engineering Co. (Barr), June 2024).

3.2 Actions Completed/Problems Encountered

The following actions were completed in 2025:

- **Baseline Sampling:** Baseline Groundwater samples were collected at MW-25(S), MW-26(S), and MW-27(S) in June and October 2025 (Appendix D).
- **Detection Monitoring Sampling:** Groundwater samples were collected from each well in the groundwater monitoring system on June 10-11 and 17-18, 2025 and August 26, October 7-8, 2025. Groundwater samples were analyzed for Appendix III constituents, per the detection monitoring program of the CCR Rules (§ 257.94 and NDAC 33.1-20-08-06-04) (Attached Table 1).
- **SSI Evaluation:** SSI evaluations were conducted in accordance with the Groundwater Statistical Method Selection Certification (AECOM, 2017) for the June 2025 and October 2025 detection monitoring events. Both detection monitoring events resulted in verified SSIs (Attached Table 2).
- **Alternative Source Demonstration (ASD):** ASDs were conducted on the verified SSIs for the October 2024 and June 2025 detection monitoring events. The October 2024 SSIs were identified in the 2024 Annual Report (Barr Engineering Co. (Barr), January 2025). Both ASDs demonstrated an alternative source, as allowed by the CCR Rules (§ 257.94(e)(2) and NDAC 33.1-20-08-06-04(e)(2)). An ASD for the October 2025 detection monitoring event is in progress and will be completed within 90 days of the SSI determination. More details are provided in Section 3.3. Subsequent determinations and actions (if any) will be addressed in the 2026 Annual Report.

Problems encountered in 2025:

- The water levels and field turbidity for samples collected at MW-27(S) suggest the well was screened in a low yielding interval of the uppermost aquifer. Groundwater may not fully recharge for the Site's semi-annual sampling frequency.

3.3 Data and Collection Summary

3.3.1 June 2025 Detection Monitoring Event

Groundwater samples were collected from the twelve groundwater monitoring network wells at the Site on June 10-11 and 17-18, 2025. Nine SSIs (chloride at MW-16(S), MW-20(S), MW-24(S), MW-25(S), MW-26(S) and boron, calcium, chloride, and total dissolved solids (TDS) at MW-27(S)) were identified. No verification resampling was performed. A summary of results is included in Attached Table 3. Field data sheets and analytical laboratory reports for detection monitoring sampling are included in Appendix A. Water level contours are shown on Figure 3, and flow calculations are included in Appendix C.

An ASD was conducted on the verified SSIs and was able to successfully demonstrate that a natural variation in groundwater quality and/or "a source other than the CCR unit" and/or statistical methods and/or sampling methods resulted in the SSIs, as allowed by § 257.94(e)(2) and NDAC 33.1-20-08-06-04(e)(2). The Alternative Source Demonstration: June 2025 Event Report is included in Appendix B.

3.3.2 October 2025 Detection Monitoring Event

Groundwater samples were collected from the twelve groundwater monitoring network wells at the Site on August 26 and October 7-8, 2025. Ten SSIs (chloride at MW-16(S), MW-20(S), MW-24(S), MW-25(S); calcium and chloride at MW-26(S); and boron, calcium, chloride, and TDS at MW-27(S)) were identified. No verification resampling was performed. A summary of results is included in Attached Table 3. Field data sheets and analytical laboratory reports for detection monitoring sampling are included in Appendix A. Water level contours are shown on Figure 4, and flow calculations are included in Appendix C.

An ASD was ongoing at the beginning of 2026. If the ASD is not successful, appropriate actions will be initiated per the CCR Rule as applicable.

3.4 Activities for Upcoming Year

The following key activities for analytical results and statistical evaluations are planned for 2026:

- Complete the ASD or assessment monitoring determination for the October 2025 detection monitoring event in accordance with the Statistical Certification (AECOM, October 2017).
- Evaluate analytical results from 2026 semi-annual detection monitoring events for SSIs according to the Statistical Certification (AECOM, October 2017).
- Continue baseline sample collection at MW-25(S), MW-26(S), and MW-27(S) until eight baseline samples have been collected.
- Evaluate sampling frequency and recharge rates at MW-27(S).
- Review the conceptual site model and consider recommendations for improvements to the monitoring well network if needed.

4 References

AECOM. (January 2018). *Sampling and Analysis Plan, CCR Monitoring Program, Antelope Valley Station. Prepared for Basin Electric Power Cooperative.* .


AECOM. (October 2017). *CCR Groundwater Monitoring System Report, Antelope Valley Station. Prepared for Basin Electric Power Cooperative.* .

Barr Engineering Co. (Barr). (January 2025). *2024 Annual Groundwater Monitoring and Corrective Action Report: AVS CCR Landfill.*

Barr Engineering Co. (Barr). (June 2024). *Groundwater Monitoring System Certification, Antelope Valley Station Landfill. Prepared for Basin Electric Power Cooperative.* .



Attached Tables



Attached Table 1
Sampling Summary
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

| Event Classification and Number | Monitoring Well | Up or Down Gradient | Event date | No. Samples |
|---------------------------------|-----------------|---------------------|------------|-------------|
| Detection Monitoring Event #1 | MW-15S | Down | 6/10/2025 | 1 |
| Detection Monitoring Event #1 | MW-16S | Down | 6/11/2025 | 1 |
| Detection Monitoring Event #1 | MW-17S | Down | 6/18/2025 | 1 |
| Detection Monitoring Event #1 | MW-18S | Up | 6/17/2025 | 1 |
| Detection Monitoring Event #1 | MW-19S | Up | 6/19/2025 | 2 |
| Detection Monitoring Event #1 | MW-20S | Down | 6/10/2025 | 1 |
| Detection Monitoring Event #1 | MW-21S | Up | 6/18/2025 | 1 |
| Detection Monitoring Event #1 | MW-22S | Down | 6/11/2025 | 2 |
| Detection Monitoring Event #1 | MW-24S | Down | 6/17/2025 | 1 |
| Detection Monitoring Event #1 | MW-25S | Down | 6/11/2025 | 1 |
| Detection Monitoring Event #1 | MW-26S | Down | 6/11/2025 | 1 |
| Detection Monitoring Event #1 | MW-27S | Down | 6/17/2025 | 1 |
| Detection Monitoring Event #2 | MW-15S | Down | 10/7/2025 | 1 |
| Detection Monitoring Event #2 | MW-16S | Down | 10/8/2025 | 1 |
| Detection Monitoring Event #2 | MW-17S | Down | 10/8/2025 | 1 |
| Detection Monitoring Event #2 | MW-18S | Up | 8/26/2025 | 1 |
| Detection Monitoring Event #2 | MW-19S | Up | 8/26/2025 | 2 |
| Detection Monitoring Event #2 | MW-20S | Down | 10/7/2025 | 1 |
| Detection Monitoring Event #2 | MW-21S | Up | 8/26/2025 | 1 |
| Detection Monitoring Event #2 | MW-22S | Down | 10/8/2025 | 2 |
| Detection Monitoring Event #2 | MW-24S | Down | 10/8/2025 | 1 |
| Detection Monitoring Event #2 | MW-25S | Down | 10/8/2025 | 1 |
| Detection Monitoring Event #2 | MW-26S | Down | 10/8/2025 | 1 |
| Detection Monitoring Event #2 | MW-27S | Down | 10/8/2025 | 1 |

Attached Table 2
Statistical Evaluation Summary
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

Spring 2025

| Appendix III Constituents | | | | | | |
|----------------------------------|-----------|-------------|----------|----------|-----|---------|
| Well | Boron (T) | Calcium (T) | Chloride | Fluoride | pH | Sulfate |
| MW-15(S) | 0.12 | 3.79 | 13.2 | 1.32 | 8.0 | 356 |
| MW-16(S) | 0.14 | 5.41 | 26.2 | 2.04 | 8.1 | 107 |
| MW-17(S) | 0.12 | 4.05 | 13 | 1.63 | 7.9 | 293 |
| MW-20(S) | 0.12 | 4.65 | 24.6 | 1.16 | 8.0 | 1,760 |
| MW-22(S) | 0.12 | 2.49 | 11.1 | 1.75 | 8.1 | 193 |
| MW-24(S) | 0.11 | 4.35 | 49.6 | 1.56 | 8.1 | 62.4 |
| MW-25(S) | 0.12 | 4.01 | 39.6 | 1.26 | 8.2 | 29.8 |
| MW-26(S) | 0.13 | 11 | 30.6 | 1.28 | 8.1 | 75.9 |
| MW-27(S) | 0.68 | 419 | 64.9 | 1.41 | 8.1 | 230 |

Fall 2025

| Appendix III Constituents | | | | | | |
|----------------------------------|-----------|-------------|----------|----------|-----|---------|
| Well | Boron (T) | Calcium (T) | Chloride | Fluoride | pH | Sulfate |
| MW-15(S) | 0.11 | 3.93 | 13.1 | 1.4 | 8.1 | 486 |
| MW-16(S) | 0.15 | 3.71 | 32.6 | 2.37 | 8.2 | 125 |
| MW-17(S) | 0.12 | 3.72 | 13.6 | 1.48 | 8.0 | 300 |
| MW-20(S) | 0.13 | 6.19 | 25.6 | 1.2 | 8.0 | 74.8 |
| MW-22(S) | 0.12 | 2.56 | 11.4 | 1.84 | 8.2 | 234 |
| MW-24(S) | 0.1 | 4.54 | 49.7 | 1.61 | 8.1 | 52.6 |
| MW-25(S) | 0.14 | 4.56 | 40.4 | 1.42 | 8.2 | 36 |
| MW-26(S) | 0.12 | 17.3 | 31.5 | 1.36 | 8.1 | 120 |
| MW-27(S) | 0.21 | 58.1 | 65.0 | 1.48 | 8.0 | 141 |

Sample had a value higher than the prediction limit determined from background data and is a verified SSI

Sample did not have a value higher than the prediction limit determined from background data

pH: two-sided prediction limit; color indicates sample higher and/or lower than prediction limits

No data at MW-14(S) and MW-23(S) as they have been historically dry

Attached Table 3
Water Quality Analytical Data Summary
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

| Parameter | Analysis | Location | MW-45S | MW-15S | MW-16S | MW-17S | MW-17S | MW-18S | MW-18S | MW-19S | MW-19S | MW-20S | MW-20S | MW-21S | MW-21S | MW-22S | MW-22S |
|-------------------------|----------|----------|--------|-----------|------------|-----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | | Date | 6/10/2025 | 10/07/2025 | 8/11/2025 | N | N | N | N | N | N | N | N | N | N | FD |
| Sample Type | Units | | | | | | | | | | | | | | | | |
| Boron, total | mg/l | Lab | 0.12 | 0.11 | 0.14 | 0.15 | 0.12 | 0.12 | 0.10 | <0.1 | 0.13 | 0.12 | 0.12 | 0.11 | 0.12 | 0.12 | 0.12 |
| Calcium, total | mg/l | Lab | 3.79 | 3.33 | 5.41 | 3.71 | 4.05 | 3.72 | 4.43 | 4.29 | 4.30 | 4.17 | 4.14 | 4.54 | 4.16 | 2.49 | 2.38 |
| Chloride | mg/l | Lab | 13.2 | 13.1 | 26.2 | 32.6 | 13.0 | 13.6 | 8.5 | 8.7 | 18.5 | 18.7 | 18.8 | 18.8 | 18.0 | 11.1 | 11.1 |
| Fluoride | mg/l | Lab | 1.32 | 1.40 | 2.04 | 2.37 | 1.63 | 1.48 | 1.32 | 1.23 | 0.73 | 0.77 | 0.66 | 0.68 | 1.16 | 1.20 | 1.65 |
| pH | pH units | Field | 8.01 | 8.06 | 8.08 | 8.21 | 7.91 | 8.02 | 9.36 | 9.30 | 8.01 | — | 8.02 | 7.97 | 7.88 | 8.14 | — |
| Solids, total dissolved | mg/l | Lab | 1910 | 1930 | 1200 | 1150 | 1740 | 1780 | 1860 | 2180 | 2190 | 2170 | 1760 | 1800 | 2030 | 1890 | 1670 |
| Sulfate, as SO4 | mg/l | Lab | 356 | 466 | 107 | 125 | 293 | 300 | 555 | 596 | 696 | 738 | 749 | 561 | 74.8 | 401 | 403 |

— Not analyzed/Not available.


N: Sample Type: Normal

FD: Sample Type: Field Duplicate

U: The analyte was analyzed for, but was not detected.



Figures





Batt Footer: ArcGISPro 3.3.1, 2025-03-26 11:07 File: [Projects\34291\1134\Mars\Antelope Valley Station Alternative Source\Antelope Valley Station Alternative Source.mxd] Location Map User: GCR Layout: Figure 1 Site

— Permit Boundary
— Railroad




0 2,500 5,000
Foot

Imagery: USDA-NAIP, 2024


Site Location
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota

FIGURE 1

BARR.



- Groundwater Monitoring System Wells
- △ Water Level Only Monitoring
- Permit Boundary
- Existing Landfill Limits
- Future Expansion Limit
- ▨ Leachate Management Area
- ▨ Limits of Ash as of 2025 (approximate)




Imagery: USDA-NAIP, 2024

Monitoring Network
Antelope Valley Station
 Basin Electric Power Cooperative
 Beulah, North Dakota

FIGURE 2

BARR



- Groundwater Monitoring System Wells
- △ Water Level Only Monitoring
- Permit Boundary
- Existing Landfill Limits
- ▨ Future Expansion Limit
- ▨ Leachate Management Area
- ▨ Limits of Ash as of 2025 (approximate)
- Groundwater Contours
- Flow Direction




0 300 600
Feet

Imagery: USDA-NAIP, 2024


**Spring 2025 Potentiometric Surface
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota**

FIGURE 3

BARR



- Groundwater Monitoring System Wells
- △ Water Level Only Monitoring
- Permit Boundary
- Existing Landfill Limits
- Future Expansion Limit
- Leachate Management Area
- Limits of Ash as of 2025 (approximate)
- Flow Direction
- Groundwater Contour



Imagery: USDA-NAIP, 2024


**Fall 2025 Potentiometric Surface
Antelope Valley Station
2025 Annual Monitoring Report
Basin Electric Power Cooperative
Beulah, North Dakota**

FIGURE 4

BARR.




Appendices





Appendix A

Lab and Field Reports





Appendix B

Alternative Source Demonstrations



Technical Memorandum

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Project: 34291134.00

1 Introduction

Basin Electric Power Cooperative (Basin Electric) owns and operates Antelope Valley Station (AVS), comprised of a coal-fired generating station consisting of two power generating units, located in Beulah, North Dakota (Figure 1). Unit 1 coal-based operations began in 1984, and Unit 2 operations began in 1986. The landfill (Site or CCR Landfill) was permitted by the North Dakota Department of Environmental Quality (NDDEQ) in 1995 under Permit SP-160 (now designated 0160) and began accepting coal combustion residuals (CCR) in 1996. The most recent Permit 0160 was issued by NDDEQ in early 2022, and the most recent cell including a composite liner system and leachate collection system was constructed the same year. Basin Electric utilizes a consulting firm, Barr Engineering Co. (Barr) to assist in groundwater reporting and analysis. Barr is familiar with the site and installed and certified the most recent wells (MW-25S, MW-26S, and MW-27S) added to the network. Barr has reviewed the historical groundwater data and CCR information for the site and is knowledgeable about facility design and operation.

The CCRs including fly ash, bottom ash, and flue gas desulfurization (FGD) waste are managed at the Site along with other minor wastes accepted as per the NDDEQ permit. The CCR unit is required to comply with the provisions of the US Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261, Disposal of Coal Combustion Residuals from Electric Utilities) and the NDDEQ CCR Rule (NDAC Title 33.1, Article 20, Chapter 8).

Basin Electric has implemented a Detection Monitoring Program in accordance with the U.S. Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261) for the Site. As part of the Detection Monitoring Program, statistically significant increases (SSIs) in monitored groundwater quality parameters over background were identified at the Site for the following monitoring wells during semi-annual detection monitoring completed in the fall of 2024 on October 1-2 and 8, 2024:

- MW-16S – Chloride
- MW-20S – Chloride
- MW-24S – Chloride
- MW-25S – Chloride
- MW-26S – Chloride
- MW-27S – Boron, calcium, and chloride

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 2

The CCR Rule (US EPA, 2015) § 257.94(e)(2) allows for an alternative source demonstration (ASD) in the event of an identified SSI in a water quality parameter in a downgradient monitoring well over background levels:

The owner or operator may demonstrate that a source other than the CCR unit caused the statistically significant increase over background levels for a constituent or that the statistically significant increase resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. The owner or operator must complete the written demonstration within 90 days of detecting a statistically significant increase over background levels to include obtaining a certification from a qualified professional engineer verifying the accuracy of the information in the report.

The purpose of this work is to evaluate the data collected as part of the October 2024 monitoring event, along with historical data, to demonstrate if the SSIs are the results of a “source other than the CCR unit” or due to natural variation in groundwater quality or an error in sampling, analysis, or statistical evaluation. Nothing in the foregoing citation of the rule requires that the owner/operator disprove any and all potential counterarguments that EPA or others may offer to refute this demonstration. Such arguments if valid, would need to follow requirements of the rule to show a basis in fact that includes rule requirements that are based on site-specific information, and must be certified by a North Dakota licensed professional engineer. This memorandum provides a science-based reason for the data results that indicate a source other than the CCR unit.

This memorandum provides written documentation of an Alternative Source Demonstration (ASD) and certification of accuracy as described in the CCR Rule (§ 257.94(e)(2)).

1.1 Background Information

Figure 1 shows the site location and Figure 2 provides well locations. A piezometric surface map showing groundwater elevations in the lignite, which represent the uppermost aquifer in the vicinity of the CCR landfill, is presented on Figure 3, using measurements from October 2024. Groundwater generally flows from southwest to northeast.

In late 2023, three new landfill expansion wells, MW-25S, MW-26S, and MW-27S, were installed at the Site. Baseline sampling was initiated in June 2024, and these wells were first evaluated in the detection monitoring program in June 2024. There is limited data at these locations for historical comparison.

A comparison of the detection monitoring groundwater results with the prediction limits calculated using the 2016-2023 background assessment data from upgradient wells MW-18S, MW-19S, and MW-21S are included in Table 1. Concentrations for Appendix III parameters observed in October 2024 are shown on time series graphs in Attachment A. Chloride concentrations at MW-16S, MW-20S, and MW-24S are consistent with those observed during baseline monitoring events. Baseline monitoring for MW-25S, MW-26S, and MW-27S is ongoing.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 3

Table 1 SSIs Compared to Prediction Limits

| Event | Well | Parameter (units) | Measured | Interwell Prediction Limit |
|---------------------------------------|--------|-------------------|----------|----------------------------|
| Detection Monitoring – 2024 #2 (Fall) | MW-16S | Chloride (mg/L) | 26.0 | 18.7 |
| | MW-20S | Chloride (mg/L) | 25.8 | 18.7 |
| | MW-24S | Chloride (mg/L) | 50.0 | 18.7 |
| | MW-25S | Chloride (mg/L) | 42.3 | 18.7 |
| | MW-26S | Chloride (mg/L) | 29.7 | 18.7 |
| | MW-27S | Boron (mg/L) | 0.40 | 0.17 |
| | MW-27S | Calcium (mg/L) | 206 | 13.0 |
| | MW-27S | Chloride (mg/L) | 62.0 | 18.7 |

1.2 Rule Requirements

The requirements for written documentation and certification of accuracy for an ASD are included in § 257.95(g) (3):

Within 90 days of finding that any of the constituents listed in appendix IV to this part have been detected at a statistically significant level exceeding the groundwater protection standards the owner or operator must... Demonstrate that a source other than the CCR unit caused the contamination, or that the statistically significant increase resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. Any such demonstration must be supported by a report that includes the factual or evidentiary basis for any conclusions and must be certified to be accurate by a qualified professional engineer or approval from the Participating State Director or approval from EPA where EPA is the permitting authority. If a successful demonstration is made, the owner or operator must continue monitoring in accordance with the assessment monitoring program pursuant to this section, and may return to detection monitoring if the constituents in Appendix III and Appendix IV of this part are at or below background as specified in paragraph (e) of this section. The owner or operator must also include the demonstration in the annual groundwater monitoring and corrective action report required by §257.90(e), in addition to the certification by a qualified professional engineer or the approval from the Participating State Director or the approval from EPA where EPA is the permitting authority.

In accordance with the above requirement, this memorandum is being issued within 90 days of the SSI determination (January 3, 2025) following the review and analysis of the results provided in the final laboratory report which was received on October 18, 2024.

2 Potential Alternative Sources Review

The CCR Rule provides five potential alternative source categories:

1. A source other than the CCR unit
2. Sampling (or sampling equipment) methods

3. Laboratory methods
4. Statistical methods
5. Natural variation in groundwater quality

Site data were evaluated to identify potential causes for chloride concentrations in monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, and MW-26S; and boron, calcium, and chloride concentrations in MW-27S exceeding interwell prediction limits. Chloride is naturally occurring and may not necessarily be the result of a release from a CCR unit; therefore, a source other than the CCR unit, natural variation in groundwater quality, and statistical methods were further investigated as part of the ASD. Sampling methods were further investigated for the boron, calcium, and chloride SSIs at MW-27S.

2.1 Travel Time from Source of Release

Monitoring locations MW-24S, MW-25S, MW-26S, and MW-27S were added to the monitoring network in anticipation of waste placement in the landfill expansion area (Figure 3). Waste was first placed in lined Cell 5 in the landfill expansion area in May 2023. Groundwater travel time was considered both vertically as groundwater moves through the unsaturated zone and horizontally as groundwater moves in the saturated zone.

2.1.1 Migration through the liner

Vertical migration of leachate would be controlled by the presence of a driving head on the landfill liner and then migration through the unsaturated zone.

Considering the properties of the CCR materials in landfill, that the design to eliminate head on the liner, and the facility pumping operations have been normal, there is no evidence of any leachate accumulation on the liner. However, landfill leachate depth is limited to 1 foot on the liner by rule in North Dakota. Even if the 60-mil thick synthetic liner were breached (again there is no evidence that this has ever occurred), the underlying 2-foot-thick clay liner was tested and verified to exhibit a vertical permeability of 1×10^{-7} cm/s (2.8×10^{-4} feet/day) or less. Assuming a 1-foot driving head over a 2-foot-thick liner yields a vertical hydraulic gradient of 0.5 ft/ft.

The vertical advective velocity (average linear velocity or seepage velocity) of vertical saturated groundwater flow is calculated using the following equation:

$$v = \left(\frac{Kv}{n_e} \right) \left(\frac{dHv}{dLv} \right)$$

Or, stated in a more compact form:

$$v = \frac{Ki}{n_e}, \text{ where } K = \text{hydraulic conductivity, } i = \text{gradient, and } n_e = \text{effective porosity.}$$

Using an effective porosity for clay of 0.40, the above equation yields an advective velocity 3.5×10^{-4} ft/day. Dividing the distance by the velocity yields a travel time of 15.7 years to transit the liner.

2.1.2 Migration through the unsaturated zone

Assuming that the leachate fully breached the liner, the release would then need to transit through the entire unsaturated zone to reach the water table below the facility. Although unsaturated flow can be

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 5

complex, its calculation can be greatly simplified by making a conservative assumption that the flow is saturated. This is a conservative assumption because unsaturated flow would be characterized by a wetting front (and possible drying cycles) that would result in much lower velocities (longer travel time) than are estimated by assuming saturated flow.

The geologic cross sections and well logs suggest that the mine spoils and Sentinel Butte Formation are thinnest in the vicinity of MW-23S. Assuming that the base of the landfill is at 2050 feet (MSL), the mine spoils are about 90 feet thick at MW-23S, and the Sentinel Butte is about 80 feet thick above the Spaer Bed.

Geotechnical testing of materials at the site has shown mine spoils exhibit relatively low vertical hydraulic conductivities. The four undisturbed vertical hydraulic conductivity values for the mine spoils were 1.3×10^{-7} cm/sec, 4.0×10^{-8} cm/sec, 2.8×10^{-6} cm/sec, and 5.3×10^{-7} cm/sec (Terracon, 2020), which have a geometric mean of 3.0×10^{-7} cm/sec.

The maximum gradient possible would be for a constant head of 1-foot above the liner during the entire travel time through the spoils, or $(1 \text{ ft} / 90 \text{ ft} = 0.011 \text{ ft/ft})$. This is a conservative estimate because it is likely that the gradient would be much lower and that there would be intervals of unsaturated transport beneath the clay liner, which is slower than saturated transport.

Using the moisture contents of the samples in the falling head hydraulic conductivity measurements and a particle specific gravity of 2.72 (Terracon, 2020), the four undisturbed porosity measurements were 0.39, 0.45, 0.43, and 0.43. Lower effective porosity results in higher flow velocity so assuming $n_e = 0.39$ is a conservative estimate. Using the values described above, groundwater flow velocity (v) = 3.0×10^{-7} cm/sec * $0.011 \text{ ft/ft} / 0.39 = 8.54 \times 10^{-9}$ cm/sec or 0.00088 ft/year. Assuming a thickness of 90 feet, travel time through the mine spoils under the clay liner is $90 \text{ ft} / 0.00088 \text{ ft/year} = 10,177 \text{ years}$.

Like the mine spoils, the sediments of the Sentinel Butte Formation are predominately native clay sediments and are expected to have lower K_v values. Five undisturbed vertical hydraulic conductivity values for the Sentinel Butte Formation at the WISCO Landfill (Barr, 2013) were 7.0×10^{-9} cm/sec, 1.1×10^{-8} cm/sec, 3.5×10^{-9} cm/sec, 2.5×10^{-9} cm/sec, and 6.7×10^{-9} cm/sec. Six undisturbed vertical hydraulic conductivity values for the Sentinel Butte Formation at the Minnkota Coal Combustion Residuals Unit (Barr, 2012) were 3.6×10^{-8} cm/sec, 5.0×10^{-9} cm/sec, 8.8×10^{-8} cm/sec, 1.2×10^{-8} cm/sec, 1.0×10^{-8} cm/sec, and 1.0×10^{-9} cm/sec. Together, these eleven values have a geometric mean of 8.0×10^{-9} cm/sec.

The gradient is assumed to be a constant head of 1-foot above the liner during the entire travel time through the 80 ft thick Sentinel Butte Formation, or $(1 \text{ ft} / 80 \text{ ft} = 0.0125 \text{ ft/ft})$. This is a conservative estimate because it excludes the layer of spoils above, which, if factored in, would reduce the gradient and therefore the resulting flow velocity. Using the values described above ($K = 8.0 \times 10^{-9}$ cm/sec, $i = 0.0125 \text{ ft/ft}$ and $n_e = 0.39$), the vertical flow velocity (v) through the Sentinel Butte Formation is estimated as $v = 8.0 \times 10^{-9}$ cm/sec * $0.0125 / 0.39 = 2.564 \times 10^{-8}$ cm/sec or 0.00265 ft/year. Given the thickness of the Sentinel Butte Formation overlying the Spaer Bed is approximately 80 feet, travel time is $80 \text{ ft} / 0.00265 \text{ ft/year} = 301,552 \text{ years}$.

Conservatively, this scenario is calculated assuming a breach in the geomembrane liner and a continuous 1 foot of head. The estimated minimum travel time for CCR leachate to travel through the unsaturated

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 6

zone and reach the Spaer Bed is 311,744 years (15 years for the clay liner, 10,177 years for the mine spoils, and 301,552 years for the Sentinel Butte Formation).

2.1.3 Horizontal Migration in Groundwater

Once a hypothetical release has migrated through the liner and unsaturated zone, it could then reach the water table in the Spaer Lignite seam and eventually reach the detection monitoring well. The velocity of horizontal groundwater flow is calculated using the following equation:

$$v = \left(\frac{K}{n_e} \right) \left(\frac{dH}{dL} \right)$$

The average hydraulic gradient $\left(\frac{dH}{dL} \right)$ between upgradient well MW-18S and downgradient wells in the expansion area (MW-24S, MW-25S, MW-26S, and MW-27S) is 0.005 ft/ft based on the October 2024 piezometric surface map. The hydraulic conductivity (K) is 0.234 ft/day and the porosity is 0.185 for the Spaer Lignite according to the Site's CCR Groundwater Monitoring System Report (AECOM, 2017). Using this information in the above equation, groundwater velocity for the wells in the expansion area is 2.45 ft/year.

Since the waste was placed in the lined landfill expansion cell (300 ft to the closest well MW-25S) only a year and a half prior to the fall 2024 detection monitoring event, it is not plausible for any leachate to reach the monitoring wells.

Using a groundwater velocity of 2.45 ft/year, it would take approximately 122 years for a release to reach MW-24S, MW-25S, MW-26S, or MW-27S. CCR placement in the Landfill began in 1996 and the Landfill Expansion Area in 2023. Therefore, the elevated chloride at MW-24S, MW-25S, MW-26S, and MW-27S and elevated boron and calcium at MW-27S cannot be from the CCR unit.

Since the waste was placed in the lined landfill area started in 1996 or about 29 years ago, it is not plausible for any leachate to reach the monitoring wells given these conservative assumptions. If the distances used to calculate travel time are measured from the existing waste limit, the shortest flow path to MW-25S (located closest to the existing landfill boundary) is approximately 1170 feet downgradient. It would take approximately 477 years for leachate from the existing landfill to reach MW-25S and even longer for leachate to reach MW-27S, which is farthest from the CCR waste (approximately 2800 feet).

Assuming that some unidentified preferential flow pathway were to exist, it would have to result in an over four order of magnitude (10,000x) increase in flow rate (or some combination of rate, gradient, or porosity) to allow for a release to reach the boundary. Even in this extreme case, it would still take hundreds of years to reach the downgradient boundary. Such flow rates are not reasonably likely given the construction quality control on the liner, the thickness of the spoils, and the fine-grained nature of the geology and spoils.

The long time of travel supports the hypothesis that the CCR unit is not the source of the chloride observed at MW-24S, MW-25S, and MW-26S; and boron, chloride, and calcium at MW-27S.

2.2 Natural Variability in Groundwater

Site specific chloride values are variable at the site and range from 7.84 to 16.0 mg/L at downgradient wells other than those with chloride SSIs in fall 2024 (MW-15S, MW-17S, and MW-22S) from 2016 to 2024. Chloride at upgradient wells (MW-18S, MW-19S, and MW-21S) ranged from 4.38 to 19.4 mg/L as shown on time series graphs in Attachment A.

Further evaluation of sulfate concentrations, which are a principal indicator of a CCR unit release to groundwater, demonstrate that MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S are not impacted by a release from the CCR landfill. Sulfate concentrations during the October 2024 sampling event at these locations ranged from 6.83 mg/L to 131 mg/L. The sulfate concentrations at the upgradient Landfill monitoring locations (MW-18S, MW-19S, and MW-21S) were higher and ranged from 263 to 892 mg/L from 2016 to 2024. At downgradient wells other than those with SSIs (MW-15S, MW-17S, and MW-22S), sulfate concentrations were higher and ranged from 183 to 442 mg/L from 2016 to 2024. Sulfate at MW-16S, MW-20S, MW-24S, MW-25S, and MW-26S is much lower than both upgradient and downgradient monitoring locations.

Although MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S have elevated chloride concentrations compared to upgradient wells, sulfate concentrations are lower compared to the rest of the monitoring locations. The low sulfate at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S suggests that the chloride is unlikely to come from a CCR unit release because groundwater impacted by a release should have elevated concentrations of multiple Appendix III parameters.

Site specific historical groundwater samples have been collected from ten wells also screened in the Spaer Bed to the north and east of the landfill. These wells were installed and sampled in support of a groundwater monitoring program associated with the adjacent surface mine prior to development of the CCR landfill. Chloride concentrations within the Spaer Bed are variable ranging from 5.7 to 59 mg/L. Chloride concentrations at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S (25.8 to 50.0 mg/L) fall within the site-specific background water quality.

Therefore, because other indicators of the CCR unit release are absent and background chloride concentrations are variable within the Spaer Bed, we reject the hypothesis that the CCR unit is the source of the chloride observed at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S.

2.3 Statistical Methods

Interwell prediction limits are currently used to evaluate for SSIs. Interwell prediction limits are valid for the site if the stationarity of the mean and variance are assumed to be constant between upgradient monitoring wells MW-18S, MW-19S, and MW-21S and the downgradient wells (USEPA, 2009). The upgradient monitoring wells are not directly downgradient of a CCR unit (Figure 3). According to the EPA Unified Guidance (USEPA, 2009; page 6-31), interwell tests alone may not be suitable for sites with non-stationarity of distribution mean and variance. Non-stationarity may be expected due to historical mining activities and due to heterogeneity within the lignite documented at the Site.

Therefore, intrawell limits are also valid per the guidance. As shown in Table 2 below, using intrawell prediction limit methods indicates there are no SSIs for chloride at MW-16S, MW-20S and MW-24S (Attachment B). Using a combination of interwell and intrawell methods at the site would account for site

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 8

specific heterogeneity and historical conditions and would eliminate the SSI determination at MW-20S and MW-24S.

Table 2 SSIs Compared to Intrawell Prediction Limits

| Event | Well | Parameter (units) | Measured | Intrawell Prediction Limit |
|---------------------------------------|--------|-------------------|----------|----------------------------|
| Detection Monitoring – 2024 #2 (Fall) | MW-16S | Chloride (mg/L) | 26.0 | 29.7 |
| | MW-20S | Chloride (mg/L) | 25.8 | 31.0 |
| | MW-24S | Chloride (mg/L) | 50.0 | 59.4 |

Intrawell methods cannot be used at MW-25S, MW-26S, and MW-27S until at least 8 baseline samples have been collected.

2.4 Trend Testing

If a release from the landfill were occurring, it is likely that the increase in mass to the flow system would cause a change in the chemical equilibrium of the flow system that would reflect changes in concentration overtime. Therefore, if the concentrations of chloride at MW-16S, MW-20S, and MW-24S were due to a release from the landfill there should be evidence of a statistically significant increasing trend.

As shown in Attachment B, each of the data sets were tested for trends using the Mann-Kendall method and no significant trend for chloride were observed at MW-16S, MW-20S, or MW-24S.

This leads to the conclusion that there is no release related to the observed concentrations of chloride at MW-16S, MW-20S, and MW-24S.

2.5 Well Sampling and Development at MW-27S

Monitoring well MW-27S was installed in November 2023, and well development was attempted in April 2024. Approximately one well volume (~4 gallons) was purged during development before the well went dry. It is unlikely that the well was completely developed after this first attempt. The well will need to recharge and be purged multiple times in order to achieve full development.

Based on field notes, low-flow sampling methods were not used during sample collection at MW-27S during the October 2024 detection monitoring event. Specifically, the well was not purged and allowed to stabilize prior to sample collection, instead a hydrosleeve was used to collect the sample due to slow groundwater recharge times.

The preamble to the CCR Rule (VI(K)(3)) notes that "Groundwater sampling should be conducted utilizing EPA protocol low stress (low-flow) purging and sampling methodology, including measurement and stabilization of key indicator parameters prior to sampling." Well stabilization is conducted prior to groundwater sampling in order to obtain a sample representative of aquifer conditions. Properly constructed and developed groundwater monitoring wells allow for the collection of representative samples with low turbidity (U.S. EPA, 1986, 1992). However, even correctly installed wells can produce turbid samples in certain geologic materials. Thus, purging and stabilization are necessary to yield reproducible sampling results. Due to limited recharge, monitoring well MW-27S was not sufficiently

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 9

purged and did not stabilize during the fall 2024 sampling. Field notes from well development are included in Attachment C.

Monitoring well MW-27S has been documented as being slow to recharge (Barr, 2024). Obtaining sufficient groundwater volume for analysis at MW-27S has proven challenging. As a result, the sample sent for laboratory chemical analysis in fall 2024 consisted of the initial draw of water from the well without stabilization. Turbidity readings were too high for the meter and the sample color was described as black, yielding a sample with a high concentration of suspended solids, which may not be representative of typical aquifer conditions. Therefore, the SSI could also be attributed to sampling error.

The CCR Rule requires measurement of "total recoverable metals" because suspended and colloidal particles can also be a means of transport for contaminants. However, the suspended solids responsible for the boron, calcium, and chloride SSIs at monitoring well MW-27S are believed to be natural aquifer material and not mobilized CCR contaminants.

Therefore, due to slow recharge times preventing full development and the well to be purged before sampling, the sample collected from MW-27S is not representative of aquifer conditions and is not a representative sample.

3 Conclusion

An alternative source demonstration for chloride at this site is supported by the following lines of evidence:

- Based on groundwater flow velocities and timing of CCR placement, the elevated chloride (and boron, calcium, and chloride at MW-27S) concentrations could not have come from the CCR unit.
- Chloride in groundwater is variable across the site. While there are somewhat elevated concentrations of chloride in many downgradient wells, there are low sulfate concentrations. Only this single detection monitoring parameter indicated an SSI in several monitoring wells. There is a relative absence of sulfate, a primary indicator of a release, in the groundwater as compared to the presence of sulfate in the water within the upgradient monitoring wells and the downgradient wells with lower chloride. Groundwater chemistry in the expansion area wells is both chemically distinct from the other monitoring wells (background and downgradient) at the CCR unit and chemically distinct from the character of the CCR unit.
- Intrawell statistical methods did not result in SSIs for chloride at MW-16S, MW-20S, and MW-24S. There are not enough baseline samples at MW-25S, MW-26S, and MW-27S for intrawell analyses.
- Well sampling and development limitations due to slow groundwater recharge resulted in high turbidity and the SSIs for boron, calcium, chloride, and TDS at MW-27S.

As this report demonstrates, the SSI analysis presented in Table 1 for monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S is attributed to a source other than the CCR Unit for chloride in the groundwater. The SSI analysis for boron, calcium, and chloride at MW-27S is attributed to sampling techniques due to non-representative aquifer conditions from slow groundwater recharge rates.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 10

Future monitoring data will add to our understanding of the site and the results are expected to augment this ASD and conclusions.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 11

4 References

AECOM, 2024. 2023 Annual Groundwater Monitoring and Corrective Action Report, AVS CCR Landfill. January 2024.

Barr, 2012. Letter to Minnkota Power Cooperative, Inc., Regarding Cells 4, 5, and 6 Drilling Report. May 17, 2012.

Barr, 2013. Site Characterization Investigation Report and Environmental System Plan, WISCO Oilfield Special Waste Landfill, Williston, North Dakota. February 2013.

Barr, 2024. Coal Combustion Residuals Landfill Groundwater Monitoring Well Network Certification, Antelope Valley Station Landfill. June 2024.

Barr, 2025. 2024 Annual Groundwater Monitoring and Corrective Action Report, AVS CCR Landfill. January 2025.

Terracon, 2020. Tests of Soils – Permeability, AVS Landfill Expansion, October 12, 2020.

United States Environmental Protection Agency (USEPA), 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities Unified Guidance. March 2009.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 12

5 Certification


I certify that the written demonstration provided (above) for chloride in monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S and boron and calcium in MW-27S is supported by the data, accurate, and consistent with our review of the groundwater data collected to date and as required under the CCR Rule ((§ 257.94(e)(2)). I further certify that this report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of North Dakota.




Kevin Solie, P.E.
ND P.E. License No. 9488
Barr Engineering Company





Dated this 28th day of March 2025



Figures







- Groundwater Monitoring System Wells
- △ Water Level Only Monitoring
- Orange line Permit Boundary
- Purple line Existing Landfill Limits
- Green dashed line Future Expansion Limit
- Green diagonal hatching Leachate Management Area
- Pink dashed line Limits of Ash as of 2025 (approximate)




0 300 600
Feet

Imagery: USDA-NAIP, 2024


Monitoring Network
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota

FIGURE 2

BARR.



- Groundwater Monitoring System Wells
- Water Level Only Monitoring
- Permit Boundary
- Existing Landfill Limits
- Future Expansion Limit
- Leachate Management Area
- Limits of Ash as of 2025 (approximate)
- Flow Direction
- Groundwater Contour



Imagery: USDA-NAIP, 2024

Fall 2024 Potentiometric Surface
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota

FIGURE 3

BARR.



Attachments



Attachment A

Time Series Graphs

Basin Electric North Dakota

Site Name: AVS Landfill

Event Date: 6-9-25

Weather Conditions: Nice

Field Technician: MK

River Elevation (if applicable)

1658.2

| Well ID | Time | Depth to Water* | Well Condition | Comments |
|---------|------|-----------------|----------------|-------------|
| MW-14S | 1110 | 204.6 | DRY | ALL IS WELL |
| MW-15S | | 218.96 | | |
| MW-20S | | 220.6 | | |
| MW-16S | | 235.82 | | |
| MW-17S | | 238.45 | | |
| MW-22S | | 210.14 | | |
| MW-25S | | 198.66 | | |
| MW-23S | | | DRY | |
| MW-26S | | 190.65 | | |
| MW-24S | | 206.22 | | |
| MW-27S | | 208 | | |
| MW-19S | | 149.4 | | |
| MW-18S | | 199.13 | | |
| MW-21S | | 202.75 | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

* Depth to water as measured from the top of PVC casing.

Well/Piezo ID:

MW-10S

Ground Water Sample Collection Record

| | | | |
|----------------|--------------|--------------|---------------|
| Client: | BEPC | Date: | 10-10-25 |
| Project No: | | Time: | 1041 |
| Site Location: | AVS Landfill | Finish | 0940 10/11/25 |
| Weather Conds: | Sunny Breezy | Collector(s) | MR |

WATER LEVEL DATA: (measured from Top of Casing)

Well

a. Total Well Length

c. Casing Material PVC

Pump Settings 2139 c max PSI

~25mL

b. Water Table Depth 235.82

d. Casing Diameter

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make YSI Model HACH

Serial Number

5320084101

20030C084551

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|-----------------------|---------|--------------------|---------|---------|-----------------|-------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1325 | INITIAL 1.75 | 19.9 | 4.55 | 2018 | 8.16 | 34.3 | 11.2 | BROWN | 238.55 |
| 1329 | 1.9 L | 20.8 | 3.00 | 2004 | 8.13 | 87.1 | 9.64 | | 238.75 |
| 1333 | 1.92 L | 21.5 | 3.15 | 2084 | 8.11 | 113.9 | 8.82 | | 238.90 |
| 1337 | 2 L | 21.8 | 2.98 | 2117 | 8.09 | 125.9 | 9.82 | | 239 |
| 1341 | 2.1 L | 21.8 | 2.8 | 2142 | 8.08 | 132.2 | 9.73 | | 239.11 |
| 1344 | 2.14 L | 21.4 | 2.69 | 2165 | 8.06 | 137.8 | 8.87 | | 239.2 |
| 1348 | 2.17 L | 22.3 | 2.22 | 2144 | 8.06 | 142.4 | 8.33 | | 239.4 |
| 1352 | 2.2 L | 21.4 | 2.19 | 2145 | 8.05 | 144.4 | 8.29 | | 239.52 |
| | L | Purged down to 245ft. | | | | | | | |
| 0830 | L | 13.7 | 4.74 | 1985 | 8.08 | -365.4 | 8.92 | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail

Yes

No

N/A

Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

DTW

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | |
| | 500mL | 1 | HNO3 | Metals | 0830 |
| | | | | | |
| | | | | | |

Comments

Signature MR

Date 10-11-25

Well/Piezo ID:

MN-245

Ground Water Sample Collection Record

| | | | |
|----------------|--------------|--------------|----------|
| Client: | BEPC | Date: | 10-11-25 |
| Project No: | | Time: | 1315 |
| Site Location: | AVS Landfill | Finish | |
| Weather Conds: | smoky 0001 | Collector(s) | MK |

WATER LEVEL DATA: (measured from Top of Casing)
Well

Pump Settings 34726 e max PS1

a. Total Well Length _____ c. Casing Material PVC _____

b. Water Table Depth 190.65 d. Casing Diameter _____

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

Serial Number

5320084101

YSI

20030C084551

HACH

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|---------|---------|--------------------|---------|---------|-----------------|-------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | |
| 1403 | INITIAL 4L | 10.4 | .77 | 2816 | 8.11 | -370.7 | 21.0 | Brown | 0.33 ft |
| 1407 | 4.5 L | 10.5 | .65 | 2807 | 8.10 | -370.6 | 21.0 | | 192.56 |
| 1411 | 5 L | 10.5 | .59 | 2803 | 8.10 | -370.8 | 18.7 | | 192.50 |
| 1415 | 5.5 L | 10.46 | .60 | 2812 | 8.09 | -370.8 | 18.7 | | 192.56 |
| 1419 | 10 L | 10.5 | .49 | 2808 | 8.09 | -371.4 | 14.0 | | 192.55 |
| 1422 | 11.5 L | 10.10 | .47 | 2798 | 8.09 | -371.5 | 15.1 | | 192.58 |
| 1424 | 7 L | 10.5 | .46 | 2801 | 8.09 | -371.8 | 14.3 | | 192.60 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail Yes No N/A

Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 1427 |
| | 500mL | 1 | HNO3 | Metals | ↓ |
| | | | | | |
| | | | | | |

Comments

Signature YMC

Date 10-11-25



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

MVTL Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Cooperative
 WO: 89554
 Chain of Custody
 Page 1 of 1

| Account # | Phone # |
|------------------------|---|
| 2040 | 701-746-7238 701-557-5488 |
| Contact | Emails: mdihle@beppc.com aknutson@beppc.com |
| Name of Sampler | Mark Dihle |
| Martha Knutson | |
| Quote Number | Date Submitted |
| | 6/12/2025 |
| Project Name/Number | Purchase Order # |
| AVS Landfill CCR Wells | 79070801 |

| Lab Use Only | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | # cl | Filtered | Analysis Required |
|--------------|-------------------|-----------------------------------|--------------|--------------|------|----------|--|
| 001 | MW-16S | GW | 6/10/2025 | 945 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 002 | MW-20S | GW | 6/10/2025 | 1029 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | MW-16S | GW | 6/11/2025 | 830 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | MW-22S | GW | 6/11/2025 | 1102 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | DUP | GW | 6/11/2025 | 1102 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 006 | MW-25S | GW | 6/11/2025 | 1252 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 007 | MW-26S | GW | 6/11/2025 | 1427 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| — | AVS LEACHATE POND | SW | 6/10/2025 | 1435 | 2 | N | Total Metals: Mn, Se, Ba, Cd, Cr, B, Mo, As, Pb, Fe, Ca, Mg, Na, K, Cl, SO4, NO2, NO3, TDS, Alkalinity |
| | | GW | | | | | |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|-------------|-----------|------|------|-----|----------|
| 1. MILLENIUM EXPRESS | 6/12/2025 | NOON | ✓ | 6/12/2025 | 1:34 | 4.82 | Y/N | 71939 |
| 2. | | | | | | | | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 15 of 16

Well/Piezo ID:

MW-175

Ground Water Sample Collection Record

| | | | |
|----------------|---------------------|---------------|--------------|
| Client: | BEPC | Date: | 08/10/17 25 |
| Project No: | | Time: | 0817 |
| Site Location: | AVS Landfill | Finish: | 1055 0.18 25 |
| Weather Conds: | Sunny Humid WARM | Collector(s): | MK |

WATER LEVEL DATA: (measured from Top of Casing)

Well

a. Total Well Length _____ c. Casing Material PVC _____ Pump Settings 23/37 e max psi

b. Water Table Depth 238.45 d. Casing Diameter _____

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

Serial Number

5320084101

YSI

20030C084551

HACH

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity ✓ (NTU) | Color | DTW ft |
|------|----------------------|----------------------|---------|--------------------|------|--------|-------------------|-------|--------|
| 0941 | INITIAL 4L | 12.9 | 19.9 | 2699 | 7.94 | -20.2 | 4.75 | BROWN | 245.25 |
| 0945 | 4.5 L | 12.7 | 17.4 | 2054 | 7.97 | 10.3 | 5.04 | | 245.90 |
| 0949 | 5 L | 13.1 | 1.04 | 2048 | 7.97 | 30.0 | 5.05 | | 246.10 |
| 0953 | 5.5 L | 12.8 | 1.49 | 2602 | 7.97 | 56.4 | 5.22 | | 246.75 |
| 0957 | 10 L | 13.1 | 1.37 | 2603 | 7.97 | 88.3 | 5.74 | | 247.1 |
| 1001 | 10.5 L | 13.1 | 1.34 | 2649 | 7.94 | 106.6 | 6.59 | | 247.55 |
| | L | Pumped down to 250FT | | | | | | | |
| 0948 | L | 19.9 | 4.25 | 2740 | 7.91 | -212.6 | 1005 | | 243.99 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail

Yes No N/A Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

DTW

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 0949 |
| | 500mL | 1 | HNO3 | Metals | ↓ |
| | | | | | |
| | | | | | |

Comments

Signature

Date 0.18.25

Well/Piezo ID:

MW-185

Ground Water Sample Collection Record

Client: BEPC Date: 10-17-25
 Project No: Time: 1250
 Site Location: AVS Landfill Finish: 1424
 Weather Conds: Sunny Warm Collector(s) MK

WATER LEVEL DATA: (measured from Top of Casing)

a. Total Well Length

c. Casing Material PVC

Well

Pump Settings 39/21 C max PSI

b. Water Table Depth 199.13 d. Casing Diameter

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

Serial Number

5320084101

YSI

20030C084551

HACH

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
 <0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|---------|---------|--------------------|---------|---------|-----------------|--------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1355 | INITIAL | 7 | .72 | 21002 | 9.48 | -173.7 | 4.09 | yellow | 119.55 |
| 1359 | 75 L | 14.0 | .70 | 2147 | 9.47 | -183.0 | 4.77 | | 119.54 |
| 1402 | 8 L | 13.9 | .59 | 21070 | 9.44 | -164.7 | 4.70 | | 119.56 |
| 1404 | 85 L | 13.9 | .55 | 21079 | 9.41 | -157.3 | 4.51 | | 119.50 |
| 1410 | 9 L | 13.9 | .53 | 21088 | 9.38 | -152.9 | 4.98 | | 119.50 |
| 1414 | 95 L | 13.8 | .53 | 2122 | 9.36 | -143.2 | 4.40 | | 119.49 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail Yes No N/A

Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 1415 |
| | 500mL | 1 | HNO3 | Metals | |
| | | | | | |
| | | | | | |

Comments

Signature

Date 10-17-25

Well/Piezo ID:

MW-215

Ground Water Sample Collection Record

| | | | |
|----------------|--------------|--------------|----------|
| Client: | BEPC | Date: | 10-18-25 |
| Project No: | | Time: | 11:15 |
| Site Location: | AVS Landfill | Finish | 12:57 |
| Weather Conds: | HOT, SUNNY | Collector(s) | MK |

WATER LEVEL DATA: (measured from Top of Casing)

Well

Pump Settings 28/320 max psi

a. Total Well Length _____ c. Casing Material PVC _____

b. Water Table Depth 202.75 d. Casing Diameter _____

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

Serial Number

5320084101

YSI

20030C084551

HACH

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (us/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|---------|---------|--------------------|---------|---------|-----------------|--------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1229 | INITIAL 7L | 13.0 | .115 | 3111 | 7.87 | 104.5 | 2.71 | Yellow | 212.0 |
| 1233 | 7.5 L | 13.3 | .01 | 3103 | 7.89 | 78.6 | 1.80 | Brown | 212.50 |
| 1237 | 8 L | 13.9 | .57 | 3090 | 7.87 | 85.0 | 1.74 | | 212.90 |
| 1241 | 8.5 L | 14.0 | .02 | 3097 | 7.88 | 91.5 | 1.90 | | 213.11 |
| 1245 | 9 L | 14.0 | .102 | 3104 | 7.88 | 92.9 | 1.84 | | 213.22 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail Yes No N/A

Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 1247 |
| | 500mL | 1 | HNO3 | Metals | |
| | | | | | |
| | | | | | |

Comments

Signature MK Date 10-18-25



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Cooperative
 WO: 90275

Page 1 of 1



Order #
 Only

| | | | | | | | |
|---|-----------|--|---|--------------|-----|----------|--|
| Company Name and Address Basin Electric Power Coop. Land Olde Station 3901 Highway 200A Stanton, ND 58571 | | Account # 2040 | Phone # 701-745-7238 701-557-5438 | | | | |
| Contact Mark Dihle | | Emails mdihle@bepc.com aknutson@bepc.com | | | | | |
| Name of Sampler Mariah Knutson | | | | | | | |
| Billing Address (Indicate if different from above) Attn: Liabilities | | Quote Number | Date Submitted 6/19/2025 | | | | |
| | | Project Name/Number AVS Landfill CCR Wells | Purchase Order # 79070801 | | | | |
| Lab Use Only | Sample ID | Sample Matrix <small>GW - Groundwater</small> | Date Sampled | Time Sampled | 5 # | Filtered | Analysis Required |
| 001 | MW-17S | GW | 6/18/2025 | 949 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 002 | MW-24S | GW | 6/17/2025 | 1135 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | MW-27S | GW | 6/17/2025 | 1219 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | MW-18S | GW | 6/17/2025 | 1415 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | MW-19S | GW | 6/18/2025 | 910 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 006 | DUP | GW | 6/18/2025 | 910 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 007 | MW-21S | GW | 6/18/2025 | 1247 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| Comments: | | | | | | | |

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|-------------|-----------|------|-------|-----|----------|
| 1. MILLENIUM EXPRESS | 6/19/2025 | NOON | C. LARSON | 6/19/2025 | 1425 | 3.7°C | Y/N | 1M457 |
| 2. | | | | | | | | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 14 of 15

Well/Piezo ID:

MW-195

Ground Water Sample Collection Record

| | | | |
|----------------|---------------|--------------|---------|
| Client: | BEPC | Date: | 8-26-25 |
| Project No: | | Time: | 0801 |
| Site Location: | AVS Landfill | Finish | 0920 |
| Weather Conds: | Cloudy, Sunny | Collector(s) | MF |

WATER LEVEL DATA: (measured from Top of Casing)

Well

Pump Settings 15/15 @ max psi

a. Total Well Length _____

c. Casing Material PVC

b. Water Table Depth 149.41

d. Casing Diameter _____

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make YSI Model HACH

Serial Number
5320084101
20030C084551c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | DO | | Spec. Cond (us/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|------|----------------------|---------|---------|--------------------|------|--------|-----------------|-------|--------|
| | | +/- 0.2 | +/- 10% | | | | | | |
| 0850 | INITIAL 5L | 10.2 | 0.48 | 32846 | 8.00 | -316.2 | 1.05 | clear | 149.55 |
| 0854 | 5.5 L | 10.3 | 0.48 | 3285 | 8.01 | -318.1 | 1.00 | | 149.55 |
| 0858 | 6 L | 10.3 | 0.49 | 3289 | 8.01 | -325.3 | 0.92 | | 149.56 |
| 0902 | 6.5 L | 10.4 | 0.49 | 3299 | 8.01 | -327.7 | 0.86 | | 149.56 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail

Yes No N/A

Has required volume been removed

Has required turbidity been reached

Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 0903 |
| | 500mL | 1 | HNO3 | Metals | |
| | | | | | |
| | | | | | |

Comments

Signature MCW Date 8-26-25

Basin Electric North Dakota

Site Name: AVS Landfill
Event Date: 8/25/2025
Weather Conditions:
Field Technician: MK

River Elevation (if applicable)

* Depth to water as measured from the top of PVC casing.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Coop

WO: 97784



Chain of Custody

Page 1 of 1

Work Order #
 Lab Use Only

| | | |
|---|---|---|
| Company Name and Address Basin Electric Power Coop. Leland Olds Station 3901 Highway 200A Stanton, ND 58571 | Account # 2040 | Work Order # 701-746-7238 701-557-5488 |
| Contact Mark Dihle | Emails mdihle@bepc.com aknutson@bepc.com | |
| Name of Sampler Mariah Knutson | | |
| Quote Number | Date Submitted 8/27/2025 | |
| Project Name/Number AVS Landfill CCR | Purchase Order # 790708-01 | |

| Lab Use Only | Lab | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | δ # | Filtered | Analysis Required | |
|--------------|-----|-------------------|-----------------------------------|-----------------|-----------------|--------|----------|---|--|
| | | | | | | | | | |
| Q01 | | MW-19S | GW | 8/26/2025 | 903 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, | |
| 002 | | DUP | GW | 8/26/2025 | 903 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, | |
| 003 | | MW-18S | GW | 8/26/2025 | 1137 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, | |
| 004 | | MW-21S | GW | 8/26/2025 | 1403 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, | |
| 005 | | AVS LEACHATE POND | SW | 8/26/2025 | 1435 | 1 | N | Total Metals: Mn,Se,Ba,Cd,Cr,B,Mo,As,Pb,Fe,Ca,Mg,Na,K, Cl,SO4, NO2, NO3, TDS, Alkalinity | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|----------------|-----------|------|------|-----|----------|
| 1. MILLENIUM EXPRESS | 8/27/2025 | NOON | <i>Sabrina</i> | 8/27/2025 | 1444 | 14°C | Y/N | TM805 |
| 2. | | | | | | | Y/N | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 8 of 9

Well/Piezo ID: MW-115

Ground Water Sample Collection Record

| | | | |
|----------------|--------------|--------------|--------------|
| Client: | BEPC | Date: | 10-7-25 |
| Project No: | | Time: | 1110 |
| Site Location: | AVS Landfill | Finish | 0924 10-8-25 |
| Weather Conds: | Sunny, cool | Collector(s) | |

WATER LEVEL DATA: (measured from Top of Casing)

Well

Pump Settings 40/1000 max psi

a. Total Well Length _____ c. Casing Material PVC _____

b. Water Table Depth 230.31 d. Casing Diameter _____

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

Serial Number

5320084101

YSI

20030C084551

HACH

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|-----------------------|---------|--------------------|---------|---------|-----------------|---------------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1303 | INITIAL 15L | 10.9 | 4.00 | 2174 | 8.21 | 124.9 | 55.2 | BROWN | 238.99 |
| 1307 | 1.8 L | 10.2 | 3.69 | 2139 | 8.21 | 124.8 | 57.8 | | 239.13 |
| 1311 | 1.9 L | 10.1 | 3.13 | 2093 | 8.20 | 124.1 | 55.5 | | 239.15 |
| 1315 | 2 L | 10.8 | 2.54 | 2085 | 8.19 | 124.2 | 56.2 | | 239.40 |
| 1319 | 2.1 L | 11.0 | 2.40 | 2059 | 8.18 | 124.4 | 58.1 | | 239.50 |
| | L | | | | | | | | |
| | L | Pumped down to 245 ft | | | | | | | |
| 0810 | L | 9.9 | 4.05 | 1739 | 8.21 | 304.2 | 55.0 | Brown w/ Silt | 243.37 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail Yes No N/A

Has required volume been removed

Yes

No

Has required turbidity been reached

Have parameters stabilized

If no or N/A - Explain below.

DTW

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 0810 |
| | 500mL | 1 | HNO3 | Metals | |
| | | | | | |
| | | | | | |

Comments

Signature man Date 10-8-25

Well/Piezo ID:

MN-225

Ground Water Sample Collection Record

| | | | |
|----------------|--------------|--------------|---------|
| Client: | BEPC | Date: | 10.8.25 |
| Project No: | | Time: | 1009 |
| Site Location: | AVS Landfill | Finish | 1130 |
| Weather Conds: | Cold, sunny | Collector(s) | MK |

WATER LEVEL DATA: (measured from Top of Casing)

a. Total Well Length

c. Casing Material PVC

Well

Pump Settings 22/38°C max PSI

b. Water Table Depth

210.03

d. Casing Diameter

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

YSI
HACHSerial Number
5320084101
20030C084551c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|---------|---------|--------------------|---------|---------|-----------------|-------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1100 | INITIAL 5.25 | 10.7 | 1.09 | 2530 | 8.17 | -320.2 | 5.11 | BROWN | 210.49 |
| 1104 | 5.75 | 10.8 | 0.70 | 2529 | 8.17 | -321.3 | 5.12 | | 210.45 |
| 1108 | 4.25 | 10.8 | 0.61 | 2535 | 8.16 | -328.7 | 5.57 | | 210.30 |
| 1112 | 4.75 | 10.9 | 0.57 | 2529 | 8.16 | -329.3 | 5.05 | | 210.30 |
| 1116 | 7.25 | 10.9 | 0.54 | 2532 | 8.17 | -330.4 | 5.27 | | 210.29 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail Yes No N/A

Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 1116 |
| | 500mL | 1 | HNO3 | Metals | ↓ |
| | | | | | |
| | | | | | |

Comments

DUP

Signature

MCM

Date 10.8.25

Well/Piezo ID:

MN-205

Ground Water Sample Collection Record

| | | | |
|----------------|---------------|--------------|---------|
| Client: | BEPC | Date: | 10.8.15 |
| Project No: | | Time: | 1229 |
| Site Location: | AVS Landfill | Finish | 1326 |
| Weather Conds: | Sunny, Breezy | Collector(s) | MK |

WATER LEVEL DATA: (measured from Top of Casing)

a. Total Well Length _____ c. Casing Material PVC Well Pump Settings 20/45 c max PSI

b. Water Table Depth 190.43 d. Casing Diameter _____

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model
YSI HACHSerial Number
5320084101
20030C084551c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1
<0.5 <5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|---------|---------|--------------------|---------|---------|-----------------|-------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1322 | INITIAL 3.75 | 13.3 | 2.91 | 2880 | 8.10 | 343.3 | 20.4 | Brown | 191.44 |
| 1324 | 4.25 | 12.0 | 2.42 | 2886 | 8.10 | 344.0 | 20.7 | | 191.5 |
| 1330 | 4.75 | 12.1 | 2.00 | 2874 | 8.09 | 345.7 | 17.0 | | 191.61 |
| 1334 | 5.25 | 11.9 | 1.70 | 2904 | 8.09 | 347.3 | 12.2 | | 191.61 |
| 1338 | 5.75 | 12.0 | 1.47 | 2885 | 8.08 | 348.4 | 12.4 | | 191.62 |
| 1342 | 6.25 | 12.1 | 1.40 | 2895 | 8.09 | 348.5 | 11.6 | | 191.63 |
| 1344 | 6.75 | 12.2 | 1.44 | 2884 | 8.08 | 348.6 | 11.2 | | 191.65 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail Yes No N/A

Has required volume been removed Has required turbidity been reached Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION: Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 1347 |
| | 500mL | 1 | HNO3 | Metals | |
| | | | | | |
| | | | | | |

Comments _____

Signature MM.mw Date 10.8.25

Well/Piezo ID:

MN-245

Ground Water Sample Collection Record

| | | | |
|----------------|--------------|--------------|---------|
| Client: | BEPC | Date: | 10-8-25 |
| Project No: | | Time: | 1401 |
| Site Location: | AVS Landfill | Finish | 1452 |
| Weather Conds: | Sunny Breezy | Collector(s) | MK |

WATER LEVEL DATA: (measured from Top of Casing)

a. Total Well Length

c. Casing Material PVC

Well

Pump Settings 20/37°C max. PSI

b. Water Table Depth

206.27

d. Casing Diameter

WELL PURGING DATA

a. Purge Method Dedicated Bladder Pump

b. Field Testing Equipment Used: Make Model

YSI

Serial Number

5320084101

HACH

20030C084551

c. Field Testing Equipment Calibration Documentation Found in Field Notebook # 1 Page # 1

<0.5

<5

| Time | Volume Removed (gal) | T° (C) | DO mg/L | Spec. Cond (µs/cm) | pH | ORP | Turbidity (NTU) | Color | DTW |
|---------------|----------------------|---------|---------|--------------------|---------|---------|-----------------|-------|---------|
| Stabilization | | +/- 0.2 | +/- 10% | +/- 3% | +/- 0.1 | +/- 10% | +/- 10% | | 0.33 ft |
| 1433 | INITIAL | 5.75 | 10.0 | .59 | 3144 | 8.09 | -3003 | 8.32 | BROWN |
| 1437 | 0.25 L | 10.1 | .49 | 3142 | 8.11 | -303.9 | 8.12 | | 207.81 |
| 1441 | 0.75 L | 10.1 | .45 | 3148 | 8.12 | -307.6 | 8.12 | ↓ | 207.78 |
| 1445 | 7.25 L | 10.1 | .42 | 3145 | 8.12 | -299.5 | 8.81 | | 207.77 |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |
| | L | | | | | | | | |

e. Acceptance criteria pass/fail

Yes

No

N/A

Has required volume been removed
Has required turbidity been reached
Have parameters stabilized

If no or N/A - Explain below.

SAMPLE COLLECTION:

Method: Bladder Pump

| Sample ID | Container Typ | No. of Containers | Preservation | Analysis | Time |
|-----------|---------------|-------------------|--------------|------------|------|
| | 1L | 1 | | TDS/Anions | 1445 |
| | 500mL | 1 | HNO3 | Metals | ↓ |
| | | | | | |
| | | | | | |

Comments

Signature Mun

Date 10-8-25

Basin Electric North Dakota

| | |
|----------------------------|--------------|
| Site Name: | AVS Landfill |
| Event Date: | 10/6/2025 |
| Weather Conditions: | |
| Field Technician: | MK |

River Elevation (if applicable)

* Depth to water as measured from the top of PVC casing.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Coop

WO: 103535



Chain of Custody

Page 1 of 1

| Work Order # |
|--------------|
| Lab Use Only |

| | | |
|---|--|--|
| Company Name and Address Basin Electric Power Coop. Leland Olds Station 3901 Highway 200A Stanton, ND 58571 | Account # 2040 | Phone # 701-745-7238 701-557-6488 |
| Contact Mark Dihle | Email mdihle@bepc.com aknutson@bepc.com | |
| Name of Sampler Mariah Knutson | | |
| Quote Number AVS Landfill CCR Wells | Date Submitted 10/8/2025 | Purchase Order # 79070801 |

| Lab Use Only | Lab | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | # of Filtered | Analysis Required | |
|--------------|-----|-----------|-----------------------------------|-----------------|-----------------|------------------|---|---|
| | | | | | | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, | |
| 001 | | MW-15S | GW | 10/7/2025 | 1004 | 2 | N | |
| 002 | | MW-20S | GW | 10/7/2025 | 1052 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | | MW-16S | GW | 10/8/2025 | 816 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | | MW-17S | GW | 10/8/2025 | 834 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | | MW-22S | GW | 10/8/2025 | 1116 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 006 | | DUP | GW | 10/8/2025 | 1116 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 007 | | MW-25S | GW | 10/8/2025 | 1218 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 008 | | MW-26S | GW | 10/8/2025 | 1347 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 009 | | MW-24S | GW | 10/8/2025 | 1445 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 010 | | MW-27S | GW | 10/8/2025 | 1309 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|-------------------|-----------|------|-------|-----|----------|
| 1. MILLENIUM EXPRESS | 10/9/2025 | NOON | <i>Mark Dihle</i> | 10/9/2025 | 1443 | 5.0°C | Y/N | 10959 |
| 2. | | | | | | | Y/N | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 18 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040 **Client:** Basin Electric Power Cooperative
Workorder: AVS Landfill CCR Wells (89554) **PO:** 790708-01

Mark Dihle
Basin Electric Power Cooperative
1717 E. Interstate Avenue
Bismarck, ND 58503

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:

C. Carroll

Claudette Carroll, Lab Manager Bismarck, ND

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125 ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267 ND W/DW # ND-016

Workorder Comments

All analytes with dilution factors greater than 1 (displayed in DF column) required dilution due to matrix or high concentration of target analyte unless otherwise noted and reporting limits (RDL column) have been adjusted accordingly.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: *Tuesday, July 1, 2025 2:32:47 PM*

Page 1 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 89554001 | Date Collected: | 06/10/2025 09:45 | | Matrix: | Groundwater | |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|------|
| Sample ID: | MW-15S | Date Received: | 06/12/2025 14:34 | | Collector: | Client | |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 356 | mg/L | 25 | 5 | | 06/18/2025 11:56 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/12/2025 16:25 | 06/26/2025 10:57 | |
| Calcium | 3.79 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 | |
| Magnesium | 2.55 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 | |
| Potassium | 3.82 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 | |
| Sodium | 733 | mg/L | 5 | 5 | 06/12/2025 16:25 | 06/16/2025 14:49 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1042 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 13:58 | |
| Bicarbonate | 1042 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 13:58 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 13:58 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.2 | units | 0.1 | 1 | | 06/13/2025 13:58 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 13.2 | mg/L | 2.0 | 1 | | 06/17/2025 10:41 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.32 | mg/L | 0.1 | 1 | | 06/13/2025 13:58 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1910 | mg/L | 10 | 1 | | 06/13/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 2 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 89554002 | Date Collected: | 06/10/2025 10:29 | | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|
| Sample ID: | MW-20S | Date Received: | 06/12/2025 14:34 | | Collector: | Client |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 56.1 | mg/L | 5 | 1 | | 06/18/2025 12:03 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/12/2025 16:25 | 06/26/2025 10:57 |
| Calcium | 4.65 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 |
| Magnesium | 2.90 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 |
| Potassium | 4.03 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 |
| Sodium | 698 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:54 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 1372 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 14:09 |
| Bicarbonate | 1372 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 14:09 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 14:09 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.1 | units | 0.1 | 1 | | 06/13/2025 14:09 |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 24.6 | mg/L | 2.0 | 1 | | 06/17/2025 10:43 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 1.16 | mg/L | 0.1 | 1 | | 06/13/2025 14:09 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 1760 | mg/L | 10 | 1 | | 06/13/2025 15:38 |

Analysis Results Comments

Fluoride

Matrix spike and/or matrix spike duplicate recovery was high; the associated laboratory fortified blank recovery was acceptable.

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 3 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 89554003 | Date Collected: | 06/11/2025 08:30 | Matrix: | Groundwater | | |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-16S | Date Received: | 06/12/2025 14:34 | Collector: | Client | | |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 107 | mg/L | 5 | 1 | | 06/18/2025 12:04 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.14 | mg/L | 0.1 | 1 | 06/12/2025 16:25 | 06/26/2025 10:58 | |
| Calcium | 5.41 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:56 | |
| Magnesium | 2.30 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:56 | |
| Potassium | 3.32 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:56 | |
| Sodium | 473 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 12:56 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 778 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 14:21 | |
| Bicarbonate | 778 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 14:21 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 14:21 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 06/13/2025 14:21 | |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 26.2 | mg/L | 2.0 | 1 | | 06/17/2025 10:51 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 2.04 | mg/L | 0.1 | 1 | | 06/13/2025 14:21 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1200 | mg/L | 10 | 1 | | 06/13/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 4 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 89554004 | Date Collected: | 06/11/2025 11:02 | Matrix: | Groundwater | | |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-22S | Date Received: | 06/12/2025 14:34 | Collector: | Client | | |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 193 | mg/L | 25 | 5 | | 06/18/2025 11:59 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/12/2025 16:25 | 06/26/2025 10:59 | |
| Calcium | 2.49 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 14:50 | |
| Magnesium | 1.99 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 14:50 | |
| Potassium | 3.53 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 14:50 | |
| Sodium | 662 | mg/L | 5 | 5 | 06/12/2025 16:25 | 06/16/2025 14:51 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1031 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 16:37 | |
| Bicarbonate | 1031 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 16:37 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 16:37 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 06/13/2025 16:37 | |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 11.1 | mg/L | 2.0 | 1 | | 06/17/2025 10:52 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.75 | mg/L | 0.1 | 1 | | 06/13/2025 16:37 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1650 | mg/L | 10 | 1 | | 06/13/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 5 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 89554005 | Date Collected: | 06/11/2025 11:02 | Matrix: | Groundwater | | |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | DUP | Date Received: | 06/12/2025 14:34 | Collector: | Client | | |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 171 | mg/L | 5 | 1 | | 06/18/2025 12:23 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/12/2025 16:25 | 06/26/2025 10:59 | |
| Calcium | 2.38 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 14:52 | |
| Magnesium | 1.94 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 14:52 | |
| Potassium | 3.24 | mg/L | 1 | 1 | 06/12/2025 16:25 | 06/16/2025 14:52 | |
| Sodium | 648 | mg/L | 5 | 5 | 06/12/2025 16:25 | 06/16/2025 14:53 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1031 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 16:48 | |
| Bicarbonate | 1031 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 16:48 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 16:48 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 06/13/2025 16:48 | |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 11.1 | mg/L | 2.0 | 1 | | 06/17/2025 10:53 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.65 | mg/L | 0.1 | 1 | | 06/13/2025 16:48 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1670 | mg/L | 10 | 1 | | 06/13/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 6 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 89554006 | Date Collected: | 06/11/2025 12:52 | | Matrix: | Groundwater | |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|------|
| Sample ID: | MW-25S | Date Received: | 06/12/2025 14:34 | | Collector: | Client | |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 29.8 | mg/L | 5 | 1 | | 06/18/2025 12:24 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/13/2025 16:10 | 06/26/2025 11:04 | |
| Calcium | 4.01 | mg/L | 1 | 1 | 06/13/2025 16:10 | 06/16/2025 14:54 | |
| Magnesium | 3.11 | mg/L | 1 | 1 | 06/13/2025 16:10 | 06/16/2025 14:54 | |
| Potassium | 4.04 | mg/L | 1 | 1 | 06/13/2025 16:10 | 06/16/2025 14:54 | |
| Sodium | 826 | mg/L | 5 | 5 | 06/13/2025 16:10 | 06/16/2025 14:55 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1489 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 17:00 | |
| Bicarbonate | 1489 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 17:00 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 17:00 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.2 | units | 0.1 | 1 | | 06/13/2025 17:00 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 39.6 | mg/L | 2.0 | 1 | | 06/17/2025 10:54 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.26 | mg/L | 0.1 | 1 | | 06/13/2025 17:00 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1910 | mg/L | 10 | 1 | | 06/13/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 7 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

**Account #:** 2040**Client:** Basin Electric Power Cooperative**Analytical Results**

| Lab ID: | 89554007 | Date Collected: | 06/11/2025 14:27 | | Matrix: | Groundwater | |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|------|
| Sample ID: | MW-26S | Date Received: | 06/12/2025 14:34 | | Collector: | Client | |
| Temp @ Receipt (C): | 4.8 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 75.9 | mg/L | 5 | 1 | | 06/18/2025 12:25 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.13 | mg/L | 0.1 | 1 | 06/13/2025 16:10 | 06/26/2025 11:05 | |
| Calcium | 11.0 | mg/L | 1 | 1 | 06/13/2025 16:10 | 06/16/2025 14:56 | |
| Magnesium | 2.90 | mg/L | 1 | 1 | 06/13/2025 16:10 | 06/16/2025 14:56 | |
| Potassium | 4.72 | mg/L | 1 | 1 | 06/13/2025 16:10 | 06/16/2025 14:56 | |
| Sodium | 746 | mg/L | 5 | 5 | 06/13/2025 16:10 | 06/16/2025 14:57 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1335 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 17:12 | |
| Bicarbonate | 1335 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 17:12 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/13/2025 17:12 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.2 | units | 0.1 | 1 | | 06/13/2025 17:12 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 30.6 | mg/L | 2.0 | 1 | | 06/17/2025 10:56 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.28 | mg/L | 0.1 | 1 | | 06/13/2025 17:12 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1820 | mg/L | 10 | 1 | | 06/13/2025 15:38 | |

Analysis Results Comments**pH**

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 8 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| QC Results Summary | | | | | | WO #: | 89554 | |
|--------------------|---------|--------------------|--------------|--------|-------|--------|-------|-----|
| Sulfate | QC Type | Original Sample ID | Blank Result | Units: | mg/L | | | |
| | LFB | | | 100 | 101.0 | 85 | 115 | |
| | LFB | | | 100 | 97.9 | 85 | 115 | |
| | LFB | | | 100 | 95.8 | 85 | 115 | |
| | LFB | | | 100 | 91.3 | 85 | 115 | |
| | LFB | | | 100 | 89.6 | 85 | 115 | |
| | LFB | | | 100 | 85.6 | 85 | 115 | |
| | LFB | | | 100 | 97.8 | 85 | 115 | |
| | LFB | | | 100 | 97.5 | 85 | 115 | |
| | MB | | <5 | | | | | |
| | MB | | <5 | | | | | |
| | MB | | <5 | | | | | |
| | MB | | <5 | | | | | |
| | MB | | <5 | | | | | |
| | MB | | <5 | | | | | |
| | MB | | <5 | | | | | |
| | MS/MSD | 89364014 | | 500 | 94.8 | 85 | 115 | 0.0 |
| | MS/MSD | 89364024 | | 100 | 94.6 | 85 | 115 | 0.1 |
| | MS/MSD | 89416008 | | 100 | 85.3 | 85 | 115 | 0.4 |
| | MS/MSD | 89554004 | | 500 | 88.8 | 85 | 115 | 0.0 |
| | MS/MSD | 89584006 | | 100 | 80.2 | 85 | 115 | 0.5 |
| | MS/MSD | 89758001 | | 1000 | 95.8 | 85 | 115 | 0.0 |
| | MS/MSD | 89769002 | | 100 | 97.2 | 85 | 115 | 0.0 |
| Chloride | | | | | | Units: | mg/L | |
| Chloride | QC Type | Original Sample ID | Blank Result | Units: | mg/L | | | |
| | LFB | | | 30 | 96.4 | 90 | 110 | |
| | LFB | | | 30 | 96.8 | 90 | 110 | |
| | LFB | | | 30 | 95.8 | 90 | 110 | |
| | LFB | | | 30 | 95.4 | 90 | 110 | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 9 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Chloride | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB | | | 30 | 95.2 | | 90 | 110 | | |
| LFB | | | 30 | 95.6 | | 90 | 110 | | |
| LFB | | | 30 | 94.9 | | 90 | 110 | | |
| LFB | | | 30 | 95.0 | | 90 | 110 | | |
| LFB | | | 30 | 94.3 | | 90 | 110 | | |
| LFB | | | 30 | 94.4 | | 90 | 110 | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MS/MSD | 89354007 | | 30 | 96.1 | 96.1 | 80 | 120 | 0.0 | 20 |
| MS/MSD | 89354028 | | 30 | 98.9 | 97.9 | 80 | 120 | 0.5 | 20 |
| MS/MSD | 89554002 | | 30 | 96.5 | 96.7 | 80 | 120 | 0.0 | 20 |
| MS/MSD | 89631003 | | 30 | 95.7 | 94.7 | 80 | 120 | 0.6 | 20 |
| MS/MSD | 89761001 | | 30 | 94.4 | 94.4 | 80 | 120 | 0.0 | 20 |

| Boron | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-OE | | | 0.4 | 101.0 | | 85 | 115 | | |
| LFB-OE | | | 0.4 | 102.0 | | 85 | 115 | | |
| MB | | <0.1 | | | | | | | |
| MB | | <0.1 | | | | | | | |
| MS/MSD | 89554005 | | 0.4 | 94.5 | 95.3 | 70 | 130 | 0.6 | 20 |
| PDS/PDSO | 89556001 | | 8 | 107.0 | 108.0 | 75 | 125 | 0.8 | 20 |
| PDS/PDSO | 90443002 | | 2 | 82.3 | 83.0 | 75 | 125 | 0.6 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 10 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885

www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Calcium | | Units: mg/L | | | | | | | |
|-----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 104.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 106.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 89196003 | | 100 | 102.0 | 102.0 | 75 | 125 | 0.2 | 20 |
| PDS/PDSO | 89154006 | | 100 | 99.5 | 101.0 | 75 | 125 | 0.7 | 20 |
| PDS/PDSO | 89364012 | | 100 | 95.0 | 95.7 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 89416005 | | 100 | 102.0 | 102.0 | 75 | 125 | 0.2 | 20 |
| PDS/PDSO | 89416008 | | 100 | 100.0 | 101.0 | 75 | 125 | 0.4 | 20 |
| DUP | 89423002 | | | | | | | 2.5 | 20 |
| PDS/PDSO | 89584004 | | 100 | 102.0 | 102.0 | 75 | 125 | 0.2 | 20 |
| PDS/PDSO | 89584009 | | 100 | 103.0 | 105.0 | 75 | 125 | 1.1 | 20 |
| PDS/PDSO | 89584010 | | 100 | 101.0 | 102.0 | 75 | 125 | 0.5 | 20 |
| Magnesium | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 106.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 108.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 89196003 | | 100 | 103.0 | 102.0 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 89154006 | | 100 | 102.0 | 103.0 | 75 | 125 | 0.8 | 20 |
| PDS/PDSO | 89364012 | | 100 | 101.0 | 101.0 | 75 | 125 | 0.4 | 20 |
| PDS/PDSO | 89416005 | | 100 | 105.0 | 105.0 | 75 | 125 | 0.4 | 20 |
| PDS/PDSO | 89416008 | | 100 | 103.0 | 104.0 | 75 | 125 | 0.6 | 20 |
| DUP | 89423002 | | | | | | | 0.6 | 20 |
| PDS/PDSO | 89584004 | | 100 | 105.0 | 105.0 | 75 | 125 | 0.2 | 20 |
| PDS/PDSO | 89584009 | | 100 | 105.0 | 107.0 | 75 | 125 | 1.2 | 20 |
| PDS/PDSO | 89584010 | | 100 | 105.0 | 106.0 | 75 | 125 | 0.9 | 20 |
| Potassium | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 105.0 | | 85 | 115 | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 11 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Potassium | | Units: mg/L | | | | | | | |
|-----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 108.0 | | 85 | 115 | | |

| | | | | | | | | | |
|----------|----------|--|-----|-------|-------|----|-----|-----|----|
| MB | <1 | | | | | | | | |
| MB | <1 | | | | | | | | |
| PDS/PDSO | 89196003 | | 100 | 108.0 | 108.0 | 75 | 125 | 0.4 | 20 |
| PDS/PDSO | 89364006 | | 100 | 105.0 | 107.0 | 75 | 125 | 1.8 | 20 |
| PDS/PDSO | 89364012 | | 100 | 104.0 | 103.0 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 89416005 | | 100 | 107.0 | 104.0 | 75 | 125 | 2.4 | 20 |
| PDS/PDSO | 89416008 | | 100 | 102.0 | 105.0 | 75 | 125 | 2.4 | 20 |
| DUP | 89423002 | | | | | | | 1.3 | 20 |
| PDS/PDSO | 89584004 | | 100 | 104.0 | 104.0 | 75 | 125 | 0.1 | 20 |
| PDS/PDSO | 89584009 | | 100 | 103.0 | 106.0 | 75 | 125 | 2.6 | 20 |
| PDS/PDSO | 89584010 | | 100 | 102.0 | 106.0 | 75 | 125 | 3.1 | 20 |

| Sodium | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 103.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 108.0 | | 85 | 115 | | |
| MB | <1 | | | | | | | | |
| MB | <1 | | | | | | | | |
| PDS/PDSO | 89196003 | | 100 | 105.0 | 104.0 | 75 | 125 | 1.3 | 20 |
| PDS/PDSO | 89364006 | | 100 | 105.0 | 105.0 | 75 | 125 | 0.1 | 20 |
| PDS/PDSO | 89364012 | | 100 | 102.0 | 105.0 | 75 | 125 | 2.5 | 20 |
| PDS/PDSO | 89416005 | | 100 | 105.0 | 102.0 | 75 | 125 | 3.1 | 20 |
| PDS/PDSO | 89416008 | | 100 | 107.0 | 104.0 | 75 | 125 | 2.2 | 20 |
| DUP | 89423002 | | | | | | | 2.4 | 20 |
| PDS/PDSO | 89584004 | | 100 | 104.0 | 106.0 | 75 | 125 | 1.6 | 20 |
| PDS/PDSO | 89584009 | | 100 | 105.0 | 105.0 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 89584010 | | 100 | 106.0 | 105.0 | 75 | 125 | 0.7 | 20 |

| Alkalinity, Total | | Units: mg/L | | | | | | | |
|-------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM | | | 501 | 89.7 | | 80 | 120 | | |
| LFB | | | 410 | 93.5 | | 90 | 110 | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 12 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

| Alkalinity, Total | | Units: mg/L | | | | | | | |
|-------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |

| | | | | | | | | | |
|--------|----------|--|-------|------|------|----|-----|-----|----|
| LFB | | | 410 | 98.8 | | 90 | 110 | | |
| LFB | | | 410 | 92.3 | | 90 | 110 | | |
| LFB | | | 410 | 92.4 | | 90 | 110 | | |
| MB | | | <20.5 | | | | | | |
| MB | | | <20.5 | | | | | | |
| MB | | | <20.5 | | | | | | |
| MB | | | <20.5 | | | | | | |
| MS/MSD | 89554001 | | 410 | 85.3 | 84.9 | 80 | 120 | 0.0 | 20 |
| MS/MSD | 89584002 | | 410 | 87.9 | 87.5 | 80 | 120 | 0.4 | 20 |
| MS/MSD | 89584007 | | 410 | 87.1 | 87.0 | 80 | 120 | 0.2 | 20 |

| pH | | Units: units | | | | | | | |
|---------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |

| | | | | | | | | | |
|--------|----------|--|---|-------|--|--|--|-----|----|
| CRM-PH | | | 6 | 100.7 | | | | | |
| CRM-PH | | | 6 | 100.2 | | | | | |
| CRM-PH | | | 6 | 100.0 | | | | | |
| CRM-PH | | | 6 | 100.0 | | | | | |
| DUP | 89584001 | | | | | | | 0.7 | 20 |
| DUP | 89584009 | | | | | | | 0.1 | 20 |

| Fluoride | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |

| | | | | | | | | | |
|----------|----------|--|------|-------|-------|-------|--------|-----|----|
| CRM-F | | | 0.6 | 101.0 | | 83.99 | 111.11 | | |
| LFB-F | | | 0.5 | 92.0 | | 90 | 110 | | |
| LFB-F | | | 0.5 | 98.0 | | 90 | 110 | | |
| LFB-F | | | 0.5 | 98.0 | | 90 | 110 | | |
| MB-F | | | <0.1 | | | | | | |
| MB-F | | | <0.1 | | | | | | |
| MB-F | | | <0.1 | | | | | | |
| MS/MSD-F | 89554002 | | 0.5 | 102.0 | 122.0 | 80 | 120 | 5.8 | 20 |
| MS/MSD-F | 89554006 | | 0.5 | 100.0 | 86.0 | 80 | 120 | 4.1 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 13 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Total Dissolved Solids | | Units: mg/L | | | | | | | |
|------------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM | | | 736 | 98.0 | | 90.35 | 110.33 | | |
| MB | | | <10 | | | | | | |
| DUP | 89554001 | | | | | 0.0 | 20 | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 14 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-8724

Basin Electric Power Cooperative

WO: 89554 Chain of Custody

Page 1 of 1



Order #
Only

| Account # | Phone # |
|------------------------|--|
| 2040 | 701-745-7238 701-557-5488 |
| Contact | Mark Dihle mdihle@becc.com aknutson@becc.com |
| Name of Sampler | Marlah Knutson |
| Quote Number | Date Submitted |
| Project Name/Number | 6/12/2025 |
| AVS Landfill CCR Wells | Purchase Order # 78070801 |

| Lab Use Only | Lab | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | # of | Filtered | Analysis Required |
|--------------|-------------------|-----------|-----------------------------------|--------------|--------------|------|----------|---|
| 001 | MW-15S | GW | 6/10/2025 | 945 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 002 | MW-20S | GW | 6/10/2025 | 1029 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | MW-16S | GW | 6/11/2025 | 830 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | MW-22S | GW | 6/11/2025 | 1102 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | DUP | GW | 6/11/2025 | 1102 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 006 | MW-25S | GW | 6/11/2025 | 1252 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 007 | MW-26S | GW | 6/11/2025 | 1427 | 2 | N | | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| — | AVS LEACHATE POND | SW | 6/10/2025 | 1435 | 2 | N | | Total Metals: Mn, Se, Ba, Cd, Cr, B, Mo, As, Pb, Fe, Ca, Mg, Na, K, Cl, SO4, ND, NO3, TDS Alkalinity |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|-----------------|-----------|------|-------|-----|----------|
| 1. MILLENIUM EXPRESS | 6/12/2025 | NOON | <i>John Doe</i> | 6/12/2025 | 1434 | 64.5C | Y/N | 74939 |
| 2. | | | | | | | | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 15 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Sample Condition Checklist

Date: 12 Jun 25

Time: 1517

Analyst: PW

Work Order #: 89554

Containers Supplied by MVTL: Yes

No (Designate customer supplied containers as "Other" in container size column)

| Comments: | | | | | | | | | | | |
|-------------------|---------------------|-------|--|---------------------|--------------|-------|--|---|---------------------------------|---|--|
| Number of Bottles | Container Size (mL) | | Container Type | | Preservation | pH | Sample IDs Preservation reagent added Date/Time Analyst | Unique ID of preservation reagent added | Sample pH after preservation | Required for HNO ₃ samples only (24 hours later) Sample ID pH Recheck Result Date/Time/Analyst | |
| | F-(500) = Filtered | | CG = Clear Glass, P = Plastic, AG = Amber Glass | | | | | | | | |
| 1 | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| 1 | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | (125) | (250) | (500) | F-(500) | 1000 | Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | |
| | Oil and grease | | | (CG) (P) (AG) Other | | | HCl | n/a | | | |
| | TOC Vials | | | (G) (AG) | | | H ₃ PO ₄ | n/a | | | |
| | DOC Vials | | | (G) (AG) | | | None H ₃ PO ₄ | n/a | | | |

*All samples requiring analyses performed outside of the Bismarck laboratory (New Ulm and Sub-Contract) are not documented on this form.

*All samples requiring microbiological tests are not documented on this form.

Form #80-910025-2

M:\Documents\FORMS\Approved Templates\Bismarck\Waters\80-910025-2 Sample Condition Checklist

Page 1 of 1

Effective Date : 1 July 2024

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:32:47 PM

Page 16 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040 **Client:** Basin Electric Power Cooperative
Workorder: AVS Landfill CCR Wells (90275) **PO:** 790708-01

Mark Dihle
Basin Electric Power Cooperative
1717 E. Interstate Avenue
Bismarck, ND 58503

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:

C. Carroll

Claudette Carroll, Lab Manager Bismarck, ND

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125 ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267 ND W/DW # ND-016

Workorder Comments

All analytes with dilution factors greater than 1 (displayed in DF column) required dilution due to matrix or high concentration of target analyte unless otherwise noted and reporting limits (RDL column) have been adjusted accordingly.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 1 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275001 | Date Collected: | 06/18/2025 09:49 | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|------------|--------------------|
| Sample ID: | MW-17S | Date Received: | 06/19/2025 14:35 | Collector: | Client |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | |
| Parameter | Results | Units | RDL | DF | Prepared |
| Method: ASTM D516-16 | | | | | |
| Sulfate | 293 | mg/L | 25 | 5 | 06/25/2025 09:17 |
| Method: EPA 6010D | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/19/2025 16:59 |
| Calcium | 4.05 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Magnesium | 2.28 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Potassium | 3.52 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Sodium | 684 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Method: SM2320 B-2021 | | | | | |
| Alkalinity, Total | 1097 | mg/L as CaCO ₃ | 20.5 | 1 | 06/24/2025 13:17 |
| Bicarbonate | 1087 | mg/L as CaCO ₃ | 20.5 | 1 | 06/24/2025 13:17 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | 06/24/2025 13:17 |
| Method: SM4500 H+ B-2021 | | | | | |
| pH | 8.4 | units | 0.1 | 1 | 06/24/2025 13:17 * |
| Method: SM4500-CI-E 2021 | | | | | |
| Chloride | 13.0 | mg/L | 2.0 | 1 | 06/24/2025 10:34 |
| Method: SM4500-F-C-2021 | | | | | |
| Fluoride | 1.63 | mg/L | 0.1 | 1 | 06/23/2025 15:51 |
| Method: USGS I-1750-85 | | | | | |
| Total Dissolved Solids | 1740 | mg/L | 10 | 1 | 06/24/2025 09:43 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 2 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275002 | Date Collected: | 06/17/2025 11:35 | | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|
| Sample ID: | MW-24S | Date Received: | 06/19/2025 14:35 | | Collector: | Client |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 62.4 | mg/L | 5 | 1 | | 06/25/2025 09:30 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.11 | mg/L | 0.1 | 1 | 06/19/2025 16:59 | 06/26/2025 11:30 |
| Calcium | 4.35 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:27 |
| Magnesium | 3.46 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:27 |
| Potassium | 4.48 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:27 |
| Sodium | 881 | mg/L | 5 | 5 | 06/19/2025 16:59 | 06/24/2025 15:13 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 1592 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 13:28 |
| Bicarbonate | 1589 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 13:28 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 13:28 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 06/24/2025 13:28 |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 49.6 | mg/L | 2.0 | 1 | | 06/24/2025 10:35 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 1.56 | mg/L | 0.1 | 1 | | 06/23/2025 16:05 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 1950 | mg/L | 10 | 1 | | 06/24/2025 09:43 |

Analysis Results Comments

Fluoride

Matrix spike and/or matrix spike duplicate recovery was low; the associated laboratory control sample recovery was acceptable.

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 3 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275003 | Date Collected: | 06/17/2025 12:19 | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|
| Sample ID: | MW-27S | Date Received: | 06/19/2025 14:35 | Collector: | Client |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | |
| Parameter | Results | Units | RDL | DF | Prepared |
| Method: ASTM D516-16 | | | | | |
| Sulfate | 230 | mg/L | 25 | 5 | 06/25/2025 09:19 |
| Method: EPA 6010D | | | | | |
| Boron | 0.68 | mg/L | 0.1 | 1 | 06/19/2025 16:59 |
| Calcium | 419 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Magnesium | 152 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Potassium | 27.4 | mg/L | 1 | 1 | 06/19/2025 16:59 |
| Sodium | 1040 | mg/L | 5 | 5 | 06/19/2025 16:59 |
| Method: SM2320 B-2021 | | | | | |
| Alkalinity, Total | 1659 | mg/L as CaCO ₃ | 20.5 | 1 | 06/24/2025 13:39 |
| Bicarbonate | 1659 | mg/L as CaCO ₃ | 20.5 | 1 | 06/24/2025 13:39 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | 06/24/2025 13:39 |
| Method: SM4500 H+ B-2021 | | | | | |
| pH | 8.2 | units | 0.1 | 1 | 06/24/2025 13:39 |
| Method: SM4500-Cl-E 2021 | | | | | |
| Chloride | 64.9 | mg/L | 10.0 | 5 | 06/24/2025 10:36 |
| Method: SM4500-F-C-2021 | | | | | |
| Fluoride | 1.41 | mg/L | 0.1 | 1 | 06/23/2025 18:17 |
| Method: USGS I-1750-85 | | | | | |
| Total Dissolved Solids | 2500 | mg/L | 10 | 1 | 06/24/2025 09:43 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 4 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275004 | Date Collected: | 06/17/2025 14:15 | | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|
| Sample ID: | MW-18S | Date Received: | 06/19/2025 14:35 | | Collector: | Client |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 555 | mg/L | 25 | 5 | | 06/25/2025 09:20 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.10 | mg/L | 0.1 | 1 | 06/19/2025 16:59 | 06/26/2025 11:32 |
| Calcium | 4.43 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:29 |
| Magnesium | 1.66 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:29 |
| Potassium | 3.92 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:29 |
| Sodium | 697 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:29 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 820 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 13:48 |
| Bicarbonate | 638 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 13:48 |
| Carbonate | 182 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 13:48 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 9.2 | units | 0.1 | 1 | | 06/24/2025 13:48 |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 8.5 | mg/L | 2.0 | 1 | | 06/24/2025 10:37 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 1.32 | mg/L | 0.1 | 1 | | 06/23/2025 18:31 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 1780 | mg/L | 10 | 1 | | 06/24/2025 09:43 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 5 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275005 | Date Collected: | 06/18/2025 09:10 | Matrix: | Groundwater | | |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-19S | Date Received: | 06/19/2025 14:35 | Collector: | Client | | |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 696 | mg/L | 25 | 5 | | 06/25/2025 09:21 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.13 | mg/L | 0.1 | 1 | 06/19/2025 16:59 | 06/26/2025 11:32 | |
| Calcium | 4.30 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:30 | |
| Magnesium | 3.34 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:30 | |
| Potassium | 4.26 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:30 | |
| Sodium | 844 | mg/L | 5 | 5 | 06/19/2025 16:59 | 06/24/2025 15:15 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 845 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:00 | |
| Bicarbonate | 845 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:00 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:00 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 06/24/2025 14:00 | |
| Method: SM4500-Cl-E 2021 | | | | | | | |
| Chloride | 18.5 | mg/L | 2.0 | 1 | | 06/24/2025 10:38 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 0.77 | mg/L | 0.1 | 1 | | 06/23/2025 18:45 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 2180 | mg/L | 10 | 1 | | 06/24/2025 09:43 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 6 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275006 | Date Collected: | 06/18/2025 09:10 | Matrix: | Groundwater | | |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | DUP | Date Received: | 06/19/2025 14:35 | Collector: | Client | | |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 738 | mg/L | 25 | 5 | | 06/25/2025 09:22 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.13 | mg/L | 0.1 | 1 | 06/19/2025 16:59 | 06/26/2025 11:35 | |
| Calcium | 4.30 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:32 | |
| Magnesium | 3.37 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:32 | |
| Potassium | 4.30 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:32 | |
| Sodium | 840 | mg/L | 5 | 5 | 06/19/2025 16:59 | 06/24/2025 15:16 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 825 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:08 | |
| Bicarbonate | 825 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:08 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:08 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.2 | units | 0.1 | 1 | | 06/24/2025 14:08 | |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 18.7 | mg/L | 2.0 | 1 | | 06/24/2025 10:40 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 0.73 | mg/L | 0.1 | 1 | | 06/23/2025 18:58 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 2190 | mg/L | 10 | 1 | | 06/24/2025 09:43 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 7 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 90275007 | Date Collected: | 06/18/2025 12:47 | | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|----|------------------|--------------------|
| Sample ID: | MW-21S | Date Received: | 06/19/2025 14:35 | | Collector: | Client |
| Temp @ Receipt (C): | 3.9 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 401 | mg/L | 25 | 5 | | 06/25/2025 09:23 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 06/19/2025 16:59 | 06/26/2025 11:37 |
| Calcium | 4.54 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:33 |
| Magnesium | 3.12 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:33 |
| Potassium | 4.19 | mg/L | 1 | 1 | 06/19/2025 16:59 | 06/24/2025 13:33 |
| Sodium | 827 | mg/L | 5 | 5 | 06/19/2025 16:59 | 06/24/2025 15:17 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 1187 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:17 |
| Bicarbonate | 1187 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:17 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 06/24/2025 14:17 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.2 | units | 0.1 | 1 | | 06/24/2025 14:17 * |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 18.0 | mg/L | 2.0 | 1 | | 06/24/2025 10:41 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 1.65 | mg/L | 0.1 | 1 | | 06/23/2025 19:12 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 2030 | mg/L | 10 | 1 | | 06/24/2025 09:43 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 8 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| QC Results Summary | | | | | | | WO #: | 90275 | | | | |
|--------------------|--------------------|--------------|--------------------|--------------|------------------|----------------------------|-------------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| Sulfate | | QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) | | |
| LFB | | | 100 | | 102.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 102.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 102.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 100.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 100.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 100.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 100.0 | | 85 | | 115 | | | |
| LFB | | | 100 | | 100.0 | | 85 | | 115 | | | |
| MB | | | <5 | | | | | | | | | |
| MB | | | <5 | | | | | | | | | |
| MB | | | <5 | | | | | | | | | |
| MB | | | <5 | | | | | | | | | |
| MB | | | <5 | | | | | | | | | |
| MB | | | <5 | | | | | | | | | |
| MS/MSD | 90134001 | | 1000 | | 80.6 | | 82.2 | | 85 | | 115 | 1.2 |
| MS/MSD | 90167004 | | 100 | | 98.1 | | 99.5 | | 85 | | 115 | 1.4 |
| MS/MSD | 90304002 | | 100000 | | 86.5 | | 89.8 | | 85 | | 115 | 2.7 |
| MS/MSD | 90443002 | | 10000 | | 81.1 | | 84.2 | | 85 | | 115 | 1.5 |
| MS/MSD | 90446002 | | 500 | | 81.0 | | 85.8 | | 85 | | 115 | 2.6 |
| MS/MSD | 90448004 | | 100 | | 98.8 | | 98.8 | | 85 | | 115 | 0.0 |
| Chloride | | QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) | | |
| LFB | | | 30 | | 97.1 | | 90 | | 110 | | | |
| LFB | | | 30 | | 97.4 | | 90 | | 110 | | | |
| LFB | | | 30 | | 97.3 | | 90 | | 110 | | | |
| LFB | | | 30 | | 96.8 | | 90 | | 110 | | | |
| LFB | | | 30 | | 96.6 | | 90 | | 110 | | | |
| LFB | | | 30 | | 96.2 | | 90 | | 110 | | | |
| LFB | | | 30 | | 96.0 | | 90 | | 110 | | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 9 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Chloride QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | | | | | |
|---------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| | | | | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MS/MSD | 89806001 | | 30 | 100.2 | 100.3 | 80 | 120 | 0.0 | 20 |
| MS/MSD | 90166003 | | 30 | 105.1 | 103.1 | 80 | 120 | 0.8 | 20 |
| MS/MSD | 90304007 | | 30 | 101.4 | 101.5 | 80 | 120 | 0.2 | 20 |

| Boron QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | | | | | |
|------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| | | | | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-OE | | | 0.4 | 104.0 | | 85 | 115 | | |
| MB | | <0.1 | | | | | | | |
| PDS/PDSO | 89556001 | | 8 | 107.0 | 108.0 | 75 | 125 | 0.8 | 20 |
| MS/MSD | 90275006 | | 0.4 | 95.1 | 96.0 | 70 | 130 | 0.7 | 20 |
| PDS/PDSO | 90443002 | | 2 | 82.3 | 83.0 | 75 | 125 | 0.6 | 20 |

| Calcium QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | | | | | |
|--------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| | | | | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 99.8 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 89096001 | | 100 | 103.0 | 103.0 | 75 | 125 | 0.1 | 20 |
| PDS/PDSO | 89760001 | | 100 | 99.5 | 98.1 | 75 | 125 | 0.8 | 20 |
| PDS/PDSO | 89938001 | | 100 | 102.0 | 101.0 | 75 | 125 | 0.6 | 20 |
| PDS/PDSO | 90167005 | | 100 | 101.0 | 102.0 | 75 | 125 | 0.1 | 20 |
| PDS/PDSO | 90304006 | | 100 | 95.9 | 95.9 | 75 | 125 | 0.0 | 20 |

| Magnesium QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | | | | | |
|----------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| | | | | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 99.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 89096001 | | 100 | 105.0 | 105.0 | 75 | 125 | 0.1 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 10 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Magnesium | | | | | | | | | | |
|-------------------|--------------------|--------------|--------------|-------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| PDS/PDSO | 89938001 | | 100 | 102.0 | 101.0 | 75 | 125 | 0.8 | 20 | |
| PDS/PDSO | 89938001 | | 100 | 104.0 | 103.0 | 75 | 125 | 0.8 | 20 | |
| PDS/PDSO | 90167005 | | 100 | 102.0 | 101.0 | 75 | 125 | 0.1 | 20 | |
| PDS/PDSO | 90304006 | | 100 | 97.2 | 97.9 | 75 | 125 | 0.4 | 20 | |
| Potassium | | | | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 101.0 | | | 85 | 115 | | |
| MB | | <1 | | | | | | | | |
| PDS/PDSO | 89096001 | | 100 | 103.0 | 103.0 | 75 | 125 | 0.3 | 20 | |
| PDS/PDSO | 89760001 | | 100 | 103.0 | 102.0 | 75 | 125 | 0.8 | 20 | |
| PDS/PDSO | 89938001 | | 100 | 105.0 | 104.0 | 75 | 125 | 0.8 | 20 | |
| PDS/PDSO | 90167005 | | 100 | 106.0 | 106.0 | 75 | 125 | 0.3 | 20 | |
| PDS/PDSO | 90304006 | | 100 | 102.0 | 105.0 | 75 | 125 | 2.6 | 20 | |
| Sodium | | | | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 98.9 | | | 85 | 115 | | |
| MB | | <1 | | | | | | | | |
| PDS/PDSO | 89096001 | | 100 | 73.6 | 72.8 | 75 | 125 | 0.2 | 20 | |
| PDS/PDSO | 89760001 | | 100 | 104.0 | 105.0 | 75 | 125 | 0.6 | 20 | |
| PDS/PDSO | 89938001 | | 100 | 107.0 | 101.0 | 75 | 125 | 4.0 | 20 | |
| PDS/PDSO | 90167005 | | 100 | 108.0 | 108.0 | 75 | 125 | 0.1 | 20 | |
| PDS/PDSO | 90304006 | | 100 | 84.8 | 86.7 | 75 | 125 | 0.5 | 20 | |
| Alkalinity, Total | | | | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Units: mg/L | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM | | | 501 | 93.1 | | | 80 | 120 | | |
| LFB | | | 410 | 96.9 | | | 90 | 110 | | |
| LFB | | | 410 | 96.6 | | | 90 | 110 | | |
| LFB | | | 410 | 95.7 | | | 90 | 110 | | |
| LFB | | | 410 | 96.5 | | | 90 | 110 | | |
| LFB | | | 410 | 96.3 | | | 90 | 110 | | |
| MB | | <20.5 | | | | | | | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 11 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Alkalinity, Total | | Units: mg/L | | | | | | | |
|-------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| MB | | <20.5 | | | | | | | |
| MB | | <20.5 | | | | | | | |
| MB | | <20.5 | | | | | | | |
| MB | | <20.5 | | | | | | | |
| MS/MSD | 90275006 | | 410 | 90.5 | 89.3 | 80 | 120 | 0.6 | 20 |
| MS/MSD | 90304008 | | 410 | 92.2 | 87.0 | 80 | 120 | 3.2 | 20 |
| MS/MSD | 90442002 | | 410 | 91.2 | 91.4 | 80 | 120 | 0.1 | 20 |
| MS/MSD | 90446002 | | 410 | 91.7 | 91.7 | 80 | 120 | 0.0 | 20 |
| pH | | Units: units | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM-PH | | 6 | | 100.5 | | | | | |
| CRM-PH | | 6 | | 100.5 | | | | | |
| CRM-PH | | 6 | | 100.5 | | | | | |
| CRM-PH | | 6 | | 100.2 | | | | | |
| CRM-PH | | 6 | | 100.0 | | | | | |
| DUP | 90275002 | | | | | | | 0.7 | 20 |
| DUP | 90391001 | | | | | | | 0.1 | 20 |
| DUP | 90440001 | | | | | | | 0.4 | 20 |
| DUP | 90446002 | | | | | | | 0.9 | 20 |
| Fluoride | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM-F | | 0.6 | | 99.2 | | 83.99 | 111.11 | | |
| IFB-F | | 0.5 | | 94.0 | | 90 | 110 | | |
| IFB-F | | 0.5 | | 98.0 | | 90 | 110 | | |
| IFB-F | | 0.5 | | 100.0 | | 90 | 110 | | |
| IFB-F | | 0.5 | | 104.0 | | 90 | 110 | | |
| MB-F | | <0.1 | | | | | | | |
| MB-F | | <0.1 | | | | | | | |
| MB-F | | <0.1 | | | | | | | |
| MB-F | | <0.1 | | | | | | | |
| MS/MSD-F | 90275002 | | 0.5 | 92.0 | 70.0 | 80 | 120 | 5.6 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 12 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Fluoride | | Units: mg/L | | | | | | | |
|------------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| MS/MSD-F | 90295007 | | 0.5 | 122.0 | 106.0 | 80 | 120 | 3.2 | 20 |
| MS/MSD-F | 90304007 | | 0.5 | 90.0 | 86.0 | 80 | 120 | 2.1 | 20 |
| Total Dissolved Solids | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM | | | 736 | 99.0 | 99.0 | 90.35 | 110.33 | | |
| MB | | <10 | | | | | | | |
| DUP | 90168002 | | | | | 0.6 | 20 | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 13 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Cooperative Chain of Custody

WO: 90275

Page 1 of 1



Order #

Only

| | | |
|---|---|--|
| Company Name and Address Basin Electric Power Coop. Leland Olds Station 3901 Highway 200A Stanton, ND 58571 | Account # 2040 | Phone # 701-745-7238 701-557-5458 |
| Contact Mark Dihle | Emails mdihle@bepc.com aknutson@bepc.com | |
| Name of Sampler Mariah Knutson | | |
| Billing Address (indicate if different from above) Attn: Liabilities | Quote Number 6/19/2025 | Date Submitted 6/19/2025 |
| | Project Name/Number AVS Landfill CCR Wells | Purchase Order # 78070801 |

| Lab Use Only | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | Filter # | Filtered | Analysis Required |
|--------------|-----------|-----------------------------------|--------------|--------------|-------------|----------|--|
| 001 | MW-17S | GW | 6/18/2025 | 949 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 002 | MW-24S | GW | 6/17/2025 | 1135 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | MW-27S | GW | 6/17/2025 | 1219 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | MW-18S | GW | 6/17/2025 | 1415 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | MW-19S | GW | 6/18/2025 | 910 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 006 | DUP | GW | 6/18/2025 | 910 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 007 | MW-21S | GW | 6/18/2025 | 1247 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|-------------|-----------|------|-------|-----|----------|
| 1. MILLENIUM EXPRESS | 6/19/2025 | NOON | C. (Aut) | 6/19/2025 | 1435 | 3.4°C | Y/N | 1M907 |
| 2. | | | | | | | | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 14 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Sample Condition Checklist

Date: 19 Jun 25

Analyst: PW

Work Order #: 90275

Yes

No (Designate customer supplied containers as "Other" in container size column)

Comments:

| Number of Bottles | Container Size (mL) | Container Type | Preservation | pH | Sample IDs Preservation reagent added Date/Time Analyst | Unique ID of preservation reagent added | Sample pH after preservation | Required for HNO ₃ samples only (24 hours later) Sample ID pH Recheck Result Date/Time/Analyst |
|-------------------|--|---------------------|---|--------|--|---|---------------------------------|---|
| | | | | | | | | |
| 7 | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| 7 | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | |
| | Oil and grease | (CG) (P) (AG) Other | HCl | n/a | | | | |
| | TOC Vials | (G) (AG) | H ₃ PO ₄ | n/a | | | | |
| | DOC Vials | (G) (AG) | None H ₃ PO ₄ | n/a | | | | |

*All samples requiring analyses performed outside of the Bismarck laboratory (New Ulm and Sub-Contract) are not documented on this form.

*All samples requiring microbiological tests are not documented on this form.

Form #80-910025-2

M:\Documents\FORMS\Approved Templates\Bismarck\Waters\80-910025-2 Sample Condition Checklist
Page 1 of 1

Effective Date : 1 July 2024

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, July 1, 2025 2:41:34 PM

Page 15 of 15



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Workorder: AVS Landfill CCR (97784)

PO: 790708-01

Mark Dihle
Basin Electric Power Cooperative
1717 E. Interstate Avenue
Bismarck, ND 58503

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:

C. Carroll

Claudette Carroll, Lab Manager Bismarck, ND

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125 ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267 ND W/DW # ND-016

Workorder Comments

All analytes with dilution factors greater than 1 (displayed in DF column) required dilution due to matrix or high concentration of target analyte unless otherwise noted and reporting limits (RDL column) have been adjusted accordingly.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: [Tuesday, September 9, 2025 9:31:41 AM](#)

Page 1 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 97784001 | Date Collected: | 08/26/2025 09:03 | | Matrix: | Groundwater | |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|------|
| Sample ID: | MW-19S | Date Received: | 08/27/2025 14:44 | | Collector: | Client | |
| Temp @ Receipt (C): | 1.4 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 765 | mg/L | 25 | 5 | | 09/03/2025 10:55 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 08/27/2025 16:36 | 09/08/2025 11:59 | |
| Calcium | 4.17 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:12 | |
| Magnesium | 3.27 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:12 | |
| Potassium | 4.40 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:12 | |
| Sodium | 808 | mg/L | 5 | 5 | 08/27/2025 16:36 | 08/29/2025 11:41 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 838 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 21:58 | |
| Bicarbonate | 838 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 21:58 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 21:58 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 08/27/2025 21:58 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 18.8 | mg/L | 2.0 | 1 | | 09/02/2025 10:49 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 0.66 | mg/L | 0.1 | 1 | | 08/27/2025 21:58 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 2170 | mg/L | 10 | 1 | | 08/29/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 2 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 97784002 | Date Collected: | 08/26/2025 09:03 | | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|
| Sample ID: | DUP | Date Received: | 08/27/2025 14:44 | | Collector: | Client |
| Temp @ Receipt (C): | 1.4 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 749 | mg/L | 25 | 5 | | 09/03/2025 10:56 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 08/27/2025 16:36 | 09/08/2025 12:01 |
| Calcium | 4.14 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:13 |
| Magnesium | 3.28 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:13 |
| Potassium | 4.36 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:13 |
| Sodium | 827 | mg/L | 5 | 5 | 08/27/2025 16:36 | 08/29/2025 11:42 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 851 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:09 |
| Bicarbonate | 851 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:09 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:09 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 08/27/2025 22:09 |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 18.9 | mg/L | 2.0 | 1 | | 09/02/2025 10:50 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 0.68 | mg/L | 0.1 | 1 | | 08/27/2025 22:09 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 2170 | mg/L | 10 | 1 | | 08/29/2025 15:38 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 3 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 97784003 | Date Collected: | 08/26/2025 11:37 | | | Matrix: | Groundwater |
|---------------------------------|----------|---------------------------|------------------|----|------------------|------------------|-------------|
| Sample ID: | MW-18S | Date Received: | 08/27/2025 14:44 | | | Collector: | Client |
| Temp @ Receipt (C): | 1.4 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 596 | mg/L | 25 | 5 | | 09/03/2025 10:57 | |
| Method: EPA 6010D | | | | | | | |
| Boron | <0.1 | mg/L | 0.1 | 1 | 08/27/2025 16:36 | 09/08/2025 12:02 | |
| Calcium | 4.29 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:15 | |
| Magnesium | 1.69 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:15 | |
| Potassium | 4.08 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:15 | |
| Sodium | 679 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:15 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 846 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:20 | |
| Bicarbonate | 662 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:20 | |
| Carbonate | 183 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:20 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 9.2 | units | 0.1 | 1 | | 08/27/2025 22:20 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 8.7 | mg/L | 2.0 | 1 | | 09/02/2025 10:52 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.23 | mg/L | 0.1 | 1 | | 08/27/2025 22:20 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1860 | mg/L | 10 | 1 | | 08/29/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 4 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 97784004 | Date Collected: | 08/26/2025 14:03 | Matrix: | Groundwater | | |
|---------------------------------|----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-21S | Date Received: | 08/27/2025 14:44 | Collector: | Client | | |
| Temp @ Receipt (C): | 1.4 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 403 | mg/L | 25 | 5 | | 09/03/2025 10:59 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.11 | mg/L | 0.1 | 1 | 08/27/2025 16:36 | 09/08/2025 12:02 | |
| Calcium | 4.16 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:18 | |
| Magnesium | 2.96 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:18 | |
| Potassium | 4.23 | mg/L | 1 | 1 | 08/27/2025 16:36 | 08/29/2025 13:18 | |
| Sodium | 794 | mg/L | 5 | 5 | 08/27/2025 16:36 | 08/29/2025 11:46 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1189 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:33 | |
| Bicarbonate | 1189 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:33 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:33 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 08/27/2025 22:33 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 18.0 | mg/L | 2.0 | 1 | | 09/02/2025 10:53 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.53 | mg/L | 0.1 | 1 | | 08/27/2025 22:33 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1990 | mg/L | 10 | 1 | | 08/29/2025 15:38 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 5 of 9

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

**Account #:** 2040**Client:** Basin Electric Power Cooperative**Analytical Results**

| Lab ID: | 97784005 | Date Collected: | 08/26/2025 14:35 | | Matrix: | Surface Water |
|---------------------------------|-------------------|---------------------------|------------------|----|------------------|------------------|
| Sample ID: | AVS Leachate Pond | Date Received: | 08/27/2025 14:44 | | Collector: | Client |
| Temp @ Receipt (C): | 1.4 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 5790 | mg/L | 100 | 20 | | 09/03/2025 11:00 |
| Method: EPA 353.2 | | | | | | |
| Nitrate + Nitrite as N | 4.80 | mg/L | 4 | 20 | | 09/04/2025 15:39 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.96 | mg/L | 0.5 | 5 | 08/27/2025 16:36 | 09/08/2025 12:03 |
| Calcium | 312 | mg/L | 20 | 20 | 08/27/2025 16:36 | 08/29/2025 11:47 |
| Iron | 2.60 | mg/L | 0.5 | 5 | 08/27/2025 16:36 | 08/28/2025 16:19 |
| Magnesium | 72.2 | mg/L | 20 | 20 | 08/27/2025 16:36 | 08/29/2025 11:47 |
| Manganese | 0.72 | mg/L | 0.25 | 5 | 08/27/2025 16:36 | 08/28/2025 16:19 |
| Potassium | 233 | mg/L | 20 | 20 | 08/27/2025 16:36 | 08/29/2025 11:47 |
| Sodium | 3080 | mg/L | 20 | 20 | 08/27/2025 16:36 | 08/29/2025 11:47 |
| Method: EPA 6020B | | | | | | |
| Arsenic | 0.1657 | mg/L | 0.002 | 5 | 08/27/2025 16:36 | 09/02/2025 11:39 |
| Barium | 0.2089 | mg/L | 0.004 | 10 | 08/27/2025 16:36 | 09/02/2025 11:34 |
| Cadmium | 0.0021 | mg/L | 0.0005 | 5 | 08/27/2025 16:36 | 09/02/2025 11:39 |
| Chromium | 0.3005 | mg/L | 0.004 | 10 | 08/27/2025 16:36 | 09/02/2025 11:34 |
| Lead | 0.0019 | mg/L | 0.0005 | 5 | 08/27/2025 16:36 | 09/02/2025 11:39 |
| Molybdenum | 1.962 | mg/L | 0.02 | 50 | 08/27/2025 16:36 | 09/02/2025 11:29 |
| Selenium | 0.1213 | mg/L | 0.005 | 5 | 08/27/2025 16:36 | 09/02/2025 11:39 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 293 | mg/L as CaCO ₃ | 20.5 | 1 | | 08/27/2025 22:44 |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 368 | mg/L | 20.0 | 10 | | 09/02/2025 10:54 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 11500 | mg/L | 10 | 1 | | 08/29/2025 15:38 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 6 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

Analysis Results Comments

Iron

Matrix spike and/or matrix spike duplicate recovery was low; the associated laboratory control sample recovery was acceptable.

Manganese

Matrix spike and/or matrix spike duplicate recovery was low; the associated laboratory control sample recovery was acceptable.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 7 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720

Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Coop
 WO: 97784



Chain of Custody

Page 1 of 1

Work Order #
 Lab Use Only

| | | |
|---|---|---|
| Company Name and Address <u>Basin Electric Power Coop.</u> <u>Leland Olds Station</u> <u>3901 Highway 200A</u> <u>Stanton, ND 58571</u> | Account # 2040 | Work Order # none # 701-745-7238 701-557-5488 |
| | Contact Mark Dihle | Emails mdihle@bepc.com aknutson@bepc.com |
| | Name of Sampler Mariah Knutson | |
| | Quote Number | Date Submitted 8/27/2025 |
| | Project Name/Number AVS Landfill CCR | Purchase Order # 790708-01 |

| Lab Use Only | Lab | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | # Filtered | Analysis Required | |
|--------------|-----|-------------------|-----------------------------------|-----------------|-----------------|---------------|-------------------|--|
| | | | | | | | | |
| 001 | | MW-19S | GW | 8/26/2025 | 903 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 002 | | DUP | GW | 8/26/2025 | 903 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | | MW-18S | GW | 8/26/2025 | 1137 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | | MW-21S | GW | 8/26/2025 | 1403 | 2 | N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | | AVS LEACHATE POND | SW | 8/26/2025 | 1435 | 1 | N | Total Metals: Mn,Se,Ba,Cd,Cr,B,Mo,As,Pb,Fe,Ca,Mg,Na,K, Cl,SO4, NO2, NO3, TDS, Alkalinity |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|---------------------|-----------|------|------|-----|----------|
| 1. MILLENIUM EXPRESS | 8/27/2025 | NOON | <i>Subby, Kelly</i> | 8/27/2025 | 1444 | 140C | Y/N | TM805 |
| 2. | | | | | | | Y/N | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 8 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Sample Condition Checklist

Date: 27 Aug 25 Time: 1543

Analyst: PW

Work Order #: 97754

Containers Supplied by MVTL: Yes No (Designate customer supplied containers as "Other" in container size column)

| Comments: | | | | | | | | | | |
|-------------------|--|---------------------|---|--------|--|---|---------------------------------|---|--|--|
| Number of Bottles | Container Size (mL) | Container Type | Preservation | pH | Sample IDs Preservation reagent added Date/time Analyst | Unique ID of preservation reagent added | Sample pH after preservation | Required for HNO ₃ samples only (24 hours later) Sample ID pH Recheck Result Date/Time/Analyst | | |
| | | | | | | | | F-(500) = Filtered | CG = Clear Glass, P = Plastic, AG = Amber Glass | |
| 5 | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| 5 | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | | |
| | Oil and grease | (CG) (P) (AG) Other | HCl | n/a | | | | | | |
| | TOC Vials | (G) (AG) | H ₃ PO ₄ | n/a | | | | | | |
| | DOC Vials | (G) (AG) | None H ₃ PO ₄ | n/a | | | | | | |

*All samples requiring analyses performed outside of the Bismarck laboratory (New Ulm and Sub-Contract) are not documented on this form.

*All samples requiring microbiological tests are not documented on this form.

Form #8D-910025-2 M:\Documents\Forms\Approved Templates\Bismarck\Waters\8D-910025-2 Sample Condition Checklist
Page 1 of 1

Effective Date : 1 July 2024

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Tuesday, September 9, 2025 9:31:41 AM

Page 9 of 9



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040 **Client:** Basin Electric Power Cooperative
Workorder: AVS Landfill CCR Wells (103535) **PO:** 790708-01

Mark Dihle
Basin Electric Power Cooperative
1717 E. Interstate Avenue
Bismarck, ND 58503

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:

C. Carroll

Claudette Carroll, Lab Manager Bismarck, ND

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125 ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267 ND W/DW # ND-016

Workorder Comments

All analytes with dilution factors greater than 1 (displayed in DF column) required dilution due to matrix or high concentration of target analyte unless otherwise noted and reporting limits (RDL column) have been adjusted accordingly.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: [Friday, October 24, 2025 8:33:11 AM](#)

Page 1 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535001 | Date Collected: | 10/07/2025 10:04 | Matrix: | Groundwater |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|
| Sample ID: | MW-15S | Date Received: | 10/09/2025 14:43 | Collector: | Client |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | |
| Parameter | Results | Units | RDL | DF | Prepared |
| | | | | | Analyzed |
| | | | | | Qual |
| Method: ASTM D516-16 | | | | | |
| Sulfate | 486 | mg/L | 25 | 5 | 10/15/2025 13:43 |
| Method: EPA 6010D | | | | | |
| Boron | 0.11 | mg/L | 0.1 | 1 | 10/09/2025 16:13 |
| Calcium | 3.93 | mg/L | 2 | 2 | 10/09/2025 16:13 |
| Magnesium | 2.70 | mg/L | 2 | 2 | 10/09/2025 16:13 |
| Potassium | 4.04 | mg/L | 2 | 2 | 10/09/2025 16:13 |
| Sodium | 727 | mg/L | 2 | 2 | 10/09/2025 16:13 |
| Method: SM2320 B-2021 | | | | | |
| Alkalinity, Total | 1074 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 18:00 |
| Bicarbonate | 1074 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 18:00 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 18:00 |
| Method: SM4500 H+ B-2021 | | | | | |
| pH | 8.3 | units | 0.1 | 1 | 10/10/2025 18:00 |
| Method: SM4500-Cl-E 2021 | | | | | |
| Chloride | 13.1 | mg/L | 2.0 | 1 | 10/14/2025 11:55 |
| Method: SM4500-F-C-2021 | | | | | |
| Fluoride | 1.40 | mg/L | 0.1 | 1 | 10/10/2025 18:00 |
| Method: USGS I-1750-85 | | | | | |
| Total Dissolved Solids | 1930 | mg/L | 10 | 1 | 10/10/2025 15:21 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 2 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535002 | Date Collected: | 10/07/2025 10:52 | | Matrix: | Groundwater |
|---------------------------------|-----------|---------------------------|------------------|----|------------------|--------------------|
| Sample ID: | MW-20S | Date Received: | 10/09/2025 14:43 | | Collector: | Client |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 74.8 | mg/L | 5 | 1 | | 10/15/2025 13:44 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.13 | mg/L | 0.1 | 1 | 10/09/2025 16:13 | 10/13/2025 15:56 |
| Calcium | 6.19 | mg/L | 2 | 2 | 10/09/2025 16:13 | 10/20/2025 15:37 |
| Magnesium | 3.38 | mg/L | 2 | 2 | 10/09/2025 16:13 | 10/20/2025 15:37 |
| Potassium | 4.56 | mg/L | 2 | 2 | 10/09/2025 16:13 | 10/20/2025 15:37 |
| Sodium | 755 | mg/L | 2 | 2 | 10/09/2025 16:13 | 10/20/2025 15:37 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 1380 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:11 |
| Bicarbonate | 1380 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:11 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:11 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 10/10/2025 18:11 * |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 25.6 | mg/L | 2.0 | 1 | | 10/14/2025 11:56 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 1.20 | mg/L | 0.1 | 1 | | 10/10/2025 18:11 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 1800 | mg/L | 10 | 1 | | 10/10/2025 15:21 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 3 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535003 | Date Collected: | 10/08/2025 08:16 | | Matrix: | Groundwater |
|---------------------------------|-----------|---------------------------|------------------|----|------------------|------------------|
| Sample ID: | MW-16S | Date Received: | 10/09/2025 14:43 | | Collector: | Client |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 125 | mg/L | 5 | 1 | | 10/15/2025 13:45 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.15 | mg/L | 0.1 | 1 | 10/09/2025 16:13 | 10/13/2025 15:57 |
| Calcium | 3.71 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:38 |
| Magnesium | 2.35 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:38 |
| Potassium | 3.70 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:38 |
| Sodium | 657 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:38 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 739 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:23 |
| Bicarbonate | 730 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:23 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:23 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.4 | units | 0.1 | 1 | | 10/10/2025 18:23 |
| Method: SM4500-Cl-E 2021 | | | | | | |
| Chloride | 32.6 | mg/L | 2.0 | 1 | | 10/14/2025 11:58 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 2.37 | mg/L | 0.1 | 1 | | 10/10/2025 18:23 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 1150 | mg/L | 10 | 1 | | 10/10/2025 15:21 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 4 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535004 | Date Collected: | 10/08/2025 09:34 | Matrix: | Groundwater | | |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-17S | Date Received: | 10/09/2025 14:43 | Collector: | Client | | |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 300 | mg/L | 25 | 5 | | 10/15/2025 13:46 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 10/09/2025 16:13 | 10/13/2025 15:57 | |
| Calcium | 3.72 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:42 | |
| Magnesium | 2.28 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:42 | |
| Potassium | 3.66 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:42 | |
| Sodium | 674 | mg/L | 1 | 1 | 10/09/2025 16:13 | 10/20/2025 15:42 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1125 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:36 | |
| Bicarbonate | 1125 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:36 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 18:36 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 10/10/2025 18:36 | |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 13.6 | mg/L | 2.0 | 1 | | 10/14/2025 11:59 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.48 | mg/L | 0.1 | 1 | | 10/10/2025 18:36 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1740 | mg/L | 10 | 1 | | 10/10/2025 15:21 | |

Analysis Results Comments

Fluoride

Matrix spike and/or matrix spike duplicate recovery was high; the associated laboratory fortified blank recovery was acceptable.

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 5 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535005 | Date Collected: | 10/08/2025 11:16 | Matrix: | Groundwater |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|
| Sample ID: | MW-22S | Date Received: | 10/09/2025 14:43 | Collector: | Client |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | |
| Parameter | Results | Units | RDL | DF | Prepared |
| | | | | | Analyzed |
| | | | | | Qual |
| Method: ASTM D516-16 | | | | | |
| Sulfate | 234 | mg/L | 25 | 5 | 10/15/2025 13:54 |
| Method: EPA 6010D | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 10/09/2025 16:13 |
| Calcium | 2.56 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Magnesium | 2.03 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Potassium | 3.53 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Sodium | 641 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Method: SM2320 B-2021 | | | | | |
| Alkalinity, Total | 1042 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 18:48 |
| Bicarbonate | 1027 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 18:48 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 18:48 |
| Method: SM4500 H+ B-2021 | | | | | |
| pH | 8.4 | units | 0.1 | 1 | 10/10/2025 18:48 |
| Method: SM4500-Cl-E 2021 | | | | | |
| Chloride | 11.4 | mg/L | 2.0 | 1 | 10/14/2025 12:00 |
| Method: SM4500-F-C-2021 | | | | | |
| Fluoride | 1.84 | mg/L | 0.1 | 1 | 10/10/2025 18:48 |
| Method: USGS I-1750-85 | | | | | |
| Total Dissolved Solids | 1610 | mg/L | 10 | 1 | 10/10/2025 15:21 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 6 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535006 | Date Collected: | 10/08/2025 11:16 | Matrix: | Groundwater |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|
| Sample ID: | DUP | Date Received: | 10/09/2025 14:43 | Collector: | Client |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | |
| Parameter | Results | Units | RDL | DF | Prepared |
| | | | | | Analyzed |
| | | | | | Qual |
| Method: ASTM D516-16 | | | | | |
| Sulfate | 247 | mg/L | 25 | 5 | 10/15/2025 13:48 |
| Method: EPA 6010D | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 10/09/2025 16:13 |
| Calcium | 2.55 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Magnesium | 2.03 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Potassium | 3.47 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Sodium | 640 | mg/L | 1 | 1 | 10/09/2025 16:13 |
| Method: SM2320 B-2021 | | | | | |
| Alkalinity, Total | 1062 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 19:01 |
| Bicarbonate | 1047 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 19:01 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | 10/10/2025 19:01 |
| Method: SM4500 H+ B-2021 | | | | | |
| pH | 8.4 | units | 0.1 | 1 | 10/10/2025 19:01 |
| Method: SM4500-CI-E 2021 | | | | | |
| Chloride | 11.2 | mg/L | 2.0 | 1 | 10/14/2025 12:01 |
| Method: SM4500-F-C-2021 | | | | | |
| Fluoride | 1.84 | mg/L | 0.1 | 1 | 10/10/2025 19:01 |
| Method: USGS I-1750-85 | | | | | |
| Total Dissolved Solids | 1660 | mg/L | 10 | 1 | 10/10/2025 15:21 |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 7 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535007 | Date Collected: | 10/08/2025 12:18 | Matrix: | Groundwater | | |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-25S | Date Received: | 10/09/2025 14:43 | Collector: | Client | | |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 36.0 | mg/L | 5 | 1 | | 10/15/2025 14:02 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.14 | mg/L | 0.1 | 1 | 10/10/2025 16:15 | 10/13/2025 16:02 | |
| Calcium | 4.56 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:52 | |
| Magnesium | 3.40 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:52 | |
| Potassium | 4.50 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:52 | |
| Sodium | 834 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:52 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1553 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 19:14 | |
| Bicarbonate | 1529 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 19:14 | |
| Carbonate | 24 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 19:14 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.4 | units | 0.1 | 1 | | 10/10/2025 19:14 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 40.4 | mg/L | 2.0 | 1 | | 10/14/2025 12:02 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.42 | mg/L | 0.1 | 1 | | 10/10/2025 19:14 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1940 | mg/L | 10 | 1 | | 10/10/2025 15:21 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 8 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724.
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535008 | Date Collected: | 10/08/2025 13:47 | Matrix: | Groundwater | | |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-26S | Date Received: | 10/09/2025 14:43 | Collector: | Client | | |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 120 | mg/L | 5 | 1 | | 10/15/2025 14:04 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.12 | mg/L | 0.1 | 1 | 10/10/2025 16:15 | 10/13/2025 16:04 | |
| Calcium | 17.3 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:53 | |
| Magnesium | 3.31 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:53 | |
| Potassium | 5.21 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:53 | |
| Sodium | 746 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:53 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1382 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 19:28 | |
| Bicarbonate | 1367 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 19:28 | |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 19:28 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.4 | units | 0.1 | 1 | | 10/10/2025 19:28 | |
| Method: SM4500-CI-E 2021 | | | | | | * | |
| Chloride | 31.5 | mg/L | 2.0 | 1 | | 10/14/2025 12:09 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.36 | mg/L | 0.1 | 1 | | 10/10/2025 19:28 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 1870 | mg/L | 10 | 1 | | 10/10/2025 15:21 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 9 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

Analytical Results

| Lab ID: | 103535009 | Date Collected: | 10/08/2025 14:45 | Matrix: | Groundwater | | |
|---------------------------------|-----------|---------------------------|------------------|------------|------------------|------------------|------|
| Sample ID: | MW-24S | Date Received: | 10/09/2025 14:43 | Collector: | Client | | |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed | Qual |
| Method: ASTM D516-16 | | | | | | | |
| Sulfate | 52.6 | mg/L | 5 | 1 | | 10/15/2025 14:05 | |
| Method: EPA 6010D | | | | | | | |
| Boron | 0.10 | mg/L | 0.1 | 1 | 10/10/2025 16:15 | 10/13/2025 16:04 | |
| Calcium | 4.54 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:55 | |
| Magnesium | 3.48 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:55 | |
| Potassium | 4.58 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:55 | |
| Sodium | 841 | mg/L | 2 | 2 | 10/10/2025 16:15 | 10/20/2025 15:55 | |
| Method: SM2320 B-2021 | | | | | | | |
| Alkalinity, Total | 1540 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 21:38 | |
| Bicarbonate | 1509 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 21:38 | |
| Carbonate | 31 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 21:38 | |
| Method: SM4500 H+ B-2021 | | | | | | | |
| pH | 8.4 | units | 0.1 | 1 | | 10/10/2025 21:38 | * |
| Method: SM4500-CI-E 2021 | | | | | | | |
| Chloride | 49.7 | mg/L | 2.0 | 1 | | 10/14/2025 12:11 | |
| Method: SM4500-F-C-2021 | | | | | | | |
| Fluoride | 1.61 | mg/L | 0.1 | 1 | | 10/10/2025 21:38 | |
| Method: USGS I-1750-85 | | | | | | | |
| Total Dissolved Solids | 2040 | mg/L | 10 | 1 | | 10/10/2025 15:21 | |

Analysis Results Comments

pH

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 10 of 19

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

**Account #:** 2040**Client:** Basin Electric Power Cooperative**Analytical Results**

| Lab ID: | 103535010 | Date Collected: | 10/08/2025 13:09 | | Matrix: | Groundwater |
|---------------------------------|-----------|---------------------------|------------------|----|-------------------|------------------|
| Sample ID: | MW-27S | Date Received: | 10/09/2025 14:43 | | Collector: | Client |
| Temp @ Receipt (C): | 5.0 | Received on Ice: | Yes | | | |
| Parameter | Results | Units | RDL | DF | Prepared | Analyzed |
| Method: ASTM D516-16 | | | | | | |
| Sulfate | 141 | mg/L | 25 | 5 | | 10/15/2025 14:06 |
| Method: EPA 6010D | | | | | | |
| Boron | 0.21 | mg/L | 0.1 | 1 | 10/10/2025 16:15 | 10/13/2025 16:05 |
| Calcium | 58.1 | mg/L | 5 | 5 | 10/10/2025 16:15 | 10/20/2025 15:56 |
| Magnesium | 27.4 | mg/L | 5 | 5 | 10/10/2025 16:15 | 10/20/2025 15:56 |
| Potassium | 11.1 | mg/L | 5 | 5 | 10/10/2025 16:15 | 10/20/2025 15:56 |
| Sodium | 952 | mg/L | 5 | 5 | 10/10/2025 16:15 | 10/20/2025 15:56 |
| Method: SM2320 B-2021 | | | | | | |
| Alkalinity, Total | 1686 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 21:52 |
| Bicarbonate | 1678 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 21:52 |
| Carbonate | <20.5 | mg/L as CaCO ₃ | 20.5 | 1 | | 10/10/2025 21:52 |
| Method: SM4500 H+ B-2021 | | | | | | |
| pH | 8.3 | units | 0.1 | 1 | | 10/10/2025 21:52 |
| Method: SM4500-CI-E 2021 | | | | | | |
| Chloride | 65.0 | mg/L | 10.0 | 5 | | 10/14/2025 12:12 |
| Method: SM4500-F-C-2021 | | | | | | |
| Fluoride | 1.48 | mg/L | 0.1 | 1 | | 10/10/2025 21:52 |
| Method: USGS I-1750-85 | | | | | | |
| Total Dissolved Solids | 2370 | mg/L | 10 | 1 | | 10/10/2025 15:21 |

Analysis Results Comments**pH**

Sample analyzed beyond holding time.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 11 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

| QC Results Summary | | | | | | | WO #: | 103535 | | |
|--------------------|---------|--------------------|--------------|--------------|--------|-------|------------------|----------------------------|-------------------------|-------------------------|
| Sulfate | QC Type | Original Sample ID | Blank Result | Spike Amount | Units: | mg/L | RPD (%) | RPD Limit (%) | | |
| LFB | | | | | 100 | 100.0 | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) |
| | LFB | | | 100 | 96.9 | | 85 | 115 | | |
| | LFB | | | 100 | 93.7 | | 85 | 115 | | |
| | LFB | | | 100 | 96.4 | | 85 | 115 | | |
| | LFB | | | 100 | 94.3 | | 85 | 115 | | |
| | LFB | | | 100 | 99.3 | | 85 | 115 | | |
| | LFB | | | 100 | 104.0 | | 85 | 115 | | |
| | LFB | | | 100 | 110.0 | | 85 | 115 | | |
| | LFB | | | 100 | 107.0 | | 85 | 115 | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS | | | <5 | | | | | | |
| | MS/MSD | 103146005 | | 500 | 80.4 | 83.0 | 85 | 115 | 1.6 | 20 |
| | MS/MSD | 103212003 | | 1000 | 75.9 | 77.6 | 85 | 115 | 1.2 | 20 |
| | MS/MSD | 103374304 | | 2000 | 66.9 | 72.8 | 85 | 115 | 3.6 | 20 |
| | MS/MSD | 103380005 | | 500 | 93.4 | 93.9 | 85 | 115 | 0.4 | 20 |
| | MS/MSD | 103380013 | | 4000 | 72.7 | 69.5 | 85 | 115 | 1.5 | 20 |
| | MS/MSD | 103395008 | | 1000 | 99.5 | 103.9 | 85 | 115 | 2.2 | 20 |
| | MS/MSD | 103535005 | | 500 | 99.5 | 100.2 | 85 | 115 | 0.5 | 20 |
| | MS/MSD | 103708001 | | 1000 | 90.3 | 94.5 | 85 | 115 | 2.3 | 20 |
| | MS/MSD | 103813302 | | 100 | 110.0 | 110.2 | 85 | 115 | 0.0 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 12 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Chloride | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB | | | 30 | 97.3 | | 90 | 110 | | |
| LFB | | | 30 | 97.5 | | 90 | 110 | | |
| LFB | | | 30 | 97.8 | | 90 | 110 | | |
| LFB | | | 30 | 97.9 | | 90 | 110 | | |
| LFB | | | 30 | 97.3 | | 90 | 110 | | |
| LFB | | | 30 | 97.1 | | 90 | 110 | | |
| LFB | | | 30 | 97.0 | | 90 | 110 | | |
| LFB | | | 30 | 97.1 | | 90 | 110 | | |
| LFB | | | 30 | 97.3 | | 90 | 110 | | |
| LFB | | | 30 | 96.5 | | 90 | 110 | | |
| LFB | | | 30 | 97.3 | | 90 | 110 | | |
| LFB | | | 30 | 97.0 | | 90 | 110 | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MB | | <2.0 | | | | | | | |
| MS/MSD | 103185005 | | 30 | 98.8 | 100.6 | 80 | 120 | 0.9 | 20 |
| MS/MSD | 103212003 | | 30 | 99.7 | 99.0 | 80 | 120 | 0.5 | 20 |
| MS/MSD | 103386005 | | 600 | 110.9 | 115.2 | 80 | 120 | 0.8 | 20 |
| MS/MSD | 103431001 | | 30 | 88.1 | 95.3 | 80 | 120 | 1.6 | 20 |
| MS/MSD | 103646004 | | 30 | 79.6 | 77.6 | 80 | 120 | 0.4 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 13 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885

www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Chloride | | Units: mg/L | | | | | | | |
|-----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| MS/MSD | 103708001 | | 30 | 100.3 | 98.2 | 80 | 120 | 0.8 | 20 |
| Boron | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-DE | | | 0.4 | 93.5 | | 85 | 115 | | |
| LFB-DE | | | 0.4 | 104.0 | | 85 | 115 | | |
| MB | | <0.1 | | | | | | | |
| MB | | <0.1 | | | | | | | |
| PDS/PDSO | 102682017 | | 8 | 87.5 | 86.8 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 103496001 | | 4 | 87.4 | 88.9 | 75 | 125 | 1.0 | 20 |
| MS/MSD | 103535007 | | 0.4 | 92.5 | 91.3 | 70 | 130 | 1.0 | 20 |
| Calcium | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 107.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 108.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 103369003 | | 500 | 105.0 | 105.0 | 75 | 125 | 0.1 | 20 |
| PDS/PDSO | 103380005 | | 500 | 97.7 | 99.3 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 103380012 | | 500 | 96.6 | 97.0 | 75 | 125 | 0.2 | 20 |
| DUP | 103471001 | | | | | | | 0.9 | 20 |
| PDS/PDSO | 103502002 | | 100 | 102.0 | 101.0 | 75 | 125 | 0.6 | 20 |
| PDS/PDSO | 103571001 | | 100 | 94.5 | 95.2 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 103571003 | | 100 | 52.4 | 94.5 | 75 | 125 | 1.1 | 20 |
| PDS/PDSO | 103927008 | | 100 | 101.0 | 102.0 | 75 | 125 | 0.6 | 20 |
| Magnesium | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 106.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 108.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 103369003 | | 500 | 105.0 | 105.0 | 75 | 125 | 0.2 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 14 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative

| Magnesium | | Units: mg/L | | | | | | | |
|-----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| PDS/PDSO | 103380005 | | 500 | 102.0 | 102.0 | 75 | 125 | 0.5 | 20 |
| POS/PDSO | 103380012 | | 500 | 101.0 | 101.0 | 75 | 125 | 0.2 | 20 |
| DUP | 103471001 | | | | | | | 0.7 | 20 |
| PDS/PDSO | 103502002 | | 100 | 103.0 | 102.0 | 75 | 125 | 0.6 | 20 |
| PDS/PDSO | 103571001 | | 100 | 89.9 | 90.7 | 75 | 125 | 0.3 | 20 |
| POS/PDSO | 103571003 | | 100 | 86.2 | 89.5 | 75 | 125 | 1.2 | 20 |
| PDS/PDSO | 103927008 | | 100 | 99.4 | 99.7 | 75 | 125 | 0.2 | 20 |
| Potassium | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 103.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 105.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 103369003 | | 500 | 95.4 | 97.5 | 75 | 125 | 1.1 | 20 |
| PDS/PDSO | 103380005 | | 500 | 104.0 | 104.0 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 103380012 | | 500 | 104.0 | 104.0 | 75 | 125 | 0.2 | 20 |
| DUP | 103471001 | | | | | | | 0.9 | 20 |
| PDS/PDSO | 103502002 | | 100 | 102.0 | 101.0 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 103571001 | | 100 | 100.0 | 101.0 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 103571003 | | 100 | 97.3 | 99.8 | 75 | 125 | 1.9 | 20 |
| PDS/PDSO | 103927008 | | 100 | 100.0 | 99.5 | 75 | 125 | 0.6 | 20 |
| Sodium | | Units: mg/L | | | | | | | |
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| LFB-MI | | | 100 | 104.0 | | 85 | 115 | | |
| LFB-MI | | | 100 | 106.0 | | 85 | 115 | | |
| MB | | <1 | | | | | | | |
| MB | | <1 | | | | | | | |
| PDS/PDSO | 103369003 | | 500 | 99.5 | 99.0 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 103380005 | | 500 | 93.2 | 94.2 | 75 | 125 | 0.5 | 20 |
| PDS/PDSO | 103380012 | | 500 | 102.0 | 102.0 | 75 | 125 | 0.4 | 20 |
| DUP | 103471001 | | | | | | | 1.9 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 15 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Sodium | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| PDS/PDSO | 103502002 | | 100 | 81.4 | 79.3 | 75 | 125 | 0.6 | 20 |
| PDS/PDSO | 103571001 | | 100 | 78.6 | 79.7 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 103571003 | | 100 | 75.0 | 76.2 | 75 | 125 | 0.3 | 20 |
| PDS/PDSO | 103927308 | | 100 | 96.8 | 98.5 | 75 | 125 | 0.9 | 20 |

| Alkalinity, Total | | Units: mg/L | | | | | | | |
|-------------------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM | | | 501 | 94.0 | | 80 | 120 | | |
| LFB | | | 410 | 96.6 | | 90 | 110 | | |
| LFB | | | 410 | 96.8 | | 90 | 110 | | |
| LFB | | | 410 | 94.3 | | 90 | 110 | | |
| LFB | | | 410 | 96.1 | | 90 | 110 | | |
| MB | | | <20.5 | | | | | | |
| MB | | | <20.5 | | | | | | |
| MB | | | <20.5 | | | | | | |
| MB | | | <20.5 | | | | | | |
| MS/MSD | 103369004 | | 410 | 82.4 | 86.6 | 80 | 120 | 1.7 | 20 |
| MS/MSD | 103535002 | | 410 | 86.3 | 98.6 | 80 | 120 | 2.8 | 20 |
| MS/MSD | 103577001 | | 410 | 65.5 | 65.6 | 80 | 120 | 0.3 | 20 |

| pH | | Units: units | | | | | | | |
|---------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM-PH | | | 6 | 99.7 | | | | | |
| CRM-PH | | | 6 | 99.7 | | | | | |
| CRM-PH | | | 6 | 99.5 | | | | | |
| DUP | 103502002 | | | | | | | 0.8 | 20 |

| Fluoride | | Units: mg/L | | | | | | | |
|----------|--------------------|--------------|--------------|------------------|----------------------------|-------------------------|-------------------------|---------|---------------|
| QC Type | Original Sample ID | Blank Result | Spike Amount | Spike % Recovery | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
| CRM-F | | | 3.34 | 101.0 | | 63.83 | 111.07 | | |
| LFB-F | | | 0.5 | 102.0 | | 90 | 110 | | |
| LFB-F | | | 0.5 | 100.0 | | 90 | 110 | | |
| LFB-F | | | 0.5 | 102.0 | | 90 | 110 | | |
| MB-F | | | <0.1 | | | | | | |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 16 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative

| Fluoride | QC Type | Original Sample ID | Blank Result | Spike Amount | Units: Spike % Recovery | mg/L | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
|----------|---------|--------------------|--------------|--------------|-------------------------|------|----------------------------|-------------------------|-------------------------|---------|---------------|
| | MB-F | | | <0.1 | | | | | | | |

| | | | | | | | | | | | |
|--------|-----------|--|--|------|-------|-------|----|-----|-----|----|--|
| MB-F | | | | <0.1 | | | | | | | |
| MS/MSD | 103535004 | | | 0.5 | 136.0 | 108.0 | 80 | 120 | 6.7 | 20 | |
| MS/MSD | 103583001 | | | 0.5 | 100.0 | 98.0 | 80 | 120 | 0.6 | 20 | |

| Total Dissolved Solids | QC Type | Original Sample ID | Blank Result | Spike Amount | Units: Spike % Recovery | mg/L | Spike Duplicate % Recovery | Lower Control Limit (%) | Upper Control Limit (%) | RPD (%) | RPD Limit (%) |
|------------------------|---------|--------------------|--------------|--------------|-------------------------|-------|----------------------------|-------------------------|-------------------------|---------|---------------|
| | CRM | | | 736 | 100.0 | 90.35 | 90.35 | 110.33 | 110.33 | | |

| | | | | | | | | | | | |
|-----|-----------|--|--|-----|--|--|--|--|--|-----|----|
| MB | | | | <10 | | | | | | | |
| DUP | 103535007 | | | | | | | | | 0.5 | 20 |
| DUP | 103575001 | | | | | | | | | 0.7 | 20 |

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 17 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Account #: 2040

Client: Basin Electric Power Cooperative



Minnesota Valley Testing Laboratories, Inc.
 2616 East Broadway Avenue
 Bismarck, ND 58501
 Phone: (701) 258-9720
 Toll Free: (800) 279-6885 Fax: (701) 258-9724

Basin Electric Power Cooperative

WO: 103535



Chain of Custody

Page 1 of 1

Work Order #
 Lab Use Only

| | | |
|---|---|--|
| Company Name and Address Basin Electric Power Coop. Leland Olds Station 3901 Highway 200A Stanton, ND 58511 | Account # 2040 | Phone # 701-745-7238 701-557-5463 |
| Contact Mark Dihle | Emails mdihle@bepc.com aknutson@bepc.com | |
| Name of Sampler Mariah Knutson | | |
| Quote Number Attn: Liabilities | Date Submitted 10/9/2025 | |
| Project Name/Number AVS Landfill CCR Wells | Purchase Order # 79070801 | |

| Lab Use Only | Sample ID | Sample Matrix GW - Groundwater | Date Sampled | Time Sampled | # Filtered | Analysis Required |
|--------------|-----------|-----------------------------------|-----------------|-----------------|---------------|--|
| 001 | MW-15S | GW | 10/7/2025 | 1004 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 002 | MW-20S | GW | 10/7/2025 | 1052 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 003 | MW-16S | GW | 10/8/2025 | 816 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 004 | MW-17S | GW | 10/8/2025 | 934 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 005 | MW-22S | GW | 10/8/2025 | 1116 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 006 | DUP | GW | 10/8/2025 | 1116 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 007 | MW-25S | GW | 10/8/2025 | 1218 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 008 | MW-26S | GW | 10/8/2025 | 1347 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 009 | MW-24S | GW | 10/8/2025 | 1445 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |
| 010 | MW-27S | GW | 10/8/2025 | 1309 | 2 N | B, Ca, Cl, F, SO4, TDS, Mg, Na, K, Alkalinity, (Total Carbonate, Bicarbonate), pH, |

Comments:

| Transferred by | Date | Time | Received by | Date | Time | Temp | ROI | Therm. # |
|----------------------|-----------|------|--------------|-----------|------|--------|-----|----------|
| 1. MILLENIUM EXPRESS | 10/9/2025 | NOON | <i>Julie</i> | 10/9/2025 | 1443 | 5.0 °C | Y/N | TM95 |
| 2. | | | | | | | Y/N | |

Please submit the top copy with your samples. We will return the completed original with your results.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 18 of 19



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 515-382-5486 ~ Fax 515-382-3885
www.MVTL.com



Account #: 2040

Client: Basin Electric Power Cooperative



Sample Condition Checklist

Date: 9 OCT 25 Time: 1550 Analyst: CC
 Work Order #: 163535

Containers Supplied by MVTL: Yes No (Designate customer supplied containers as "Other" in container size column)

| Comments: | | | | | | | | | |
|-------------------|--|---------------------|---|--------|--|---|---------------------------------|--|---|
| Number of Bottles | Container Size (mL) | Container Type | Preservation | pH | Sample IDs Preservation reagent added Date/Time Analyst | Unique ID of preservation reagent added | Sample pH after preservation | Required for HNO ₃ samples only (24 hours later) | |
| | | | | | | | | CG = Clear Glass, P = Plastic, AG = Amber Glass | Sample ID pH Recheck Result Date/Time/Analyst |
| 10 | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| 10 | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | (125) (250) (500) F-(500) (1000) Other | (CG) (P) (AG) Other | NONE HNO ₃ H ₂ SO ₄ NaOH NaOH/ZnAcet HCl | <2 >12 | | | | | |
| | Oil and grease | (CG) (P) (AG) Other | HCl | n/a | | | | | |
| | TOC Vials | (G) (AG) | H ₃ PO ₄ | n/a | | | | | |
| | DOC Vials | (G) (AG) | None H ₃ PO ₄ | n/a | | | | | |

*All samples requiring analyses performed outside of the Bismarck laboratory (New Ulm and Sub-Contract) are not documented on this form.

*All samples requiring microbiological tests are not documented on this form.

Form #80-910025-2

M:\Documents\FORMS\Approved Templates\Bismarck\Waters\80-910025-2 Sample Condition Checklist.xlsx

Page 1 of 1

Effective Date : 1 July 2024

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Friday, October 24, 2025 8:33:11 AM

Page 19 of 19



Attachment B

Statistical Evaluation

Technical Memorandum

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Project: 34291134.00

1 Introduction

Basin Electric Power Cooperative (Basin Electric) owns and operates Antelope Valley Station (AVS), comprised of a coal-fired generating station consisting of two power generating units, located in Beulah, North Dakota (Figure 1). Unit 1 coal-based operations began in 1984, and Unit 2 operations began in 1986. The landfill (Site or CCR Landfill) was permitted by the North Dakota Department of Environmental Quality (NDDEQ) in 1995 under Permit SP-160 (now designated 0160) and began accepting coal combustion residuals (CCR) in 1996. The most recent Permit 0160 was issued by NDDEQ in early 2022, and the most recent cell including a composite liner system and leachate collection system was constructed the same year. Basin Electric utilizes a consulting firm, Barr Engineering Co. (Barr) to assist in groundwater reporting and analysis. Barr is familiar with the site and installed and certified the most recent wells (MW-25S, MW-26S, and MW-27S) added to the network. Barr has reviewed the historical groundwater data and CCR information for the site and is knowledgeable about facility design and operation.

The CCRs including fly ash, bottom ash, and flue gas desulfurization (FGD) waste are managed at the Site along with other minor wastes accepted as per the NDDEQ permit. The CCR unit is required to comply with the provisions of the US Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261, Disposal of Coal Combustion Residuals from Electric Utilities) and the NDDEQ CCR Rule (NDAC Title 33.1, Article 20, Chapter 8).

Basin Electric has implemented a Detection Monitoring Program in accordance with the U.S. Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261) for the Site. As part of the Detection Monitoring Program, statistically significant increases (SSIs) in monitored groundwater quality parameters over background were identified at the Site for the following monitoring wells during semi-annual detection monitoring completed in the fall of 2024 on October 1-2 and 8, 2024:

- MW-16S – Chloride
- MW-20S – Chloride
- MW-24S – Chloride
- MW-25S – Chloride
- MW-26S – Chloride
- MW-27S – Boron, calcium, and chloride

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 2

The CCR Rule (US EPA, 2015) § 257.94(e)(2) allows for an alternative source demonstration (ASD) in the event of an identified SSI in a water quality parameter in a downgradient monitoring well over background levels:

The owner or operator may demonstrate that a source other than the CCR unit caused the statistically significant increase over background levels for a constituent or that the statistically significant increase resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. The owner or operator must complete the written demonstration within 90 days of detecting a statistically significant increase over background levels to include obtaining a certification from a qualified professional engineer verifying the accuracy of the information in the report.

The purpose of this work is to evaluate the data collected as part of the October 2024 monitoring event, along with historical data, to demonstrate if the SSIs are the results of a "source other than the CCR unit" or due to natural variation in groundwater quality or an error in sampling, analysis, or statistical evaluation. Nothing in the foregoing citation of the rule requires that the owner/operator disprove any and all potential counterarguments that EPA or others may offer to refute this demonstration. Such arguments if valid, would need to follow requirements of the rule to show a basis in fact that includes rule requirements that are based on site-specific information, and must be certified by a North Dakota licensed professional engineer. This memorandum provides a science-based reason for the data results that indicate a source other than the CCR unit.

This memorandum provides written documentation of an Alternative Source Demonstration (ASD) and certification of accuracy as described in the CCR Rule (§ 257.94(e)(2)).

1.1 Background Information

Figure 1 shows the site location and Figure 2 provides well locations. A piezometric surface map showing groundwater elevations in the lignite, which represent the uppermost aquifer in the vicinity of the CCR landfill, is presented on Figure 3, using measurements from October 2024. Groundwater generally flows from southwest to northeast.

In late 2023, three new landfill expansion wells, MW-25S, MW-26S, and MW-27S, were installed at the Site. Baseline sampling was initiated in June 2024, and these wells were first evaluated in the detection monitoring program in June 2024. There is limited data at these locations for historical comparison.

A comparison of the detection monitoring groundwater results with the prediction limits calculated using the 2016-2023 background assessment data from upgradient wells MW-18S, MW-19S, and MW-21S are included in Table 1. Concentrations for Appendix III parameters observed in October 2024 are shown on time series graphs in Attachment A. Chloride concentrations at MW-16S, MW-20S, and MW-24S are consistent with those observed during baseline monitoring events. Baseline monitoring for MW-25S, MW-26S, and MW-27S is ongoing.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 3

Table 1 SSIs Compared to Prediction Limits

| Event | Well | Parameter (units) | Measured | Interwell Prediction Limit |
|--|--------|-------------------|----------|----------------------------|
| Detection Monitoring – 2024 #2 (Fall) | MW-16S | Chloride (mg/L) | 26.0 | 18.7 |
| | MW-20S | Chloride (mg/L) | 25.8 | 18.7 |
| | MW-24S | Chloride (mg/L) | 50.0 | 18.7 |
| | MW-25S | Chloride (mg/L) | 42.3 | 18.7 |
| | MW-26S | Chloride (mg/L) | 29.7 | 18.7 |
| | MW-27S | Boron (mg/L) | 0.40 | 0.17 |
| | MW-27S | Calcium (mg/L) | 206 | 13.0 |
| | MW-27S | Chloride (mg/L) | 62.0 | 18.7 |

1.2 Rule Requirements

The requirements for written documentation and certification of accuracy for an ASD are included in § 257.95(g) (3):

Within 90 days of finding that any of the constituents listed in appendix IV to this part have been detected at a statistically significant level exceeding the groundwater protection standards the owner or operator must... Demonstrate that a source other than the CCR unit caused the contamination, or that the statistically significant increase resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. Any such demonstration must be supported by a report that includes the factual or evidentiary basis for any conclusions and must be certified to be accurate by a qualified professional engineer or approval from the Participating State Director or approval from EPA where EPA is the permitting authority. If a successful demonstration is made, the owner or operator must continue monitoring in accordance with the assessment monitoring program pursuant to this section, and may return to detection monitoring if the constituents in Appendix III and Appendix IV of this part are at or below background as specified in paragraph (e) of this section. The owner or operator must also include the demonstration in the annual groundwater monitoring and corrective action report required by §257.90(e), in addition to the certification by a qualified professional engineer or the approval from the Participating State Director or the approval from EPA where EPA is the permitting authority.

In accordance with the above requirement, this memorandum is being issued within 90 days of the SSI determination (January 3, 2025) following the review and analysis of the results provided in the final laboratory report which was received on October 18, 2024.

2 Potential Alternative Sources Review

The CCR Rule provides five potential alternative source categories:

1. A source other than the CCR unit
2. Sampling (or sampling equipment) methods

3. Laboratory methods
4. Statistical methods
5. Natural variation in groundwater quality

Site data were evaluated to identify potential causes for chloride concentrations in monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, and MW-26S; and boron, calcium, and chloride concentrations in MW-27S exceeding interwell prediction limits. Chloride is naturally occurring and may not necessarily be the result of a release from a CCR unit; therefore, a source other than the CCR unit, natural variation in groundwater quality, and statistical methods were further investigated as part of the ASD. Sampling methods were further investigated for the boron, calcium, and chloride SSIs at MW-27S.

2.1 Travel Time from Source of Release

Monitoring locations MW-24S, MW-25S, MW-26S, and MW-27S were added to the monitoring network in anticipation of waste placement in the landfill expansion area (Figure 3). Waste was first placed in lined Cell 5 in the landfill expansion area in May 2023. Groundwater travel time was considered both vertically as groundwater moves through the unsaturated zone and horizontally as groundwater moves in the saturated zone.

2.1.1 Migration through the liner

Vertical migration of leachate would be controlled by the presence of a driving head on the landfill liner and then migration through the unsaturated zone.

Considering the properties of the CCR materials in landfill, that the design to eliminate head on the liner, and the facility pumping operations have been normal, there is no evidence of any leachate accumulation on the liner. However, landfill leachate depth is limited to 1 foot on the liner by rule in North Dakota. Even if the 60-mil thick synthetic liner were breached (again there is no evidence that this has ever occurred), the underlying 2-foot-thick clay liner was tested and verified to exhibit a vertical permeability of 1×10^{-7} cm/s (2.8×10^{-4} feet/day) or less. Assuming a 1-foot driving head over a 2-foot-thick liner yields a vertical hydraulic gradient of 0.5 ft/ft.

The vertical advective velocity (average linear velocity or seepage velocity) of vertical saturated groundwater flow is calculated using the following equation:

$$v = \left(\frac{Kv}{n_e} \right) \left(\frac{dHv}{dLv} \right)$$

Or, stated in a more compact form:

$$v = \frac{Ki}{n_e}, \text{ where } K = \text{hydraulic conductivity, } i = \text{gradient, and } n_e = \text{effective porosity.}$$

Using an effective porosity for clay of 0.40, the above equation yields an advective velocity 3.5×10^{-4} ft/day. Dividing the distance by the velocity yields a travel time of 15.7 years to transit the liner.

2.1.2 Migration through the unsaturated zone

Assuming that the leachate fully breached the liner, the release would then need to transit through the entire unsaturated zone to reach the water table below the facility. Although unsaturated flow can be

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 5

complex, its calculation can be greatly simplified by making a conservative assumption that the flow is saturated. This is a conservative assumption because unsaturated flow would be characterized by a wetting front (and possible drying cycles) that would result in much lower velocities (longer travel time) than are estimated by assuming saturated flow.

The geologic cross sections and well logs suggest that the mine spoils and Sentinel Butte Formation are thinnest in the vicinity of MW-23S. Assuming that the base of the landfill is at 2050 feet (MSL), the mine spoils are about 90 feet thick at MW-23S, and the Sentinel Butte is about 80 feet thick above the Spaer Bed.

Geotechnical testing of materials at the site has shown mine spoils exhibit relatively low vertical hydraulic conductivities. The four undisturbed vertical hydraulic conductivity values for the mine spoils were 1.3×10^{-7} cm/sec, 4.0×10^{-8} cm/sec, 2.8×10^{-6} cm/sec, and 5.3×10^{-7} cm/sec (Terracon, 2020), which have a geometric mean of 3.0×10^{-7} cm/sec.

The maximum gradient possible would be for a constant head of 1-foot above the liner during the entire travel time through the spoils, or $(1 \text{ ft} / 90 \text{ ft} = 0.011 \text{ ft/ft})$. This is a conservative estimate because it is likely that the gradient would be much lower and that there would be intervals of unsaturated transport beneath the clay liner, which is slower than saturated transport.

Using the moisture contents of the samples in the falling head hydraulic conductivity measurements and a particle specific gravity of 2.72 (Terracon, 2020), the four undisturbed porosity measurements were 0.39, 0.45, 0.43, and 0.43. Lower effective porosity results in higher flow velocity so assuming $n_e = 0.39$ is a conservative estimate. Using the values described above, groundwater flow velocity (v) = 3.0×10^{-7} cm/sec * $0.011 \text{ ft/ft} / 0.39 = 8.54 \times 10^{-9}$ cm/sec or 0.00088 ft/year. Assuming a thickness of 90 feet, travel time through the mine spoils under the clay liner is $90 \text{ ft} / 0.00088 \text{ ft/year} = 10,177 \text{ years}$.

Like the mine spoils, the sediments of the Sentinel Butte Formation are predominately native clay sediments and are expected to have lower K_v values. Five undisturbed vertical hydraulic conductivity values for the Sentinel Butte Formation at the WISCO Landfill (Barr, 2013) were 7.0×10^{-9} cm/sec, 1.1×10^{-8} cm/sec, 3.5×10^{-9} cm/sec, 2.5×10^{-9} cm/sec, and 6.7×10^{-9} cm/sec. Six undisturbed vertical hydraulic conductivity values for the Sentinel Butte Formation at the Minnkota Coal Combustion Residuals Unit (Barr, 2012) were 3.6×10^{-8} cm/sec, 5.0×10^{-9} cm/sec, 8.8×10^{-8} cm/sec, 1.2×10^{-8} cm/sec, 1.0×10^{-8} cm/sec, and 1.0×10^{-9} cm/sec. Together, these eleven values have a geometric mean of 8.0×10^{-9} cm/sec.

The gradient is assumed to be a constant head of 1-foot above the liner during the entire travel time through the 80 ft thick Sentinel Butte Formation, or $(1 \text{ ft} / 80 \text{ ft} = 0.0125 \text{ ft/ft})$. This is a conservative estimate because it excludes the layer of spoils above, which, if factored in, would reduce the gradient and therefore the resulting flow velocity. Using the values described above ($K = 8.0 \times 10^{-9}$ cm/sec, $i = 0.0125 \text{ ft/ft}$ and $n_e = 0.39$), the vertical flow velocity (v) through the Sentinel Butte Formation is estimated as $v = 8.0 \times 10^{-9}$ cm/sec * $0.0125 / 0.39 = 2.564 \times 10^{-8}$ cm/sec or 0.00265 ft/year. Given the thickness of the Sentinel Butte Formation overlying the Spaer Bed is approximately 80 feet, travel time is $80 \text{ ft} / 0.00265 \text{ ft/year} = 301,552 \text{ years}$.

Conservatively, this scenario is calculated assuming a breach in the geomembrane liner and a continuous 1 foot of head. The estimated minimum travel time for CCR leachate to travel through the unsaturated

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 6

zone and reach the Spaer Bed is 311,744 years (15 years for the clay liner, 10,177 years for the mine spoils, and 301,552 years for the Sentinel Butte Formation).

2.1.3 Horizontal Migration in Groundwater

Once a hypothetical release has migrated through the liner and unsaturated zone, it could then reach the water table in the Spaer Lignite seam and eventually reach the detection monitoring well. The velocity of horizontal groundwater flow is calculated using the following equation:

$$v = \left(\frac{K}{n_e} \right) \left(\frac{dH}{dL} \right)$$

The average hydraulic gradient $\left(\frac{dH}{dL} \right)$ between upgradient well MW-18S and downgradient wells in the expansion area (MW-24S, MW-25S, MW-26S, and MW-27S) is 0.005 ft/ft based on the October 2024 piezometric surface map. The hydraulic conductivity (K) is 0.234 ft/day and the porosity is 0.185 for the Spaer Lignite according to the Site's CCR Groundwater Monitoring System Report (AECOM, 2017). Using this information in the above equation, groundwater velocity for the wells in the expansion area is 2.45 ft/year.

Since the waste was placed in the lined landfill expansion cell (300 ft to the closest well MW-25S) only a year and a half prior to the fall 2024 detection monitoring event, it is not plausible for any leachate to reach the monitoring wells.

Using a groundwater velocity of 2.45 ft/year, it would take approximately 122 years for a release to reach MW-24S, MW-25S, MW-26S, or MW-27S. CCR placement in the Landfill began in 1996 and the Landfill Expansion Area in 2023. Therefore, the elevated chloride at MW-24S, MW-25S, MW-26S, and MW-27S and elevated boron and calcium at MW-27S cannot be from the CCR unit.

Since the waste was placed in the lined landfill area started in 1996 or about 29 years ago, it is not plausible for any leachate to reach the monitoring wells given these conservative assumptions. If the distances used to calculate travel time are measured from the existing waste limit, the shortest flow path to MW-25S (located closest to the existing landfill boundary) is approximately 1170 feet downgradient. It would take approximately 477 years for leachate from the existing landfill to reach MW-25S and even longer for leachate to reach MW-27S, which is farthest from the CCR waste (approximately 2800 feet).

Assuming that some unidentified preferential flow pathway were to exist, it would have to result in an over four order of magnitude (10,000x) increase in flow rate (or some combination of rate, gradient, or porosity) to allow for a release to reach the boundary. Even in this extreme case, it would still take hundreds of years to reach the downgradient boundary. Such flow rates are not reasonably likely given the construction quality control on the liner, the thickness of the spoils, and the fine-grained nature of the geology and spoils

The long time of travel supports the hypothesis that the CCR unit is not the source of the chloride observed at MW-24S, MW-25S, and MW-26S; and boron, chloride, and calcium at MW-27S.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 7

2.2 Natural Variability in Groundwater

Site specific chloride values are variable at the site and range from 7.84 to 16.0 mg/L at downgradient wells other than those with chloride SSIs in fall 2024 (MW-15S, MW-17S, and MW-22S) from 2016 to 2024. Chloride at upgradient wells (MW-18S, MW-19S, and MW-21S) ranged from 4.38 to 19.4 mg/L as shown on time series graphs in Attachment A.

Further evaluation of sulfate concentrations, which are a principal indicator of a CCR unit release to groundwater, demonstrate that MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S are not impacted by a release from the CCR landfill. Sulfate concentrations during the October 2024 sampling event at these locations ranged from 6.83 mg/L to 131 mg/L. The sulfate concentrations at the upgradient Landfill monitoring locations (MW-18S, MW-19S, and MW-21S) were higher and ranged from 263 to 892 mg/L from 2016 to 2024. At downgradient wells other than those with SSIs (MW-15S, MW-17S, and MW-22S), sulfate concentrations were higher and ranged from 183 to 442 mg/L from 2016 to 2024. Sulfate at MW-16S, MW-20S, MW-24S, MW-25S, and MW-26S is much lower than both upgradient and downgradient monitoring locations.

Although MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S have elevated chloride concentrations compared to upgradient wells, sulfate concentrations are lower compared to the rest of the monitoring locations. The low sulfate at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S suggests that the chloride is unlikely to come from a CCR unit release because groundwater impacted by a release should have elevated concentrations of multiple Appendix III parameters.

Site specific historical groundwater samples have been collected from ten wells also screened in the Spaer Bed to the north and east of the landfill. These wells were installed and sampled in support of a groundwater monitoring program associated with the adjacent surface mine prior to development of the CCR landfill. Chloride concentrations within the Spaer Bed are variable ranging from 5.7 to 59 mg/L. Chloride concentrations at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S (25.8 to 50.0 mg/L) fall within the site-specific background water quality.

Therefore, because other indicators of the CCR unit release are absent and background chloride concentrations are variable within the Spaer Bed, we reject the hypothesis that the CCR unit is the source of the chloride observed at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S.

2.3 Statistical Methods

Interwell prediction limits are currently used to evaluate for SSIs. Interwell prediction limits are valid for the site if the stationarity of the mean and variance are assumed to be constant between upgradient monitoring wells MW-18S, MW-19S, and MW-21S and the downgradient wells (USEPA, 2009). The upgradient monitoring wells are not directly downgradient of a CCR unit (Figure 3). According to the EPA Unified Guidance (USEPA, 2009; page 6-31), interwell tests alone may not be suitable for sites with non-stationarity of distribution mean and variance. Non-stationarity may be expected due to historical mining activities and due to heterogeneity within the lignite documented at the Site.

Therefore, introwell limits are also valid per the guidance. As shown in Table 2 below, using introwell prediction limit methods indicates there are no SSIs for chloride at MW-16S, MW-20S and MW-24S (Attachment B). Using a combination of interwell and introwell methods at the site would account for site

specific heterogeneity and historical conditions and would eliminate the SSI determination at MW-20S and MW-24S.

Table 2 SSIs Compared to Intrawell Prediction Limits

| Event | Well | Parameter (units) | Measured | Intrawell Prediction Limit |
|---------------------------------------|--------|-------------------|----------|----------------------------|
| Detection Monitoring – 2024 #2 (Fall) | MW-16S | Chloride (mg/L) | 26.0 | 29.7 |
| | MW-20S | Chloride (mg/L) | 25.8 | 31.0 |
| | MW-24S | Chloride (mg/L) | 50.0 | 59.4 |

Intrawell methods cannot be used at MW-25S, MW-26S, and MW-27S until at least 8 baseline samples have been collected.

2.4 Trend Testing

If a release from the landfill were occurring, it is likely that the increase in mass to the flow system would cause a change in the chemical equilibrium of the flow system that would reflect changes in concentration overtime. Therefore, if the concentrations of chloride at MW-16S, MW-20S, and MW-24S were due to a release from the landfill there should be evidence of a statistically significant increasing trend.

As shown in Attachment B, each of the data sets were tested for trends using the Mann-Kendall method and no significant trend for chloride were observed at MW-16S, MW-20S, or MW-24S.

This leads to the conclusion that there is no release related to the observed concentrations of chloride at MW-16S, MW-20S, and MW-24S.

2.5 Well Sampling and Development at MW-27S

Monitoring well MW-27S was installed in November 2023, and well development was attempted in April 2024. Approximately one well volume (~4 gallons) was purged during development before the well went dry. It is unlikely that the well was completely developed after this first attempt. The well will need to recharge and be purged multiple times in order to achieve full development.

Based on field notes, low-flow sampling methods were not used during sample collection at MW-27S during the October 2024 detection monitoring event. Specifically, the well was not purged and allowed to stabilize prior to sample collection, instead a hydrosleeve was used to collect the sample due to slow groundwater recharge times.

The preamble to the CCR Rule (VI(K)(3)) notes that "Groundwater sampling should be conducted utilizing EPA protocol low stress (low-flow) purging and sampling methodology, including measurement and stabilization of key indicator parameters prior to sampling." Well stabilization is conducted prior to groundwater sampling in order to obtain a sample representative of aquifer conditions. Properly constructed and developed groundwater monitoring wells allow for the collection of representative samples with low turbidity (U.S. EPA, 1986, 1992). However, even correctly installed wells can produce turbid samples in certain geologic materials. Thus, purging and stabilization are necessary to yield reproducible sampling results. Due to limited recharge, monitoring well MW-27S was not sufficiently

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 9

purged and did not stabilize during the fall 2024 sampling. Field notes from well development are included in Attachment C.

Monitoring well MW-27S has been documented as being slow to recharge (Barr, 2024). Obtaining sufficient groundwater volume for analysis at MW-27S has proven challenging. As a result, the sample sent for laboratory chemical analysis in fall 2024 consisted of the initial draw of water from the well without stabilization. Turbidity readings were too high for the meter and the sample color was described as black, yielding a sample with a high concentration of suspended solids, which may not be representative of typical aquifer conditions. Therefore, the SSI could also be attributed to sampling error.

The CCR Rule requires measurement of “total recoverable metals” because suspended and colloidal particles can also be a means of transport for contaminants. However, the suspended solids responsible for the boron, calcium, and chloride SSIs at monitoring well MW-27S are believed to be natural aquifer material and not mobilized CCR contaminants.

Therefore, due to slow recharge times preventing full development and the well to be purged before sampling, the sample collected from MW-27S is not representative of aquifer conditions and is not a representative sample.

3 Conclusion

An alternative source demonstration for chloride at this site is supported by the following lines of evidence:

- Based on groundwater flow velocities and timing of CCR placement, the elevated chloride (and boron, calcium, and chloride at MW-27S) concentrations could not have come from the CCR unit.
- Chloride in groundwater is variable across the site. While there are somewhat elevated concentrations of chloride in many downgradient wells, there are low sulfate concentrations. Only this single detection monitoring parameter indicated an SSI in several monitoring wells. There is a relative absence of sulfate, a primary indicator of a release, in the groundwater as compared to the presence of sulfate in the water within the upgradient monitoring wells and the downgradient wells with lower chloride. Groundwater chemistry in the expansion area wells is both chemically distinct from the other monitoring wells (background and downgradient) at the CCR unit and chemically distinct from the character of the CCR unit.
- Intrawell statistical methods did not result in SSIs for chloride at MW-16S, MW-20S, and MW-24S. There are not enough baseline samples at MW-25S, MW-26S, and MW-27S for intrawell analyses.
- Well sampling and development limitations due to slow groundwater recharge resulted in high turbidity and the SSIs for boron, calcium, chloride, and TDS at MW-27S.

As this report demonstrates, the SSI analysis presented in Table 1 for monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S is attributed to a source other than the CCR Unit for chloride in the groundwater. The SSI analysis for boron, calcium, and chloride at MW-27S is attributed to sampling techniques due to non-representative aquifer conditions from slow groundwater recharge rates.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 10

Future monitoring data will add to our understanding of the site and the results are expected to augment this ASD and conclusions.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 11

4 References

AECOM, 2024. 2023 Annual Groundwater Monitoring and Corrective Action Report, AVS CCR Landfill. January 2024.

Barr, 2012. Letter to Minnkota Power Cooperative, Inc., Regarding Cells 4, 5, and 6 Drilling Report. May 17, 2012.

Barr, 2013. Site Characterization Investigation Report and Environmental System Plan, WISCO Oilfield Special Waste Landfill, Williston, North Dakota. February 2013.

Barr, 2024. Coal Combustion Residuals Landfill Groundwater Monitoring Well Network Certification, Antelope Valley Station Landfill. June 2024.

Barr, 2025. 2024 Annual Groundwater Monitoring and Corrective Action Report, AVS CCR Landfill. January 2025.

Terracon, 2020. Tests of Soils – Permeability, AVS Landfill Expansion, October 12, 2020.

United States Environmental Protection Agency (USEPA), 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities Unified Guidance. March 2009.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Fall 2024)
Date: March 28, 2025
Page: 12

5 Certification


I certify that the written demonstration provided (above) for chloride in monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S and boron and calcium in MW-27S is supported by the data, accurate, and consistent with our review of the groundwater data collected to date and as required under the CCR Rule ((§ 257.94(e)(2)). I further certify that this report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of North Dakota.



Kevin Solie, P.E.
ND P.E. License No. 9488
Barr Engineering Company



Dated this 28th day of March 2025



Figures



Permit Boundary
Railroad




A horizontal scale bar with three tick marks. The first tick mark is labeled '0'. The second tick mark is labeled '2,500'. The third tick mark is labeled '5,000'. Below the scale bar, the word 'Feet' is centered.


Imagery: USDA-NAIP, 2024


**Site Location
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota**

FIGURE 1

 BARR.








Attachments



Attachment A


Time Series Graphs

Boron, total





Time Series Analysis Run 1/3/2025 10:20 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AV\$_CCR

Calcium, total




Time Series Analysis Run 1/3/2025 10:20 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AV_S_CCR






pH, field




Time Series Analysis Run 1/3/2025 10:20 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AVSS_CCR

Solids, total dissolved



Time Series Analysis Run 1/3/2025 10:20 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AVSS_CCR

Sulfate, as SO₄




Time Series Analysis Run 1/3/2025 10:20 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AVSS_CCR



Attachment B

Statistical Evaluation


Chloride
 Within Limit
 Intrawell Parametric



Background Data Summary (based on natural log transformation): Mean=2.831, Std. Dev.=0.2478, n=19, 5.263% NDs. Seasonality was not detected with 95% confidence. Normally test: Shapiro Wilk @alpha = 0.05, calculated = 0.9118, critical = 0.901. Kappa = 2.301 (c=7, w=10, 1 of 2, event alpha = 0.05132). Report alpha = 0.0007523.

Prediction Limit Analysis Run 3/27/2025 4:55 PM View: All
 Antelope Valley Station Client: Basin Electric Data: BEPC_AVs_CCR


Chloride
 Within Limit
 Intrawell Parametric



Background Data Summary: Mean=49.58, Std. Dev.=3.129, n=8. Seasonality was not detected with 95% confidence. Normally test: Shapiro Wilk @alpha = 0.05, calculated = 0.8682, critical = 0.818. Kappa = 3.133 (c=7, w=10, 1 of 2, event alpha = 0.05132). Report alpha = 0.0007523.

Prediction Limit Analysis Run 3/27/2025 4:55 PM View: All
 Antelope Valley Station Client: Basin Electric Data: BEPC_AVs_CCR

Chloride
 Within Limit
 Intrawell Parametric





Background Data Summary: Mean=22.29, Std. Dev.=3.748, n=18, 5.556% NDs. Seasonality was not detected with 95% confidence. Normally test: Shapiro Wilk @alpha = 0.05, calculated = 0.904, critical = 0.897. Kappa = 2.33 (c=7, w=10, 1 of 2, event alpha = 0.05132). Report alpha = 0.0007523.

Prediction Limit Analysis Run 3/27/2025 4:55 PM View: All
 Antelope Valley Station Client: Basin Electric Data: BEPC_AVs_CCR


Prediction Limit

| Antelope Valley Station | | Client: Basin Electric | | Data: BEPC_AV\$ CCR | | Printed 3/27/2025, 4:57 PM | | | | | |
|-------------------------|--------|------------------------|------------|---------------------|---------|----------------------------|------|-------|-----------|----------|--------------------|
| Constituent | Well | Upper Lim. | Lower Lim. | Date | Observ. | Sig. | Bq_N | %NDS | Transform | Alpha | Method |
| Chloride (mg/l) | MW-16S | 29.7 | n/a | 10/2/2024 | 26 | No | 19 | 5.263 | ln(x) | 0.000... | Param Intra 1 of 2 |
| Chloride (mg/l) | MW-20S | 31 | n/a | 10/1/2024 | 25.8 | No | 18 | 5.556 | No | 0.000... | Param Intra 1 of 2 |
| Chloride (mg/l) | MW-24S | 59.4 | n/a | 10/2/2024 | 50 | No | 8 | 0 | No | 0.000... | Param Intra 1 of 2 |



Sen's Slope and 95% Confidence Band Analysis Run 3/27/2025 4:58 PM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AVSCCR

Sen's Slope and 95% Confidence Band Analysis Run 3/27/2025 4:58 PM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AV5_CCR




Scantech™ v10.0.34 Software | Licensed to Barr Engineering Company, 119

Trend Test

| Antelope Valley Station | | Client: Basin Electric | | Data: BEPC_AV\$_CCR | | Printed 3/27/2025, 4:58 PM | | | | |
|-------------------------|--------|------------------------|----------|---------------------|----|----------------------------|-----------|-------|-------|--------|
| Well | Slope | Calc. | Critical | Sig. | N | %NDs | Normality | Xform | Alpha | Method |
| MN-16S | 1.095 | 62 | 66 | No | 21 | 4.762 | n/a | n/a | 0.05 | NP |
| MN-20S | 0.5175 | 44 | 62 | No | 20 | 5 | n/a | n/a | 0.05 | NP |
| MN-24S | 1.931 | 19 | 23 | No | 10 | 0 | n/a | n/a | 0.05 | NP |

Constituent
Chloride (mg/l)
Chloride (mg/l)
Chloride (mg/l)



Attachment C

Well Development



Barr Engineering Company

Field Log Data Sheet

| Client: <u>Basin Electric</u> | Monitoring Point: <u>MW-27</u> | | | | | | | |
|---------------------------------|--------------------------------|-------------------------------|---|--------------|-------------|--------------|-------------|----------------------------|
| Location: <u>AN5</u> | Date: <u>4-25-2024</u> | | | | | | | |
| Project #: <u>34291126</u> | Sample Time: | | | | | | | |
| GENERAL DATA | | STABILIZATION TEST | | | | | | |
| Barr lock: | <u>Basin</u> | Time/ Volume | Temp. °C | <u>µS/cm</u> | pH | ORP Eh | <u>Mg/L</u> | NTU |
| Casing diameter: | <u>2"</u> | | | | | | | |
| Total well depth:* | <u>229.40</u> | <u>1425</u> <u>3.5 gal</u> | <u>13.5</u> | <u>2572</u> | <u>8.25</u> | <u>-96.3</u> | <u>0.83</u> | <u>Black</u> <u>OOR</u> |
| Static water level:* | <u>205.83</u> | | | | | | | |
| Water depth:* | <u>23.57</u> | | | | | | | |
| Well volume: (gal) | <u>3.84</u> | | | | | | | |
| Purge method: | <u>Bailer</u> | | | | | | | |
| Sample method: | <u>Bailer</u> | | | | | | | |
| Start time: | X | Odor: | <u>None</u> | | | | | |
| Stop time: | X | Purge Appearance: | <u>Dark Brown / Black</u> | | | | | |
| Duration: (minutes) | X | Sample Appearance: | | | | | | |
| Rate, gpm: | | Comments: | <u>Purged dry</u> <u>1 well volume</u> | | | | | |
| Volume, purged: | <u>~ 3.8 gal</u> | | <u>"Sedimentary"</u> | | | | | |
| Duplicate collected? | <u>NA</u> | CO2- | Mn2- | Fe(T)- | Fe2- | | | |
| Sample collection by: | | | | | | | | |
| Others present: | | Well Condition: | <u>New</u> | | | | | |
| MW: groundwater monitoring well | | WS: water supply well | SW: surface water | SE: sediment | other: | | | |
| VOC- | semi-volatile- | general- | nutrient- | cyanide- | DRO- | Sulfide- | | |
| oil, grease- | bacteria- | total metal- | filtered metal- | methane- | filter- | | | |
| Others: | | | | | | | | |

*Measurements are referenced from top of riser pipe, unless otherwise indicated.

Technical Memorandum

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Project: 34291134.00

1 Introduction

Basin Electric Power Cooperative (Basin Electric) owns and operates Antelope Valley Station (AVS), comprised of a coal-fired generating station consisting of two power generating units, located in Beulah, North Dakota (Figure 1). Unit 1 coal-based operations began in 1984, and Unit 2 operations began in 1986. The landfill (Site or CCR Landfill) was permitted by the North Dakota Department of Environmental Quality (NDDEQ) in 1995 under Permit SP-160 (now designated 0160) and began accepting coal combustion residuals (CCR) in 1996. The most recent Permit 0160 was issued by NDDEQ in early 2022, and the most recent cell including a composite liner system and leachate collection system was constructed the same year. Basin Electric utilizes a consulting firm, Barr Engineering Co. (Barr) to assist in groundwater reporting and analysis. Barr is familiar with the site and installed and certified the most recent wells (MW-25S, MW-26S, and MW-27S) added to the network. Barr has reviewed the historical groundwater data and CCR information for the site and is knowledgeable about facility design and operation.

The CCRs including fly ash, bottom ash, and flue gas desulfurization (FGD) waste are managed at the Site along with other minor wastes accepted as per the NDDEQ permit. The CCR unit is required to comply with the provisions of the US Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261, Disposal of Coal Combustion Residuals from Electric Utilities) and the NDDEQ CCR Rule (NDAC Title 33.1, Article 20, Chapter 8).

Basin Electric has implemented a Detection Monitoring Program in accordance with the U.S. Environmental Protection Agency (EPA) CCR Rule (40 CFR Parts 257 and 261) for the Site. As part of the Detection Monitoring Program, statistically significant increases (SSIs) in monitored groundwater quality parameters over background were identified at the Site for the following monitoring wells during semi-annual detection monitoring completed in the spring of 2025 on June 9-11 and 17-18, 2025:

- MW-16S – Chloride
- MW-20S – Chloride
- MW-24S – Chloride
- MW-25S – Chloride
- MW-26S – Chloride
- MW-27S – Boron, calcium, chloride, and total dissolved solids (TDS)

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 2

The CCR Rule (US EPA, 2015) § 257.94(e)(2) allows for an alternative source demonstration (ASD) in the event of an identified SSI in a water quality parameter in a downgradient monitoring well over background levels:

The owner or operator may demonstrate that a source other than the CCR unit caused the statistically significant increase over background levels for a constituent or that the statistically significant increase resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. The owner or operator must complete the written demonstration within 90 days of detecting a statistically significant increase over background levels to include obtaining a certification from a qualified professional engineer verifying the accuracy of the information in the report.

The purpose of this work is to evaluate the data collected as part of the June 2025 monitoring event, along with historical data, to demonstrate if the SSIs are the results of a “source other than the CCR unit” or due to natural variation in groundwater quality or an error in sampling, analysis, or statistical evaluation. Nothing in the foregoing citation of the rule requires that the owner/operator disprove any and all potential counterarguments that EPA or others may offer to refute this demonstration. Such arguments if valid, would need to follow requirements of the rule to show a basis in fact that includes rule requirements that are based on site-specific information. This memorandum provides a science-based reason for the data results that indicate a source other than the CCR unit.

This memorandum provides written documentation of an Alternative Source Demonstration (ASD) and certification of accuracy as described in the CCR Rule (§ 257.94(e)(2)).

1.1 Background Information

Figure 1 shows the site location and Figure 2 provides well locations. A piezometric surface map showing groundwater elevations in the lignite, which represent the uppermost aquifer in the vicinity of the CCR landfill, is presented on Figure 3, using measurements from June 2025. Groundwater generally flows from southwest to northeast.

In late 2023, three new landfill expansion wells, MW-25S, MW-26S, and MW-27S, were installed at the Site. Baseline sampling was initiated in June 2024, and these wells were first evaluated in the detection monitoring program in June 2024. There is limited data at these locations for historical comparison.

A comparison of the detection monitoring groundwater results with the prediction limits calculated using the 2016-2023 background assessment data from upgradient wells MW-18S, MW-19S, and MW-21S are included in Table 1. Concentrations for Appendix III parameters observed in June 2025 are shown on time series graphs in Attachment A. Chloride concentrations at MW-16S, MW-20S, and MW-24S are consistent with those observed during baseline monitoring events. Baseline monitoring for MW-25S, MW-26S, and MW-27S is ongoing.

Table 1 SSIs Compared to Prediction Limits

| Event | Well | Parameter (units) | Measured | Interwell Prediction Limit |
|-------|--------|-------------------|----------|----------------------------|
| | MW-16S | Chloride (mg/L) | 26.0 | 18.7 |
| | MW-20S | Chloride (mg/L) | 25.8 | 18.7 |

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 3

| | | | | |
|--|--------|-------------------------------|-------|------|
| Detection Monitoring – 2025 #1 (Spring) | MW-24S | Chloride (mg/L) | 50.0 | 18.7 |
| | MW-25S | Chloride (mg/L) | 42.3 | 18.7 |
| | MW-26S | Chloride (mg/L) | 29.7 | 18.7 |
| | MW-27S | Boron (mg/L) | 0.40 | 0.17 |
| | MW-27S | Calcium (mg/L) | 206 | 13.0 |
| | MW-27S | Chloride (mg/L) | 62.0 | 18.7 |
| | MW-27S | Total Dissolved Solids (mg/L) | 2,500 | 2230 |

1.2 Rule Requirements

The requirements for written documentation and certification of accuracy for an ASD are included in § 257.95(g) (3):

Within 90 days of finding that any of the constituents listed in appendix IV to this part have been detected at a statistically significant level exceeding the groundwater protection standards the owner or operator must... Demonstrate that a source other than the CCR unit caused the contamination, or that the statistically significant increase resulted from error in sampling, analysis, statistical evaluation, or natural variation in groundwater quality. Any such demonstration must be supported by a report that includes the factual or evidentiary basis for any conclusions and must be certified to be accurate by a qualified professional engineer or approval from the Participating State Director or approval from EPA where EPA is the permitting authority. If a successful demonstration is made, the owner or operator must continue monitoring in accordance with the assessment monitoring program pursuant to this section, and may return to detection monitoring if the constituents in Appendix III and Appendix IV of this part are at or below background as specified in paragraph (e) of this section. The owner or operator must also include the demonstration in the annual groundwater monitoring and corrective action report required by §257.90(e), in addition to the certification by a qualified professional engineer or the approval from the Participating State Director or the approval from EPA where EPA is the permitting authority.

In accordance with the above requirement, this memorandum is being issued within 90 days of the SSI determination (September 29, 2025) following the review and analysis of the results provided in the final laboratory report which was received on July 1, 2025.

2 Potential Alternative Sources Review

The CCR Rule provides five potential alternative source categories:

1. A source other than the CCR unit
2. Sampling (or sampling equipment) methods
3. Laboratory methods
4. Statistical methods
5. Natural variation in groundwater quality

Site data were evaluated to identify potential causes for chloride concentrations in monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, and MW-26S; and boron, calcium, chloride, and TDS concentrations in MW-27S exceeding interwell prediction limits. Chloride is naturally occurring and may not necessarily be the result of a release from a CCR unit; therefore, a source other than the CCR unit, natural variation in groundwater quality, and statistical methods were further investigated as part of the ASD. Sampling methods were further investigated for the boron, calcium, chloride, and total dissolved solids (TDS) SSIs at MW-27S.

2.1 Travel Time from Source of Release

Monitoring locations MW-24S, MW-25S, MW-26S, and MW-27S were added to the monitoring network in anticipation of waste placement in the landfill expansion area (Figure 3). Waste was first placed in lined Cell 5 in the landfill expansion area in May 2023. Groundwater travel time was considered both vertically as groundwater moves through the unsaturated zone and horizontally as groundwater moves in the saturated zone.

2.1.1 Migration through the liner

Vertical migration of leachate would be controlled by the presence of a driving head on the landfill liner and then migration through the unsaturated zone.

Considering the properties of the CCR materials in landfill, that the design to eliminate head on the liner, and the facility pumping operations have been normal, there is no evidence of any leachate accumulation on the liner. However, landfill leachate depth is limited to 1 foot on the liner by rule in North Dakota. Even if the 60-mil thick synthetic liner were breached (again there is no evidence that this has ever occurred), the underlying 2-foot-thick clay liner was tested and verified to exhibit a vertical permeability of 1×10^{-7} cm/s (2.8×10^{-4} feet/day) or less. Assuming a 1-foot driving head over a 2-foot-thick liner yields a vertical hydraulic gradient of 0.5 ft/ft.

The vertical advective velocity (average linear velocity or seepage velocity) of vertical saturated groundwater flow is calculated using the following equation:

$$v = \left(\frac{Kv}{n_e} \right) \left(\frac{dHv}{dLv} \right)$$

Or, stated in a more compact form:

$$v = \frac{Ki}{n_e} \text{, where } K = \text{hydraulic conductivity, } i = \text{gradient, and } n_e = \text{effective porosity.}$$

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 5

Using an effective porosity for clay of 0.40, the above equation yields an advective velocity 3.5×10^{-4} ft/day. Dividing the distance by the velocity yields a travel time of 15.7 years to transit the liner.

2.1.2 Migration through the unsaturated zone

Assuming that the leachate fully breached the liner, the release would then need to transit through the entire unsaturated zone to reach the water table below the facility. Although unsaturated flow can be complex, its calculation can be greatly simplified by making a conservative assumption that the flow is saturated. This is a conservative assumption because unsaturated flow would be characterized by a wetting front (and possible drying cycles) that would result in much lower velocities (longer travel time) than are estimated by assuming saturated flow.

The geologic cross sections and well logs suggest that the mine spoils and Sentinel Butte Formation are thinnest in the vicinity of MW-23S. Assuming that the base of the landfill is at 2050 feet (MSL), the mine spoils are about 90 feet thick at MW-23S, and the Sentinel Butte is about 80 feet thick above the Spaer Bed.

Geotechnical testing of materials at the site has shown mine spoils exhibit relatively low vertical hydraulic conductivities. The four undisturbed vertical hydraulic conductivity values for the mine spoils were 1.3×10^{-7} cm/sec, 4.0×10^{-8} cm/sec, 2.8×10^{-6} cm/sec, and 5.3×10^{-7} cm/sec (Terracon, 2020), which have a geometric mean of 3.0×10^{-7} cm/sec.

The maximum gradient possible would be for a constant head of 1-foot above the liner during the entire travel time through the spoils, or $(1 \text{ ft} / 90 \text{ ft} = 0.011 \text{ ft/ft})$. This is a conservative estimate because it is likely that the gradient would be much lower and that there would be intervals of unsaturated transport beneath the clay liner, which is slower than saturated transport.

Using the moisture contents of the samples in the falling head hydraulic conductivity measurements and a particle specific gravity of 2.72 (Terracon, 2020), the four undisturbed porosity measurements were 0.39, 0.45, 0.43, and 0.43. Lower effective porosity results in higher flow velocity so assuming $n_e = 0.39$ is a conservative estimate. Using the values described above, groundwater flow velocity (v) = 3.0×10^{-7} cm/sec * $0.011 \text{ ft/ft} / 0.39 = 8.54 \times 10^{-9}$ cm/sec or 0.00088 ft/year. Assuming a thickness of 90 feet, travel time through the mine spoils under the clay liner is $90 \text{ ft} / 0.00088 \text{ ft/year} = 10,177 \text{ years}$.

Like the mine spoils, the sediments of the Sentinel Butte Formation are predominately native clay sediments and are expected to have lower K_v values. Five undisturbed vertical hydraulic conductivity values for the Sentinel Butte Formation at the WISCO Landfill (Barr, 2013) were 7.0×10^{-9} cm/sec, 1.1×10^{-8} cm/sec, 3.5×10^{-9} cm/sec, 2.5×10^{-9} cm/sec, and 6.7×10^{-9} cm/sec. Six undisturbed vertical hydraulic conductivity values for the Sentinel Butte Formation at the Minnkota Coal Combustion Residuals Unit (Barr, 2012) were 3.6×10^{-8} cm/sec, 5.0×10^{-9} cm/sec, 8.8×10^{-8} cm/sec, 1.2×10^{-8} cm/sec, 1.0×10^{-8} cm/sec, and 1.0×10^{-9} cm/sec. Together, these eleven values have a geometric mean of 8.0×10^{-9} cm/sec.

The gradient is assumed to be a constant head of 1-foot above the liner during the entire travel time through the 80 ft thick Sentinel Butte Formation, or $(1 \text{ ft} / 80 \text{ ft} = 0.0125 \text{ ft/ft})$. This is a conservative estimate because it excludes the layer of spoils above, which, if factored in, would reduce the gradient and therefore the resulting flow velocity. Using the values described above ($K = 8.0 \times 10^{-9}$ cm/sec, $i =$

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 6

0.0125 ft/ft and $n_e = 0.39$), the vertical flow velocity (v) through the Sentinel Butte Formation is estimated as $v = 8.0 \times 10^{-9} \text{ cm/sec} * 0.0125 / 0.39 = 2.564 \times 10^{-8} \text{ cm/sec}$ or 0.00265 ft/year. Given the thickness of the Sentinel Butte Formation overlying the Spaer Bed is approximately 80 feet, travel time is $80 \text{ ft} / 0.00265 \text{ ft/year} = 301,552 \text{ years}$.

Conservatively, this scenario is calculated assuming a breach in the geomembrane liner and a continuous 1 foot of head. The estimated minimum travel time for CCR leachate to travel through the unsaturated zone and reach the Spaer Bed is 311,744 years (15 years for the clay liner, 10,177 years for the mine spoils, and 301,552 years for the Sentinel Butte Formation).

2.1.3 Horizontal Migration in Groundwater

Once a hypothetical release has migrated through the liner and unsaturated zone, it could then reach the water table in the Spaer Lignite seam and eventually reach the detection monitoring well. The velocity of horizontal groundwater flow is calculated using the following equation:

$$v = \left(\frac{K}{n_e} \right) \left(\frac{dH}{dL} \right)$$

The average hydraulic gradient ($\frac{dH}{dL}$) between upgradient well MW-18S and downgradient wells in the expansion area (MW-24S, MW-25S, MW-26S, and MW-27S) is 0.005 ft/ft based on the June 2025 piezometric surface map. The hydraulic conductivity (K) is 0.234 ft/day and the porosity is 0.185 for the Spaer Lignite according to the Site's CCR Groundwater Monitoring System Report (AECOM, 2017). Using this information in the above equation, groundwater velocity for the wells in the expansion area is 2.42 ft/year.

Since the waste was placed in the lined landfill expansion cell (300 ft to the closest well MW-25S) only two years prior to the spring 2025 detection monitoring event, it is not plausible for any leachate to reach the monitoring wells.

Using a groundwater velocity of 2.42 ft/year, it would take approximately 124 years for a release to reach MW-24S, MW-25S, MW-26S, or MW-27S. CCR placement in the Landfill began in 1996 and the Landfill Expansion Area in 2023. Therefore, the elevated chloride at MW-24S, MW-25S, MW-26S, and MW-27S and elevated boron, calcium, and TDS at MW-27S cannot be from the CCR unit.

Since the waste was placed in the lined landfill area started in 1996 or about 29 years ago, it is not plausible for any leachate to reach the monitoring wells given these conservative assumptions. If the distances used to calculate travel time are measured from the existing waste limit, the shortest flow path to MW-25S (located closest to the existing landfill boundary) is approximately 1170 feet downgradient. It would take approximately 477 years for leachate from the existing landfill to reach MW-25S and even longer for leachate to reach MW-27S, which is farthest from the CCR waste (approximately 2800 feet).

Assuming that some unidentified preferential flow pathway were to exist, it would have to result in an over four order of magnitude (10,000x) increase in flow rate (or some combination of rate, gradient, or porosity) to allow for a release to reach the boundary. Even in this extreme case, it would still take hundreds of years to reach the downgradient boundary. Such flow rates are not reasonably likely given

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 7

the construction quality control on the liner, the thickness of the spoils, and the fine-grained nature of the geology and spoils

The long time of travel supports the hypothesis that the CCR unit is not the source of the chloride observed at MW-24S, MW-25S, and MW-26S; and boron, chloride, calcium, and TDS at MW-27S.

2.2 Natural Variability in Groundwater

Site specific chloride values are variable at the site and range from 7.84 to 16.0 mg/L at downgradient wells other than those with chloride SSIs in spring 2025 (MW-15S, MW-17S, and MW-22S) from 2016 to 2025. Chloride at upgradient wells (MW-18S, MW-19S, and MW-21S) ranged from 4.38 to 19.4 mg/L as shown on time series graphs in Attachment A.

Further evaluation of sulfate concentrations, which are a principal indicator of a CCR unit release to groundwater, demonstrate that MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S are not impacted by a release from the CCR landfill. Sulfate concentrations during the June 2025 sampling event at these locations ranged from 29.8 mg/L to 230 mg/L. The sulfate concentrations at the upgradient Landfill monitoring locations (MW-18S, MW-19S, and MW-21S) were higher and ranged from 263 to 892 mg/L from 2016 to 2025. At downgradient wells other than those with SSIs (MW-15S, MW-17S, and MW-22S), sulfate concentrations were higher and ranged from 183 to 442 mg/L from 2016 to 2025. Sulfate at MW-16S, MW-20S, MW-24S, MW-25S, and MW-26S is much lower than both upgradient and downgradient monitoring locations.

Although MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S have elevated chloride concentrations compared to upgradient wells, sulfate concentrations are lower compared to the rest of the monitoring locations. The low sulfate at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S suggests that the chloride is unlikely to come from a CCR unit release because groundwater impacted by a release should have elevated concentrations of multiple Appendix III parameters.

Site specific historical groundwater samples have been collected from ten wells also screened in the Spaer Bed to the north and east of the landfill. These wells were installed and sampled in support of a groundwater monitoring program associated with the adjacent surface mine prior to development of the CCR landfill. Chloride concentrations within the Spaer Bed are variable ranging from 5.7 to 59 mg/L. Chloride concentrations at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S (24.6 to 64.9 mg/L) are similar to the site-specific background water quality.

To further test the hypothesis of a natural variability in the groundwater, a Piper diagram (Figure 4) was used to visually compare the measured groundwater quality at the Site. Piper diagrams are plots of major ion chemistry of water samples (calcium, magnesium, potassium, sodium, chloride, sulfate, and [bicarbonate]) that are used to differentiate between water types and to identify potential mixing of water types. The Piper diagram provides a means to identify or "fingerprint" water samples by their common characteristics (major ions) to assess which types of water are similar or dissimilar to potential source water types (Helsel et al., 2020). On the Piper diagram depicted in Figure 4, downgradient well compositions are shown as red symbols, and the upgradient well compositions as purple symbols using the spring 2025 sample results.

The Piper diagram shows the upgradient wells (MW-18S and MW-19S) as a sodium, sulfate and bicarbonate mixed type water. Downgradient wells and upgradient well (MW-21S) are characterized as

sodium bicarbonate type water. The upgradient wells (MW-18S and MW-19S) have a higher proportion of sulfate compared to downgradient wells. Wells MW-20S, MW-24S, MW-25S and MW-26S have the lowest proportion of sulfate. The water quality at MW-27S has a greater proportion of calcium and magnesium compared to the other monitoring locations. These differences underscore the natural variability within the groundwater system.

Therefore, because other indicators of the CCR unit release are absent and background chloride concentrations are variable within the Spaer Bed, we reject the hypothesis that the CCR unit is the source of the chloride observed at MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S.

2.4 Statistical Methods

Interwell prediction limits are currently used to evaluate for SSIs. Interwell prediction limits are valid for the site if the stationarity of the mean and variance are assumed to be constant between upgradient monitoring wells MW-18S, MW-19S, and MW-21S and the downgradient wells (USEPA, 2009). The upgradient monitoring wells are not directly downgradient of a CCR unit (Figure 3). According to the EPA Unified Guidance (USEPA, 2009; page 6-31), interwell tests alone may not be suitable for sites with non-stationarity of distribution mean and variance. Non-stationarity may be expected due to historical mining activities and due to heterogeneity within the lignite documented at the Site.

Therefore, intrawell limits are also valid per the guidance. As shown in Table 2 below, using intrawell prediction limit methods indicates there are no SSIs for chloride at MW-16S, MW-20S and MW-24S (Attachment B). Using a combination of interwell and intrawell methods at the site would account for site specific heterogeneity and historical conditions and would eliminate the SSI determination at MW-20S and MW-24S.

Table 2 SSIs Compared to Intrawell Prediction Limits

| Event | Well | Parameter (units) | Measured | Intrawell Prediction Limit |
|---|--------|-------------------|----------|----------------------------|
| Detection Monitoring – 2025 #1 (Spring) | MW-16S | Chloride (mg/L) | 26.2 | 29.7 |
| | MW-20S | Chloride (mg/L) | 24.6 | 31.0 |
| | MW-24S | Chloride (mg/L) | 49.6 | 59.4 |

Intrawell methods cannot be used at MW-25S, MW-26S, and MW-27S until at least 8 baseline samples have been collected.

2.5 Well Sampling and Development at MW-27S

Monitoring well MW-27S was installed in November 2023, and well development was attempted in April 2024. Approximately one well volume (~4 gallons) was purged during development before the well went dry. It is unlikely that the well was completely developed after this first attempt. The well will need to recharge and be purged multiple times in order to achieve full development.

Based on field notes, low-flow sampling methods were not used during sample collection at MW-27S during the June 2025 detection monitoring event. Specifically, the well was not purged and allowed to

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 9

stabilize prior to sample collection, instead a hydrosleeve was used to collect the sample due to slow groundwater recharge times.

The preamble to the CCR Rule (VI(K)(3)) notes that "Groundwater sampling should be conducted utilizing EPA protocol low stress (low-flow) purging and sampling methodology, including measurement and stabilization of key indicator parameters prior to sampling." Well stabilization is conducted prior to groundwater sampling in order to obtain a sample representative of aquifer conditions. Properly constructed and developed groundwater monitoring wells allow for the collection of representative samples with low turbidity (U.S. EPA, 1986, 1992). However, even correctly installed wells can produce turbid samples in certain geologic materials. Thus, purging and stabilization are necessary to yield reproducible sampling results. Due to limited recharge, monitoring well MW-27S was not sufficiently purged and did not stabilize during the spring 2025 sampling. Field notes from well development are included in Attachment C.

Monitoring well MW-27S has been documented as being slow to recharge (Barr, 2024). Obtaining sufficient groundwater volume for analysis at MW-27S has proven challenging. As a result, the sample sent for laboratory chemical analysis in spring 2025 consisted of the initial draw of water from the well without stabilization. Turbidity readings were too high for the meter and the sample color was described as black, yielding a sample with a high concentration of suspended solids, which may not be representative of typical aquifer conditions. Therefore, the SSI could also be attributed to sampling error.

The CCR Rule requires measurement of "total recoverable metals" because suspended and colloidal particles can also be a means of transport for contaminants. However, the suspended solids responsible for the boron, calcium, chloride, and TDS SSIs at monitoring well MW-27S are believed to be natural aquifer material and not mobilized CCR contaminants.

Therefore, due to slow recharge times preventing full development and the well to be purged before sampling, the sample collected from MW-27S is not representative of aquifer conditions and is not a representative sample.

3 Conclusion

An alternative source demonstration for chloride at this site is supported by the following lines of evidence:

- Based on groundwater flow velocities and timing of CCR placement, the elevated chloride (and boron, calcium, and chloride at MW-27S) concentrations could not have come from the CCR unit.
- Chloride in groundwater is variable across the site. While there are somewhat elevated concentrations of chloride in many downgradient wells, there are low sulfate concentrations. Only this single detection monitoring parameter indicated an SSI in several monitoring wells. There is a relative absence of sulfate, a primary indicator of a release, in the groundwater as compared to the presence of sulfate in the water within the upgradient monitoring wells and the downgradient wells with lower chloride. Groundwater chemistry in the expansion area wells is both chemically distinct from the other monitoring wells (background and downgradient) at the CCR unit and chemically distinct from the character of the CCR unit.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 10

- Intrawell statistical methods did not result in SSIs for chloride at MW-16S, MW-20S, and MW-24S. There are not enough baseline samples at MW-25S, MW-26S, and MW-27S for intrawell analyses.
- Well sampling and development limitations due to slow groundwater recharge resulted in high turbidity and the SSIs for boron, calcium, chloride, and TDS at MW-27S.

As this report demonstrates, the SSI analysis presented in Table 1 for monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S is attributed to a source other than the CCR Unit for chloride in the groundwater. The SSI analysis for boron, calcium, chloride, and TDS at MW-27S is attributed to sampling techniques due to non-representative aquifer conditions from slow groundwater recharge rates. Future monitoring data will add to our understanding of the site and the results are expected to augment this ASD and conclusions.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 11

4 References

AECOM, 2024. 2023 Annual Groundwater Monitoring and Corrective Action Report, AVS CCR Landfill. January 2024.

Barr, 2012. Letter to Minnkota Power Cooperative, Inc., Regarding Cells 4, 5, and 6 Drilling Report. May 17, 2012.

Barr, 2013. Site Characterization Investigation Report and Environmental System Plan, WISCO Oilfield Special Waste Landfill, Williston, North Dakota. February 2013.

Barr, 2024. Coal Combustion Residuals Landfill Groundwater Monitoring Well Network Certification, Antelope Valley Station Landfill. June 2024.

Barr, 2025. 2024 Annual Groundwater Monitoring and Corrective Action Report, AVS CCR Landfill. January 2025.

Terracon, 2020. Tests of Soils – Permeability, AVS Landfill Expansion, October 12, 2020.

United States Environmental Protection Agency (USEPA), 2009. Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities Unified Guidance. March 2009.

To: Mark Dihle, Basin Electric Power Cooperative
From: Barr Engineering Co.
Subject: Alternative Source Demonstration (ASD), Antelope Valley Station (Spring 2025)
Date: December 22, 2025
Page: 12

5 Certification


I certify that the written demonstration provided (above) for chloride in monitoring wells MW-16S, MW-20S, MW-24S, MW-25S, MW-26S, and MW-27S and boron, calcium, and TDS in MW-27S is supported by the data, accurate, and consistent with our review of the groundwater data collected to date and as required under the CCR Rule ((§ 257.94(e)(2)). I further certify that this report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of North Dakota.



Kevin Solie, P.E.
ND P.E. License No. 9488
Barr Engineering Company




Dated this 22th day of December 2025



Figures





Bar Footer: ArcGIS Pro 3.3.1, 2025-03-26 11:07 File: N:\\Projects\\34291-134\\MangAmdo\\Valley_Station_Alternative_Source\\Antelope_Valley_Station_Alternative_Source\\Layout\\Figure 2 Monitoring Network User LGK2

- Groundwater Monitoring System Wells
- △ Water Level Only Monitoring
- Permit Boundary
- Existing Landfill Limits
- ▨ Future Expansion Limit
- ▨ Leachate Management Area
- ▨ Limits of Ash as of 2025 (approximate)




0 300 600
Feet

Imagery: USDA-NAIP, 2024

Monitoring Network
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota

FIGURE 2

BARR.



- Groundwater Monitoring System Wells
- △ Water Level Only Monitoring
- Permit Boundary
- Existing Landfill Limits
- Future Expansion Limit
- ▨ Leachate Management Area
- Limits of Ash as of 2025 (approximate)



0 300 600

Feet

Imagery: USDA-NAIP, 2024

**Spring 2025 Potentiometric Surface
Antelope Valley Station
Basin Electric Power Cooperative
Beulah, North Dakota**

FIGURE 3

BARR.

Upgradient Wells

MW-18S

MW-19S

MW-21S

Downgradient Wells

MW-15S

MW-16S

MW-17S

MW-20S


MW-22S

MW-24S

MW-25S

MW-26S

MW-27S






Attachments




Attachment A

Time Series Graphs

Boron, total




Calcium, total




Time Series Analysis Run 12/3/2025 9:16 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AV_S_CCR

Chloride




Time Series Analysis Run 12/3/2025 9:16 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AV_S_CCR


Fluoride





Time Series Analysis Run 12/2/2025 11:11 AM View: All
Antelope Valley Station Client: Basin Electric Data: BEPC_AVSS_CCR

pH, field










Attachment B


Statistical Evaluation

Within Limit
 Chloride
 Intrawell Parametric




Prediction Limit Analysis Run 11/24/2025 8:35 PM View: All
 Antelope Valley Station Client: Basin Electric Data: BEPC_AVSCCR

Within Limit
 Chloride
 Intrawell Parametric



Prediction Limit Analysis Run 11/24/2025 8:37 PM View: All
 Antelope Valley Station Client: Basin Electric Data: BEPC_AVSCCR

Within Limit
 Chloride
 Intrawell Parametric



Prediction Limit Analysis Run 11/24/2025 8:36 PM View: All
 Antelope Valley Station Client: Basin Electric Data: BEPC_AVSCCR

Intrawell Prediction Limit

| Antelope Valley Station | | Client: Basin Electric | | Data: BEPC_AVSCCR | | Printed 11/24/2025, 8:41 PM | | | | | |
|-------------------------|-------------|------------------------|-------------------|-------------------|---------------|-----------------------------|-------------|-------------|------------------|--------------|---------------|
| <u>Constituent</u> | <u>Well</u> | <u>Upper Lim.</u> | <u>Lower Lim.</u> | <u>Date</u> | <u>Obsrv.</u> | <u>Sig.</u> | <u>Bq_N</u> | <u>%NDS</u> | <u>Transform</u> | <u>Alpha</u> | <u>Method</u> |
| Chloride (mg/l) | MW-20S | 31 | n/a | 6/10/2025 | 24.6 | No | 18 | 5.556 | No | 0.000... | Param 1 of 2 |
| Chloride (mg/l) | MW-24S | 59.4 | n/a | 6/17/2025 | 49.6 | No | 8 | 0 | No | 0.000... | Param 1 of 2 |
| Chloride (mg/l) | MW-16S | 29.7 | n/a | 6/11/2025 | 26.2 | No | 19 | 5.263 | ln(x) | 0.000... | Param 1 of 2 |



Attachment C

Well Development



Barr Engineering Company Field Log Data Sheet

| Client: Basin Electric | | Monitoring Point: MW-27 | | | | | | |
|---------------------------------|----------------|-------------------------|-----------------------------|--------------|--------|-----------|------|--------------|
| Location: ANS CCR Wells | | Date: 4-25-2024 | | | | | | |
| Project #: 34291126 | | Sample Time: | | | | | | |
| GENERAL DATA | | STABILIZATION TEST | | | | | | |
| Barr lock: | Basin | Time/ Volume | Temp. °C | μS/cm | pH | ORP Eh | Mg/L | NTU |
| Casing diameter: | 2" | | | | | | | |
| Total well depth:* | 229.40 | 1425 3.5 gal | 13.5 | 2572 | 8.25 | -96.3 | 0.83 | Black OOR |
| Static water level:* | 205.83 | | | | | | | |
| Water depth:* | 23.57 | | | | | | | |
| Well volume: (gal) | 3.84 | | | | | | | |
| Purge method: | Bailey | | | | | | | |
| Sample method: | Bailey | | | | | | | |
| Start time: | X | Odor: | None | | | | | |
| Stop time: | X | Purge Appearance: | Dark Brown / Black | | | | | |
| Duration: (minutes) | X | Sample Appearance: | | | | | | |
| Rate, gpm: | | Comments: | Purged dry 1 well volume | | | | | |
| Volume, purged: | ~ 3.8 gal | | | | | | | |
| Duplicate collected? | NA | | "sedimentary" | | | | | |
| Sample collection by: | | CO2- | Mn2- | Fe(T)- | Fe2- | | | |
| Others present: | | Well Condition: | New | | | | | |
| MW: groundwater monitoring well | | WS: water supply well | SW: surface water | SE: sediment | other: | | | |
| VOC- | semi-volatile- | general- | nutrient- | cyanide- | DRO- | Sulfide- | | |
| oil, grease- | bacteria- | total metal- | filtered metal- | methane- | | filter- | | |
| Others: | | | | | | | | |

*Measurements are referenced from top of riser pipe, unless otherwise indicated.



Appendix C

Groundwater Flow Rate

Appendix C
Groundwater Flow Rate
2025
Annual Monitoring Report
AVS CCR Groundwater Compliance

AVS Groundwater Velocity Calculation

| Date | 6/10/2025 | UG: MW-19S | UG: MW-18S | |
|------------------------------------|-----------|------------|------------|--|
| Kh (ft/d) | 0.234 | 0.234 | | CCR Groundwater Monitoring System Report (AECOM, 2017) |
| porosity, n | 0.185 | 0.185 | | CCR Groundwater Monitoring System Report (AECOM, 2017) |
| Average gradient, i (ft/ft) | 0.002 | 0.004 | | |
| Average V (ft/d) | 3.069E-03 | 5.450E-03 | | |
| Average V (ft/yr) | 1.12 | 1.99 | | |
| Flow Direction | E-NE | NE | | |

| | Top of Casing Elevation | Depth to Water | Water Level Elevation |
|---------------|--------------------------------|-----------------------|------------------------------|
| | ft amsl | ft below TOC | ft amsl |
| MW-15S | 2104.77 | 218.96 | 1885.81 |
| MW-16S | 2123.59 | 235.82 | 1887.77 |
| MW-17S | 2124.89 | 238.45 | 1886.44 |
| MW-18S | 2091.60 | 199.13 | 1892.47 |
| MW-19S | 2042.56 | 149.40 | 1893.16 |
| MW-20S | 2107.47 | 220.60 | 1886.87 |
| MW-21S | 2094.72 | 202.75 | 1891.97 |
| MW-22S | 2093.90 | 210.14 | 1883.76 |
| MW-24S | 2070.74 | 206.22 | 1864.52 |
| MW-25S | 2083.40 | 198.66 | 1884.74 |
| MW-26S | 2074.50 | 190.65 | 1883.85 |
| MW-27S | 2071.60 | 208.00 | 1863.60 |

Not used for flow or gradient calculations

AVS Landfill horizontal distance, ft

| | MW-19S | MW-18S |
|---------------|---------------|---------------|
| MW-15S | 2640 | |
| MW-16S | 2746 | |
| MW-17S | 2904 | |
| MW-20S | 2746 | |
| MW-22S | 3379 | |
| MW-24S | | 3643 |
| MW-25S | | 2904 |
| MW-26S | | 3326 |
| MW-27S | | 3590 |

*Used UG well *Used UG well
MW-19S for MW- MW-18S for MW-
15S, 16S, 17S, 24S, 25S, and
20S, and 22S flow 26S flow
calculations calculations

Appendix C
Groundwater Flow Rate
2025
Annual Monitoring Report
AVS CCR Groundwater Compliance

AVS difference in WL elevation, ft

| | MW-19S | MW-18S |
|---------------|---------------|---------------|
| MW-15S | 7.35 | |
| MW-16S | 5.39 | |
| MW-17S | 6.72 | |
| MW-20S | 6.29 | |
| MW-22S | 9.40 | |
| MW-24S | | 27.95 |
| MW-25S | | 7.73 |
| MW-26S | | 8.62 |

AVS horizontal gradient, ft/ft

| | MW-19S | MW-18S |
|----------------|---------------|---------------|
| MW-15S | 0.003 | |
| MW-16S | 0.002 | |
| MW-17S | 0.002 | |
| MW-20S | 0.002 | |
| MW-22S | 0.003 | |
| MW-24S | | 0.008 |
| MW-25S | | 0.003 |
| MW-26S | | 0.003 |
| Average | 0.002 | 0.004 |

Appendix C
Groundwater Flow Rate
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

AVS Groundwater Velocity Calculation

Date

10/6/2025

UG: MW-19S

UG: MW-18S

| | | |
|--------------------------|-------------|-----------|
| Kh (ft/d) | 0.234 | 0.234 |
| porosity, n | 0.185 | 0.185 |
| Average gradient, | 0.002 | 0.005 |
| Average V (ft/d) | 2.900E-03 | 6.156E-03 |
| Average V (ft/yr) | 1.06 | 2.25 |
| Flow Direction | E-NE | NE |

CCR Groundwater Monitoring System Report (AECOM, 2017)
CCR Groundwater Monitoring System Report (AECOM, 2017)

| | Top of Casing Elevation | Depth to Water | Water Level Elevation |
|---------------|--------------------------------|-----------------------|------------------------------|
| | ft amsl | ft below TOC | ft amsl |
| MW-15S | 2104.77 | 218.90 | 1885.87 |
| MW-16S | 2123.59 | 236.31 | 1887.28 |
| MW-17S | 2124.89 | 238.32 | 1886.57 |
| MW-18S | 2091.60 | 199.17 | 1892.43 |
| MW-19S | 2042.56 | 149.75 | 1892.81 |
| MW-20S | 2107.47 | 220.22 | 1887.25 |
| MW-21S | 2094.72 | 202.78 | 1891.94 |
| MW-22S | 2093.90 | 210.03 | 1883.87 |
| MW-24S | 2070.74 | 206.27 | 1864.47 |
| MW-25S | 2083.40 | 198.10 | 1885.30 |
| MW-26S | 2074.50 | 190.43 | 1884.07 |
| MW-27S | 2071.60 | 203.67 | 1867.93 |

AVS Landfill horizontal distance, ft

| | MW-19S | MW-18S |
|---------------|---------------|---------------|
| MW-15S | 2640 | |
| MW-16S | 2746 | |
| MW-17S | 2904 | |
| MW-20S | 2746 | |
| MW-22S | 3379 | |
| MW-24S | | 3643 |
| MW-25S | | 2904 |
| MW-26S | | 3326 |
| MW-27S | | 3590 |

MW-19S for MW-15S, 16S, 17S, 20S, and 22S flow calculations

MW-18S for MW-24S, 25S, and 26S flow calculations

Appendix C
Groundwater Flow Rate
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

AVS difference in WL elevation, ft

| | MW-19S | MW-18S |
|---------------|---------------|---------------|
| MW-15S | 6.94 | |
| MW-16S | 5.53 | |
| MW-17S | 6.24 | |
| MW-20S | 5.56 | |
| MW-22S | 8.94 | |
| MW-24S | | 27.96 |
| MW-25S | | 7.13 |
| MW-26S | | 8.36 |
| MW-27S | | 24.50 |

AVS horizontal gradient, ft/ft

| | MW-19S | MW-18S |
|----------------|---------------|---------------|
| MW-15S | 0.003 | |
| MW-16S | 0.002 | |
| MW-17S | 0.002 | |
| MW-20S | 0.002 | |
| MW-22S | 0.003 | |
| MW-24S | | 0.008 |
| MW-25S | | 0.002 |
| MW-26S | | 0.003 |
| MW-27S | | 0.007 |
| Average | 0.002 | 0.005 |



Appendix D

Baseline Sample Results

Appendix D
Baseline Sampling
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

| Parameter | Location | WW-25S | | WW-25S | | WW-25S | | WW-25S | | WW-25S | | WW-25S | |
|---|-----------------|----------|----------------|--------|----------------|----------|----------|-----------|-----------------|----------------|----------|-----------|--------------|
| | | Date | Sample Type | N | ID | N | N | N | N | N | N | N | N |
| Analysis Location | | | | | | | | | | | | | |
| General Parameters | | | Units | | | | | | | | | | |
| Alkalinity, bicarbonate, as CaCO ₃ | Lab | mg/l | — | — | — | 1488 | 1529 | — | — | 1335 | 1367 | — | — |
| Alkalinity, carbonate, as CaCO ₃ | Lab | mg/l | — | — | — | <20.5 U | 24 | — | — | <20.5 U | <20.5 U | — | — |
| Alkalinity, total, as CaCO ₃ | Lab | mg/l | — | — | — | 1489 | 1553 | — | — | 1336 | 1382 | — | — |
| Chloride | Lab | mg/l | 43.8 | 43.3 | 42.3 | 39.6 | 40.4 | 29.7 | 28.7 | 30.6 | 31.5 | 80.8 | 62.0 |
| Fluoride | Lab | mg/l | 1.29 | 1.29 | 1.30 | 1.26 | 1.42 | 1.34 | 1.33 | 1.28 | 1.36 | 1.17 | 1.27 |
| pH | Lab | pH units | — | — | — | 8.2 | 8.4 | — | — | 8.2 | 8.4 | — | — |
| Solids, total dissolved | Lab | mg/l | 1800 | 1900 | 1910 | 1940 | 1760 | 1730 | 1820 | 1870 | 2280 | 2160 | — |
| Sulfates, as SO ₄ | Lab | mg/l | 24.6 | 24.7 | 40.2 | 29.6 | 36.0 | 45.1 | 44.0 | 75.9 | 120 | 252 | 6.83 |
| Dissolved oxygen | Field | mg/l | 0.49 | — | 0.27 | 0.49 | 0.31 | 0.35 | 0.28 | 0.46 | 1.44 | 3.45 | 1.72 |
| pH | Field | pH units | 8.18 | — | 8.19 | 8.15 | 8.18 | 8.15 | 8.17 | 8.08 | 8.63 | 8.08 | — |
| Redox (oxidation potential) | Field | mV | -3 | — | -34 | -368.7 | -313.8 | -43.2 | -32.3 | -371.8 | -348.6 | -123.4 | -116.9 |
| Specific conductance @ 25 deg C | Field | umhos/cm | 2889 | — | 2918 | 3004 | 3014 | 2685 | 2678 | 2801 | 2884 | 3016 | 3063 |
| Temperature | Field | deg C | 9.3 | — | 10.6 | 10.0 | 9.8 | 10.9 | 11.2 | 10.5 | 12.2 | 8.5 | 11.5 |
| Turbidity | Field | NTU | 37.7 | — | 14.3 | 16.3 | 9.98 | 27.9 | 19.7 | 14.3 | 11.2 | 570 | — |
| Total Metals | | | | | | | | | | | | | |
| Antimony | Lab | mg/l | <0.001 U | — | — | <0.001 U | <0.001 U | <0.001 U | <0.001 U | <0.001 U | <0.001 U | <0.001 U | <0.001 U |
| Arsenic | Lab | mg/l | <0.002 U | — | — | <0.002 U | <0.002 U | <0.002 U | <0.002 U | <0.002 U | <0.016 | 0.0472 | — |
| Barium | Lab | mg/l | 0.0994 | — | 0.1306 | — | — | — | — | — | — | — | 1.472 |
| Beryllium | Lab | mg/l | <0.0005 U | — | <0.0005 U | — | — | <0.0005 U | <0.0005 U | <0.0005 U | — | — | 0.0002 |
| Boron | Lab | mg/l | 0.12 | 0.11 | 0.12 | 0.14 | 0.13 | 0.14 | 0.14 | 0.13 | 0.12 | 0.19 | 0.40 |
| Cadmium | Lab | mg/l | <0.0005 U | — | <0.0005 U | — | — | <0.0005 U | <0.0005 U | — | — | 0.0007 | 0.0036 |
| Calcium | Lab | mg/l | 6.12 | 5.95 | 4.38 | 4.01 | 4.56 | 4.10 | 3.51 | 11.0 | 17.3 | 28.3 | 206 |
| Chromium | Lab | mg/l | 0.0025 | — | <0.002 U | — | — | <0.002 U | <0.002 U | <0.002 U | — | 0.0053 | 0.5667 |
| Cobalt | Lab | mg/l | <0.002 U | — | <0.002 U | — | — | <0.002 U | <0.002 U | <0.002 U | — | 0.0141 | 0.0932 |
| Lead | Lab | mg/l | 0.0006 | — | <0.0005 U | — | — | <0.0005 U | <0.0005 U | <0.0005 U | — | 0.0206 | 0.1238 |
| Lithium | Lab | mg/l | 0.0430 | — | 0.0426 | — | — | 0.0490 | 0.0483 | — | — | 0.0755 | 0.201 |
| Magnesium | Lab | mg/l | — | — | — | — | — | — | — | — | — | — | — |
| Mercury | Lab | mg/l | <0.0002 U | — | <0.0002 U | — | — | <0.0002 U | <0.0002 U | <0.0002 U | — | <0.0002 U | <0.001 U |
| Molybdenum | Lab | mg/l | 0.0933 | — | 0.0920 | — | — | — | 0.0052 | <0.002 U | — | — | 0.1457 |
| Potassium | Lab | mg/l | — | — | <0.0005 U | — | — | <0.0005 U | <0.0005 U | <0.0005 U | — | — | — |
| Selenium | Lab | mg/l | <0.0005 U | — | <0.0005 U | — | — | <0.0005 U | <0.0005 U | <0.0005 U | — | — | — |
| Sodium | Lab | mg/l | — | — | — | 826 | 834 | — | <0.0005 U | <0.0005 U | — | — | — |
| Thallium | Lab | mg/l | <0.0005 U | — | <0.0005 U | — | — | <0.0005 U | <0.0005 U | <0.0005 U | — | — | 0.0011 |
| Radiochemical Parameters | | | | | | | | | | | | | |
| Radium 226 | Lab | pCi/l | 0.3 +/- 0.2 ND | — | — | — | — | — | 0.08 +/- 0.2 ND | 0.1 +/- 0.1 ND | — | — | 5.7 +/- 5.3 |
| Radium 228 | Lab | pCi/l | 1.1 +/- 0.9 ND | — | 0.2 +/- 0.8 ND | — | — | — | 0.5 +/- 0.8 ND | 1.6 +/- 0.9 | — | — | 12.3 +/- 5.7 |
| Radium, combined (226+228) | Bar Calculation | pCi/l | 1.4 +/- 0.9 q | — | 0.3 +/- 0.8 ND | — | — | — | 0.58 +/- 0.8 ND | 1.7 +/- 0.9 q | — | — | 18.0 +/- 7.8 |

Appendix D
Baseline Sampling
2025 Annual Monitoring Report
AVS CCR Groundwater Compliance

| Parameter | Analysis Location | Units | Location | | Location | |
|--|-------------------|----------|----------|-------------|-----------|---|
| | | | Date | Sample Type | 6/17/2025 | N |
| General Parameters | | | | | | |
| Alkalinity, bicarbonate as CaCO ₃ | Lab | mg/l | 1659 | | 1678 | |
| Alkalinity, carbonate as CaCO ₃ | Lab | mg/l | < 20.5 | U | < 20.5 | U |
| Alkalinity, total as CaCO ₃ | Lab | mg/l | 1659 | | 1666 | |
| Chloride | Lab | mg/l | 64.9 | | 65.0 | |
| Fluoride | Lab | mg/l | 1.41 | | 1.48 | |
| pH | Lab | pH-units | 8.2 | | 8.3 | |
| Solids, total dissolved | Lab | mg/l | 2500 | | 2370 | |
| Sulfide, as SO ₄ ²⁻ | Lab | mg/l | 141 | | | |
| Dissolved oxygen | Field | mg/l | 0.28 | | 0.25 | |
| pH | Field | pH-units | 8.10 | | 7.96 | |
| Redox (oxidation potential) | Field | mV | 44.2 | | -292.9 | |
| Specific conductance @ 25 deg C | Field | umhos/cm | 3191 | | 3254 | |
| Temperature | Field | deg C | 12.7 | | 12.0 | |
| Turbidity | Field | NTU | — | | 999 | |
| Total Metals | | | | | | |
| Antimony | Lab | mg/l | — | | — | |
| Arsenic | Lab | mg/l | — | | — | |
| Barium | Lab | mg/l | — | | — | |
| Beryllium | Lab | mg/l | — | | — | |
| Boron | Lab | mg/l | 0.68 | | 0.21 | |
| Cadmium | Lab | mg/l | — | | — | |
| Calcium | Lab | mg/l | 419 | | 58.1 | |
| Chromium | Lab | mg/l | — | | — | |
| Cobalt | Lab | mg/l | — | | — | |
| Lead | Lab | mg/l | — | | — | |
| Lithium | Lab | mg/l | — | | — | |
| Magnesium | Lab | mg/l | 152 | | 27.4 | |
| Mercury | Lab | mg/l | — | | — | |
| Molybdenum | Lab | mg/l | — | | — | |
| Potassium | Lab | mg/l | 27.4 | | 11.1 | |
| Selenium | Lab | mg/l | — | | — | |
| Sodium | Lab | mg/l | 1040 | | 932 | |
| Thallium | Lab | mg/l | — | | — | |
| Radiochemical Parameters | | | | | | |
| Radium 226 | Lab | pCi/l | — | | — | |
| Radium 228 | Lab | pCi/l | — | | — | |
| Radium, combined (226+228) | Bar Calculation | pCi/l | — | | — | |